

OHA - Drinking Water Services - Surface Water Quality Data Form

County:

Clackamas

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

Month/Year:

Nov, 2025

System Name:		City of Sandy		ID#: 4100789C		WTP: TP- Bull Run	
	12AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU] *1
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							

Slow Sand/Membrane/DE Filtration/Unfiltered

95% of daily turbidity readings $\leq$ 1 NTU? *2	PWB	CT's met Everyday? (see back)	ALL CL2 residuals at Entry Point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	PWB	(Yes) No	(Yes) No

NOTES:

PWB TURBIDITY REPORTED BY PWB

Printed Name: Brian Hutchins	DATE: 11/3/2025
Signature: 	CERT#: 6660
PHONE #: 503-572-3788	

*1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. *2 Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP-: Bull Run

System Name: City of Sandy ID#: 4100789 C Month/Year: Nov / 2025												Disinfection Giardia Log Inactiv:		3	
Date / Time	CT Headworks to Larsen					CT Larsen to Hudson					Temp	Required CT	CT Met? *3	Combined Inactivation	
	pH	Minimum Cl2 Residual	Contact Time (T)	Actual CT	Required CT	pH	Minimum Cl2 Residual	Contact Time (T)	Actual CT	Required CT					
		[ppm or mg/L]	[minutes]	C X T	formula		[ppm or mg/L]	[minutes]	C X T	formula					[° C]
1	6.92	2.32	65.99	153.09	102.39	6.92	3.03	99.67	301.99	110.99	13.43	213.38	Yes	4.22	
2	6.94	2.58	66.20	170.79	108.60	6.94	3.06	99.98	305.93	114.68	13.10	223.27	Yes	4.24	
3	6.97	2.53	66.26	167.63	109.33	6.97	3.08	100.07	308.21	116.37	13.08	225.70	Yes	4.18	
4	6.86	2.41	65.79	158.55	105.79	6.86	2.94	99.43	292.32	112.34	12.76	218.13	Yes	4.10	
5	6.83	2.55	66.14	168.65	112.00	6.83	2.99	99.92	298.77	117.61	12.26	229.61	Yes	4.05	
6	6.82	2.62	64.27	168.39	114.32	6.82	3.08	97.06	298.94	120.33	12.01	234.65	Yes	3.96	
7	6.78	2.56	64.36	164.76	116.37	6.78	3.03	97.15	294.35	122.64	11.42	239.01	Yes	3.82	
8	6.80	2.64	64.35	169.88	117.92	6.80	3.21	97.16	311.89	125.69	11.46	243.62	Yes	3.92	
9	6.79	2.63	65.25	171.60	120.88	6.79	3.12	98.50	307.31	127.71	11.01	248.59	Yes	3.83	
10	6.74	2.80	66.36	185.81	124.45	6.74	3.16	100.16	316.51	129.59	10.59	254.04	Yes	3.94	
11	6.73	2.79	66.44	185.38	124.93	6.73	3.17	100.27	317.86	130.39	10.46	255.33	Yes	3.92	
12	6.79	2.74	67.59	185.18	126.87	6.79	3.17	102.05	323.51	133.17	10.46	260.04	Yes	3.89	
13	6.74	2.63	67.77	178.23	125.42	6.74	3.13	101.71	318.35	132.69	10.18	258.11	Yes	3.82	
14	6.67	2.78	66.91	186.00	125.12	6.67	3.15	101.07	318.37	130.45	10.10	255.57	Yes	3.93	
15	6.66	2.81	67.37	189.30	125.60	6.66	3.19	101.63	324.21	131.09	10.04	256.70	Yes	3.98	
16	6.66	2.81	61.73	173.47	125.85	6.66	3.19	93.24	297.45	131.35	10.01	257.20	Yes	3.64	
17	6.65	2.81	61.70	173.39	126.07	6.65	3.21	93.10	298.85	131.88	9.93	257.95	Yes	3.64	
18	6.65	2.83	61.71	174.65	126.35	6.65	3.23	93.05	300.56	132.18	9.93	258.54	Yes	3.66	
19	6.69	2.76	61.44	169.58	126.63	6.69	2.71	92.85	251.61	125.92	9.99	252.55	Yes	3.34	
20	6.67	2.80	61.33	171.72	127.73	6.67	2.73	92.56	252.70	126.73	9.82	254.46	Yes	3.34	
21	6.69	2.83	61.43	173.85	129.92	6.69	2.78	92.75	257.85	129.19	9.72	259.11	Yes	3.33	
22	6.69	2.84	61.41	174.40	131.36	6.69	2.78	92.56	257.32	130.47	9.57	261.83	Yes	3.30	
23	6.70	2.79	66.80	186.37	131.42	6.70	2.74	100.81	276.21	130.68	9.53	262.11	Yes	3.53	
24	6.70	2.76	65.71	181.35	131.76	6.70	2.63	99.09	260.60	129.84	9.44	261.60	Yes	3.38	
25	6.70	2.79	66.68	186.04	132.82	6.70	2.66	100.68	267.80	130.88	9.37	263.70	Yes	3.45	
26	6.70	2.71	74.39	201.61	132.50	6.70	2.61	112.42	293.42	131.01	9.27	263.50	Yes	3.76	
27	6.70	2.75	74.38	204.54	133.71	6.70	2.65	112.33	297.67	132.21	9.20	265.92	Yes	3.78	
28	6.69	2.82	71.97	202.96	134.48	6.69	2.70	108.77	293.67	132.67	9.18	267.15	Yes	3.72	
29	6.71	2.73	72.00	196.56	134.68	6.71	2.63	108.68	285.83	133.16	9.11	267.84	Yes	3.61	
30	6.69	2.81	66.82	187.78	137.93	6.69	2.73	100.85	275.31	136.69	8.78	274.62	Yes	3.38	

*3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised June 2015