

OHA - Drinking Water Services - Surface Water Quality Data Form

County:

Clackamas

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

Month/Year:

Jan, 2026

System Name: City of Sandy ID#: 4100789C WTP: TP- Bull Run EP-C

	12AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU] *1
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							

Reported by PWB

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? *2	PWB	CT's met Everyday? (see back)	ALL CL2 residuals at Entry Point ≥ 0.2mg/l?
All daily turbidity readings ≤ 5 NTU?	PWB	(Yes / No)	(Yes / No)
NOTES: PWB TURBIDITY REPORTED BY PWB		Printed Name: BRAN HUTCHINS	DATE: 2/3/2026
		Signature: <i>[Signature]</i>	CERT#: 6660
		PHONE #: 503-572-3788	

*1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. *2 Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

EP-C

OHA - Drinking Water Program - Surface Water Quality Data Form													WTP-: Bull Run	Disinfection Log Inactiv: 3
System Name: City of Sandy			ID#: 4100789 C			Month/Year: Jan / 2026								
Date / Time	CT Headworks to Larsen					CT Larsen to Hudson					Temp	Required CT	CT Met? *3	CTcalc / CTrequired Combined
	pH	Minimum Cl2 Residual	Contact Time (T)	Actual CT	Required CT	pH	Minimum Cl2 Residual	Contact Time (T)	Actual CT	Required CT				
		[ppm or mg/L]	[minutes]	C X T	formula		[ppm or mg/L]	[minutes]	C X T	formula	[° C]	formula	Yes / No	Ratio
1	6.35	3.05	68.68	209.47	144.01	6.35	2.63	103.60	272.48	137.29	6.73	281.30	Yes	3.44
2	6.36	3.13	68.00	212.85	146.53	6.36	2.61	102.49	267.51	138.11	6.66	284.63	Yes	3.39
3	6.37	2.89	65.79	190.13	143.36	6.37	2.65	99.47	263.59	139.50	6.63	282.87	Yes	3.22
4	6.38	2.95	66.49	196.15	145.05	6.38	2.68	100.33	268.87	140.66	6.61	285.71	Yes	3.26
5	6.40	2.95	67.00	197.66	147.16	6.40	2.65	101.09	267.88	142.21	6.50	289.38	Yes	3.23
6	6.41	2.90	89.55	259.69	147.04	6.41	2.60	133.14	346.16	142.10	6.48	289.14	Yes	4.20
7	6.43	2.76	95.27	262.96	146.23	6.43	2.63	134.16	352.85	144.08	6.43	290.30	Yes	4.25
8	6.45	2.77	83.02	229.96	147.44	6.45	2.68	116.69	312.73	145.93	6.43	293.37	Yes	3.70
9	6.46	2.69	84.05	226.10	147.80	6.46	2.58	118.18	304.90	145.95	6.31	293.75	Yes	3.62
10	6.47	2.67	84.10	224.55	147.49	6.47	2.57	118.32	304.08	145.82	6.36	293.31	Yes	3.61
11	6.47	2.68	85.39	228.84	148.55	6.47	2.59	120.07	310.97	147.03	6.27	295.58	Yes	3.66
12	6.48	1.14	86.25	98.33	126.44	6.48	2.59	121.31	314.19	149.04	6.12	275.48	Yes	2.89
13	6.48	2.68	87.08	233.38	150.78	6.48	2.60	122.73	319.09	149.41	6.10	300.19	Yes	3.68
14	6.47	2.74	85.10	233.18	152.40	6.50	2.59	123.26	319.24	151.41	5.99	303.81	Yes	3.64
15	6.48	2.70	84.83	229.04	151.84	6.51	2.42	122.76	297.09	148.63	6.03	300.47	Yes	3.51
16	6.48	2.71	84.81	229.84	152.01	6.51	2.55	122.88	313.34	150.86	6.03	302.87	Yes	3.59
17	6.50	2.74	84.79	232.33	154.76	6.51	2.63	122.84	323.07	153.37	5.92	308.13	Yes	3.61
18	6.52	2.76	85.82	236.86	158.55	6.52	2.65	120.72	319.91	156.56	5.70	315.12	Yes	3.54
19	6.51	2.81	83.60	234.91	161.16	6.55	2.61	121.05	315.94	159.76	5.49	320.92	Yes	3.44
20	6.51	2.80	83.63	234.18	161.40	6.55	2.60	120.98	314.54	160.01	5.45	321.41	Yes	3.42
21	6.56	2.68	85.77	229.86	163.71	6.56	2.75	120.57	331.58	165.04	5.30	328.75	Yes	3.41
22	6.57	2.68	86.82	232.69	166.53	6.57	2.64	122.16	322.51	165.76	5.10	332.29	Yes	3.34
23	6.53	2.77	85.28	236.21	166.09	6.58	2.63	123.45	324.67	166.39	5.08	332.48	Yes	3.37
24	6.58	2.71	87.69	237.64	169.99	6.58	2.63	123.41	324.57	168.42	4.90	338.41	Yes	3.33
25	6.59	2.66	87.32	232.27	170.88	6.59	2.58	122.91	317.12	169.31	4.79	340.19	Yes	3.23
26	6.60	2.68	87.35	234.09	171.90	6.60	2.59	122.84	318.15	170.12	4.79	342.01	Yes	3.23
27	6.60	2.67	87.27	233.00	172.16	6.60	2.61	122.80	320.51	170.97	4.75	343.14	Yes	3.23
28	6.55	2.69	84.81	228.14	169.83	6.61	2.57	122.91	315.89	171.14	4.72	340.97	Yes	3.19
29	6.55	2.70	84.85	229.10	170.14	6.61	2.63	122.88	323.17	172.45	4.71	342.59	Yes	3.22
30	6.59	2.37	84.83	201.05	164.59	6.66	2.30	122.88	282.62	167.42	4.85	332.00	Yes	2.91
31	6.59	2.37	83.47	197.82	164.92	6.66	2.30	120.76	277.74	167.76	4.82	332.68	Yes	2.86

*3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.