

OHA - Drinking Water Services - Surface Water Quality Data Form

County: **Clackamas**

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

Month/Year: **Feb, 2026**

System Name:		City of Sandy			ID#: 4100789C		WTP: TP- Bull Run	
	12AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU] *	
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
Slow Sand/Membrane/DE Filtration/Unfiltered				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings ≤ 1 NTU? **				PWB		CT's met Everyday? (see back)		ALL CL2 residuals at Entry Point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?				PWB		Yes / No		Yes / No
NOTES:				Printed Name: Brian Hutchins				
PWB TURBIDITY REPORTED BY PWB				Signature <i>Brian Hutchins</i>			DATE: 3/2/2026	
				PHONE #: 503-572-3788			CERT#: 6660	

Reported by PWB

* Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ** Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP-: Bull Run

System Name:		City of Sandy		ID#: 4100789 EP-C		Month/Year Feb / 2026		Disinfection Giardia Log Inactivation:		3			
CT Headworks to Larsen (Leg 1 of 2)						CT Larsen to Hudson (Leg 2 of 2)							
Date / Time	pH	Minimum Cl2 Residual	Contact Time (T)	CT Calc	CT Required	pH	Minimum Cl2 Residual	Contact Time (T)	CT Calc	CT Required	Temp	CT Met? *	CTcalc / CTRequired Combined
		[ppm or mg/L]	[minutes]	C X T	formula		[ppm or mg/L]	[minutes]	C X T	formula	[° C]	Yes / No	ok if >1
1	6.60	2.37	83.45	197.77	163.74	6.66	2.30	120.87	277.99	165.96	4.98	Yes	2.88
2	6.65	2.35	86.02	202.16	167.44	6.65	2.35	121.05	284.47	167.44	4.88	Yes	2.91
3	6.67	2.29	86.02	196.99	166.03	6.67	2.29	120.94	276.95	166.03	5.01	Yes	2.85
4	6.60	2.37	84.66	200.64	162.20	6.68	2.29	122.80	281.22	165.39	5.12	Yes	2.94
5	6.61	2.38	85.32	203.05	160.79	6.58	2.25	123.60	278.10	156.72	5.32	Yes	3.04
6	6.62	2.36	85.24	201.16	161.87	6.58	2.25	123.41	277.67	157.56	5.24	Yes	3.01
7	6.62	2.35	84.22	197.91	162.56	6.57	2.24	122.05	273.39	157.66	5.16	Yes	2.95
8	6.62	2.32	82.13	190.54	161.34	6.58	2.22	119.60	265.51	157.23	5.22	Yes	2.87
9	6.62	2.38	79.27	188.66	163.23	6.57	2.32	116.18	269.54	159.23	5.15	Yes	2.85
10	6.60	2.28	82.61	188.36	160.42	6.60	2.22	116.18	257.92	159.32	5.13	Yes	2.79
11	6.60	2.38	83.64	199.06	159.68	6.60	2.24	117.52	263.24	157.13	5.37	Yes	2.92
12	6.66	2.34	87.66	205.13	161.86	6.66	2.22	123.07	273.21	159.64	5.42	Yes	2.98
13	6.65	2.36	87.45	206.39	163.18	6.65	2.26	122.88	277.70	161.31	5.28	Yes	2.99
14	6.64	2.28	89.34	203.69	160.56	6.64	2.26	126.10	284.99	160.19	5.33	Yes	3.05
15	6.69	2.30	88.60	203.78	163.29	6.69	2.20	124.57	274.05	161.42	5.38	Yes	2.95
16	6.67	2.36	87.80	207.20	163.36	6.67	2.26	123.45	278.99	161.49	5.37	Yes	3.00
17	6.70	2.30	83.17	191.29	164.54	6.68	2.19	123.45	270.35	161.31	5.32	Yes	2.84
18	6.71	2.29	83.26	190.67	163.62	6.69	2.17	123.37	267.72	160.22	5.44	Yes	2.84
19	6.67	2.39	84.01	200.79	164.15	6.65	2.29	124.33	284.72	161.11	5.35	Yes	2.99
20	6.67	2.37	78.26	185.48	163.22	6.67	2.31	109.91	253.88	162.10	5.40	Yes	2.70
21	6.70	2.35	75.97	178.52	164.50	6.67	2.26	108.74	245.74	161.06	5.41	Yes	2.61
22	6.68	2.26	77.36	174.84	162.18	6.68	2.26	108.86	246.01	162.18	5.36	Yes	2.59
23	6.68	2.25	88.22	198.50	161.88	6.68	2.21	124.22	274.52	161.14	5.37	Yes	2.93
24	6.67	2.30	82.47	189.69	162.24	6.67	2.29	116.05	265.75	162.05	5.37	Yes	2.81
25	6.68	2.43	72.99	177.37	166.06	6.34	2.32	135.16	313.58	145.23	5.30	Yes	3.23
26	6.69	2.46	72.97	179.50	166.34	6.21	2.24	136.27	305.25	136.71	5.38	Yes	3.31
27	6.67	2.49	74.31	185.03	164.16	6.17	2.22	139.22	309.08	133.26	5.52	Yes	3.45
28	6.67	2.48	62.90	155.99	164.08	6.05	2.26	117.28	265.04	128.42	5.51	Yes	3.01

* If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.