

OHA - Drinking Water Services - Surface Water Quality Data Form

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Clackamas**
 Month/Year: **Mar, 2026**

System Name:	City of Sandy			ID#: 4100789C	WTP: TP- Bull Run		
	12AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day [NTU] *
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							

Reported by PWB

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? **	PWB	CT's met Everyday? (see back)	ALL CL2 residuals at Entry Point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	PWB	Yes / No	Yes / No
NOTES: PWB TURBIDITY REPORTED BY PWB		Printed Name: Brian Hutchins	DATE: 4/2/26
		Signature: <i>Brian Hutchins</i>	CERT#: 6660
		PHONE #: (503) 572-3788	

* Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ** Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP-: Bull Run

System Name: City of Sandy ID#: 4100789 EP-C Month/Year Mar / 2026												Disinfection Giardia Log Inactivation:	3
CT Headworks to Larsen (Leg 1 of 2)						CT Larsen to Hudson (Leg 2 of 2)							
Date / Time	pH	Minimum Cl2 Residual	Contact Time (T)	CT Calc	CT Required	pH	Minimum Cl2 Residual	Contact Time (T)	CT Calc	CT Required	Temp	CT Met? *	CTcalc / CTRequired Combined
		[ppm or mg/L]	[minutes]	C X T	formula		[ppm or mg/L]	[minutes]	C X T	formula	[° C]	Yes / No	ok if >1
1	6.67	2.55	53.74	137.03	165.86	5.94	2.27	100.24	227.53	124.04	5.47	Yes	2.66
2	6.67	2.55	54.37	138.64	164.97	5.89	2.28	100.74	229.69	121.39	5.55	Yes	2.73
3	6.69	2.46	63.73	156.77	162.68	5.86	2.21	118.32	261.49	117.96	5.71	Yes	3.18
4	6.68	2.37	64.47	152.79	160.32	5.83	2.28	119.92	273.42	117.58	5.72	Yes	3.28
5	6.67	2.41	62.97	151.76	163.20	5.82	2.30	117.21	269.57	119.36	5.47	Yes	3.19
6	6.68	2.38	65.80	156.61	160.29	5.80	2.26	122.61	277.10	115.95	5.74	Yes	3.37
7	6.67	2.43	67.44	163.88	159.67	5.81	2.30	125.39	288.39	116.19	5.83	Yes	3.51
8	6.67	2.37	69.22	164.06	159.10	5.83	2.26	129.00	291.54	116.86	5.78	Yes	3.53
9	6.65	2.35	70.32	165.24	159.63	5.86	2.26	130.82	295.65	119.55	5.59	Yes	3.51
10	6.65	2.39	61.63	147.29	158.97	5.86	2.28	114.74	261.62	118.81	5.72	Yes	3.13
11	6.67	0.06	61.31	3.68	121.43	5.85	2.23	114.45	255.22	116.36	5.90	Yes	2.22
12	6.64	2.22	70.29	156.05	153.89	5.83	2.16	131.03	283.03	114.96	5.86	Yes	3.48
13	6.64	2.22	70.29	156.05	153.89	5.83	2.16	131.03	283.03	114.96	5.86	Yes	3.48
14	6.58	2.34	70.49	164.96	151.60	5.84	2.25	131.60	296.09	115.69	5.97	Yes	3.65
15	6.47	2.34	70.54	165.06	146.07	5.85	2.26	131.60	297.41	116.45	5.94	Yes	3.68
16	6.45	2.33	70.49	164.25	144.39	5.83	2.26	131.29	296.72	115.27	5.99	Yes	3.71
17	6.43	2.37	70.54	167.18	144.12	5.84	2.27	131.68	298.92	115.88	5.98	Yes	3.74
18	6.44	2.54	69.94	177.65	145.22	5.83	2.28	130.22	296.90	113.89	6.21	Yes	3.83
19	6.44	2.61	76.04	198.45	144.93	5.82	2.35	141.90	333.46	113.28	6.36	Yes	4.31
20	6.42	2.65	76.69	203.23	144.66	5.82	2.39	143.22	342.31	113.85	6.35	Yes	4.41
21	6.41	2.68	77.52	207.75	145.80	5.82	2.38	144.99	345.09	114.62	6.23	Yes	4.44
22	6.42	2.64	72.33	190.95	144.21	5.82	2.41	135.03	325.42	113.89	6.38	Yes	4.18
23	6.45	2.58	62.92	162.33	143.03	5.81	2.33	117.21	273.09	111.19	6.56	Yes	3.59
24	6.45	2.60	63.53	165.18	143.46	5.82	2.34	118.46	277.20	111.77	6.55	Yes	3.63
25	6.45	2.49	63.62	158.41	143.00	5.83	2.28	118.57	270.33	112.42	6.41	Yes	3.51
26	6.47	2.44	76.35	186.29	140.46	5.84	2.24	142.46	319.10	110.23	6.70	Yes	4.22
27	6.51	2.35	75.98	178.56	136.78	5.82	2.15	141.75	304.76	105.23	7.16	Yes	4.20
28	6.51	2.51	75.98	190.72	139.56	5.84	2.33	141.75	330.27	108.28	7.13	Yes	4.42
29	6.50	2.46	64.00	157.45	139.48	5.85	2.26	119.13	269.24	108.73	7.00	Yes	3.61
30	6.48	2.51	64.00	160.65	141.15	5.86	2.31	119.10	275.11	111.13	6.80	Yes	3.61
31	6.54	2.43	64.00	155.53	136.75	5.86	2.21	119.27	263.60	105.34	7.46	Yes	3.64

* If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.