

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Columbia

Conventional or Direct Filtration

Month/Year: Aug-25

System Name:		City of Scappoose		ID#: 41	00792	WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.03
2	0.01	0.01	0.01	0.01	0.01	0.01	0.06
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.05	0.01	0.01	0.05
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.02	0.02	0.02	0.07
7	0.02	0.01	0.01	0.01	0.01	0.01	0.02
8	0.01	0.01	0.01	OFF	0.01	0.01	0.07
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.05	0.01	0.01	0.05
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.03	0.03	0.03	0.05
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.07
15	0.03	0.03	0.03	0.03	0.03	OFF	0.03
16	OFF	OFF	0.03	0.04	0.03	0.04	0.07
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.04	0.03	0.03	0.09
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.04	0.03	0.03	0.09
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.09
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.10
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	OFF	0.04	0.03	0.03	0.09
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.04	0.03	0.03	0.10
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.09
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes	Yes	Yes
All turbidity readings < IFE ² triggers	Yes		

Notes:	PRINTED NAME: Darryl Sykes	
	SIGNATURE: <i>Darryl Sykes</i>	9/9/2025
	PHONE #: (503-543-5894)	CERT #: 2863

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:	City of Scappoose	ID#: 4100792	Aug-25	Disinfection <i>Giardia</i> Log Inactiv:	1
--------------	-------------------	--------------	--------	---	---

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1		1.06	98	104.0	16.7	7.72	32.0	YES	2289
2		1.05	277	289.5	15.7	7.76	34.6	YES	906
3		1.00	81	81.1	17.4	8.21	36.3	YES	2801
4		1.08	396	425.7	16.0	7.94	36.4	YES	520
5		1.06	82	86.5	15.7	7.70	33.9	YES	2627
6		1.41	266	375.1	15.4	7.64	35.2	YES	925
7		1.01	120	121.6	15.6	7.72	34.2	YES	1969
8		1.03	310	319.0	16.0	7.65	32.5	YES	796
9		1.03	82	84.7	15.5	7.71	34.4	YES	2779
10		1.12	264	296.2	15.4	7.69	34.7	YES	904
11		1.00	80	79.6	15.5	7.69	34.0	YES	2766
12		0.99	199	196.2	15.7	7.61	32.5	YES	1033
13		0.89	72	64.0	15.8	7.62	32.1	YES	2765
14		0.84	284	237.4	16.0	7.64	31.7	YES	758
15		0.81	117	94.5	16.7	7.60	29.7	YES	2118
16		0.93	312	289.8	15.3	7.58	32.8	YES	819
17		0.97	110	106.9	16.1	7.70	32.7	YES	1819
18		1.10	227	249.7	15.8	7.81	35.3	YES	1019
19		1.00	87	87.0	17.5	7.71	30.0	YES	2702
20		0.91	296	269.4	15.9	7.60	31.7	YES	741
21		0.92	110	100.7	16.5	7.60	30.5	YES	1741
22		1.03	189	194.7	16.9	8.40	40.4	YES	1065
23		1.03	89	91.7	17.0	8.10	35.9	YES	2150
24		0.94	268	253.0	17.4	8.30	37.3	YES	848
25		0.98	86	84.6	16.3	7.72	32.6	YES	2789
26		0.99	290	287.4	17.3	8.50	40.7	YES	839
27		0.97	122	118.7	18.1	8.65	40.7	YES	2035
28		0.99	305	302.0	17.0	8.67	44.1	YES	815
29		0.92	121	111.3	18.0	8.73	41.9	YES	1816
30		1.01	367	370.7	17.1	8.50	41.3	YES	695
31		0.94	88	82.9	17.4	8.68	42.9	YES	1587

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013