

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **Columbia**
 Month/Year: **Mar-26**

Conventional or Direct Filtration

System Name:	City of Scappoose		ID#: 41	00792	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	off	off	off	off	No Surface Flow
2	off	off	off	off	off	off	No Surface Flow
3	off	off	off	off	off	off	No Surface Flow
4	off	off	off	off	off	off	No Surface Flow
5	off	off	off	off	off	off	No Surface Flow
6	off	off	off	off	off	off	No Surface Flow
7	off	off	off	off	off	off	No Surface Flow
8	off	off	off	off	off	off	No Surface Flow
9	off	off	off	0.03	off	off	0.06
10	off	off	off	0.03	off	off	0.06
11	off	off	off	off	off	off	No Surface Flow
12	off	off	off	off	off	off	No Surface Flow
13	off	off	off	off	off	off	No Surface Flow
14	off	off	off	off	off	off	No Surface Flow
15	off	off	off	off	off	off	No Surface Flow
16	off	off	off	off	off	off	No Surface Flow
17	off	off	off	off	off	off	No Surface Flow
18	off	off	off	off	off	off	No Surface Flow
19	off	off	off	off	off	off	No Surface Flow
20	off	off	off	off	off	off	No Surface Flow
21	off	off	off	off	off	off	No Surface Flow
22	off	off	off	off	off	off	No Surface Flow
23	off	off	off	off	off	off	No Surface Flow
24	off	off	off	off	off	off	No Surface Flow
25	off	off	off	off	off	off	No Surface Flow
26	off	off	off	off	off	off	No Surface Flow
27	off	off	off	0.03	off	off	0.08
28	off	off	off	off	off	off	No Surface Flow
29	off	off	off	off	off	off	No Surface Flow
30	off	off	off	off	off	off	No Surface Flow
31	off	off	off	0.03	0.03	0.03	0.05

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes	CT's met everyday? (see back) Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes
All 4-hour turbidity readings ≤ 1 NTU? Yes		
All turbidity readings < IFE ² triggers Yes		

Notes:	PRINTED NAME: Kevin Turner	
	SIGNATURE: <i>Kevin Turner</i>	
	PHONE #: (503-543-5894)	CERT #: 9379

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: City of Scappoose				ID#: 4100792	Month/Year	Mar-26	WTP - :	A
							Disinfection <i>Giardia</i> Log Inactiv:	1

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1									No Surface Flow
2									No Surface Flow
3									No Surface Flow
4									No Surface Flow
5									No Surface Flow
6									No Surface Flow
7									No Surface Flow
8									No Surface Flow
9	10:15	0.80	1256	1004.8	11.5	7.80	45.2	Yes	210
10									No Surface Flow
11	7:30	0.81	171	139.0	11.3	7.70	44.3	Yes	1574
12									No Surface Flow
13									No Surface Flow
14									No Surface Flow
15									No Surface Flow
16									No Surface Flow
17									No Surface Flow
18									No Surface Flow
19									No Surface Flow
20									No Surface Flow
21									No Surface Flow
22									No Surface Flow
23									No Surface Flow
24									No Surface Flow
25									No Surface Flow
26									No Surface Flow
27	11:30	0.70	606	424.2	12.2	7.50	38.5	Yes	523
28									No Surface Flow
29									No Surface Flow
30									No Surface Flow
31	12:30	0.71	139	98.7	12.0	7.70	41.8	Yes	1622

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.