


OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: CLATSOP

21-Mar

System Name: SEASIDE ID#: 4100799 WTP - : A							
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.019	0.028	0.022	0.028
2	0.020	0.020	0.000	0.044	0.030	0.024	0.044
3	0.022	0.000	0.000	0.022	0.051	0.024	0.051
4	0.020	0.000	0.000	0.028	0.022	0.020	0.028
5	0.018	0.000	0.000	0.018	0.040	0.020	0.040
6	0.020	0.018	0.000	0.000	0.000	0.000	0.020
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.018	0.034	0.022	0.034
9	0.020	0.018	0.000	0.018	0.018	0.022	0.022
10	0.020	0.000	0.000	0.018	0.026	0.018	0.026
11	0.020	0.000	0.000	0.020	0.018	0.020	0.020
12	0.020	0.000	0.000	0.018	0.024	0.020	0.024
13	0.018	0.018	0.000	0.000	0.000	0.000	0.018
14	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.018	0.022	0.020	0.022
16	0.018	0.020	0.000	0.026	0.020	0.022	0.026
17	0.020	0.000	0.000	0.019	0.026	0.022	0.026
18	0.020	0.020	0.000	0.020	0.024	0.022	0.024
19	0.020	0.000	0.000	0.020	0.024	0.022	0.024
20	0.020	0.020	0.000	0.000	0.000	0.000	0.020
21	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22	0.000	0.000	0.000	0.028	0.032	0.022	0.032
23	0.020	0.020	0.020	0.024	0.028	0.026	0.028
24	0.026	0.024	0.000	0.024	0.050	0.032	0.050
25	0.030	0.000	0.000	0.042	0.030	0.022	0.042
26	0.020	0.020	0.020	0.024	0.040	0.022	0.040
27	0.020	0.020	0.000	0.000	0.000	0.000	0.020
28	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29	0.000	0.000	0.000	0.022	0.046	0.022	0.046
30	0.020	0.021	0.020	0.020	0.024	0.022	0.024
31	0.020	0.000	0.000	0.020	0.026	0.022	0.026

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: Mickael Dimmick SIGNATURE:  DATE: 4/1/11 PHONE #: ( 503 ) 738-5112 <span style="float: right;">422982</span>	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

21-Mar

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv: 0.5		
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.86	148	127.28	9.9	7.50	42	Yes	2000
2	1.08	148	159.84	10.1	7.80	28	Yes	2000
3	1.08	148	159.84	10.1	7.50	23	Yes	2000
4	1.06	148	156.88	10.1	7.80	28	Yes	2000
5	1.04	148	153.92	10.1	7.50	23	Yes	2000
6	0.00	0	0.00	0.0	0.00	0	Yes	0
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.92	148	136.16	10.1	7.30	22	Yes	2000
9	1.08	148	159.84	10.0	7.60	28	Yes	2000
10	1.08	148	159.84	10.1	7.50	23	Yes	2000
11	1.08	148	159.84	10.1	7.50	23	Yes	2000
12	1.06	148	156.88	10.1	7.40	22	Yes	2000
13	0.00	0	0.00	0.0	0.00	0	Yes	0
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.93	148	137.64	10.1	7.50	22	Yes	2000
16	1.12	148	165.76	9.8	7.70	52	Yes	2000
17	1.08	148	159.84	10.2	7.60	22	Yes	2000
18	1.12	148	165.76	10.2	7.80	23	Yes	2000
19	1.09	148	161.32	10.2	7.70	22	Yes	2000
20	0.00	0	0.00	0.0	0.00	0	Yes	0
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.91	148	134.68	10.1	7.50	22	Yes	2000
23	1.10	148	162.80	10.3	7.80	28	Yes	2000
24	1.08	148	159.84	10.5	7.50	23	Yes	2000
25	1.04	148	153.92	10.6	7.50	23	Yes	200
26	1.11	148	164.28	10.7	7.50	23	Yes	2000
27	0.00	0	0.00	0.0	0.00	0	Yes	0
28	0.00	0	0.00	0.0	0.00	0	Yes	0
29	0.97	148	143.56	10.8	7.50	22	Yes	2000
30	1.15	132	151.80	10.8	7.60	28	Yes	2200
31	1.08	132	142.56	10.7	7.50	23	Yes	2200

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012