

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

21-Apr


System Name: SEASIDE ID#: 4100799 WTP - : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.022	0.022	0.000	0.000	0.026	0.024	0.026
2	0.022	0.022	0.038	0.024	0.027	0.024	0.038
3	0.022	0.000	0.000	0.000	0.000	0.000	0.022
4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.000	0.022	0.030	0.024	0.030
6	0.023	0.022	0.022	0.000	0.000	0.028	0.028
7	0.026	0.000	0.000	0.036	0.030	0.026	0.036
8	0.024	0.024	0.033	0.026	0.048	0.028	0.048
9	0.026	0.025	0.024	0.036	0.049	0.044	0.049
10	0.036	0.042	0.034	0.000	0.000	0.000	0.042
11	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12	0.000	0.000	0.000	0.036	0.046	0.044	0.046
13	0.056	0.035	0.000	0.028	0.028	0.030	0.056
14	0.028	0.026	0.000	0.039	0.040	0.042	0.042
15	0.040	0.046	0.042	0.034	0.045	0.041	0.046
16	0.034	0.040	0.028	0.046	0.038	0.032	0.046
17	0.032	0.032	0.000	0.000	0.000	0.000	0.032
18	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19	0.000	0.000	0.000	0.030	0.038	0.034	0.038
20	0.032	0.032	0.046	0.032	0.050	0.037	0.050
21	0.034	0.034	0.000	0.040	0.046	0.038	0.046
22	0.038	0.034	0.000	0.058	0.044	0.032	0.058
23	0.030	0.032	0.028	0.036	0.040	0.034	0.040
24	0.032	0.032	0.032	0.000	0.000	0.000	0.032
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26	0.000	0.000	0.000	0.038	0.042	0.036	0.042
27	0.034	0.034	0.000	0.034	0.042	0.036	0.042
28	0.034	0.000	0.000	0.034	0.044	0.034	0.044
29	0.036	0.034	0.000	0.032	0.036	0.034	0.036
30	0.034	0.000	0.000	0.032	0.030	0.028	0.034
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: Mike Dimmick

SIGNATURE: 

PHONE #: (503) 738-5112

DATE: 5/3/21

CERT #: 412282

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

21-Apr

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.07	132	141.24	11.1	7.70	28	Yes	2200
2	1.10	132	145.20	11.2	7.40	28	Yes	2200
3	0.00	0	0.00	0.0	0.00	0	Yes	0
4	0.00	0	0.00	0.0	0.00	0	Yes	0
5	0.93	148	137.64	11.6	7.50	22	Yes	2000
6	1.01	132	133.32	12.1	7.40	23	Yes	2200
7	1.00	132	132.00	12.1	7.50	22	Yes	2200
8	1.07	132	141.24	12.3	7.50	23	Yes	2200
9	1.04	132	137.28	12.2	7.50	23	Yes	2200
10	0.00	0	0.00	0.0	0.00	0	Yes	0
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	1.01	132	133.32	12.3	7.40	23	Yes	2200
13	1.05	132	138.60	12.6	7.40	23	Yes	2200
14	1.02	132	134.64	12.9	7.60	28	Yes	2200
15	1.02	132	134.64	12.8	7.50	23	Yes	2200
16	1.08	132	142.56	13.2	7.50	23	Yes	2200
17	0.00	0	0.00	0.0	0.00	0	Yes	0
18	0.00	0	0.00	0.0	0.00	0	Yes	0
19	0.95	115	109.25	13.8	7.50	23	Yes	2400
20	1.16	115	133.40	14.0	7.50	23	Yes	2400
21	1.15	123	141.45	14.2	7.50	23	Yes	2300
22	0.97	115	111.55	14.4	7.50	22	Yes	2400
23	1.04	123	127.92	14.5	7.40	23	Yes	2300
24	0.00	0	0.00	0.0	0.00	0	Yes	0
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.84	123	103.32	14.8	7.50	22	Yes	2300
27	1.07	148	158.36	15.0	7.40	15	Yes	2000
28	1.05	148	155.40	15.1	7.60	19	Yes	2000
29	1.03	148	152.44	15.3	7.50	15	Yes	2000
30	1.01	148	149.48	15.5	7.60	19	Yes	2000
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.