


OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

21-May

System Name: SEASIDE ID#: 4100799 WTP - : A							
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3	0.000	0.000	0.000	0.040	0.028	0.026	0.040
4	0.026	0.026	0.000	0.032	0.036	0.037	0.037
5	0.032	0.000	0.000	0.033	0.036	0.032	0.036
6	0.034	0.034	0.000	0.042	0.048	0.036	0.048
7	0.048	0.030	0.000	0.032	0.047	0.036	0.048
8	0.038	0.034	0.000	0.000	0.000	0.000	0.038
9	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.046	0.042	0.042	0.046
11	0.048	0.046	0.048	0.042	0.041	0.039	0.048
12	0.040	0.050	0.000	0.058	0.046	0.048	0.058
13	0.046	0.046	0.000	0.046	0.060	0.050	0.060
14	0.059	0.044	0.044	0.053	0.056	0.038	0.059
15	0.038	0.042	0.040	0.000	0.000	0.000	0.042
16	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17	0.000	0.000	0.000	0.036	0.048	0.043	0.048
18	0.058	0.038	0.042	0.042	0.065	0.051	0.065
19	0.058	0.058	0.000	0.026	0.028	0.026	0.058
20	0.032	0.000	0.000	0.030	0.034	0.028	0.034
21	0.028	0.028	0.000	0.028	0.036	0.030	0.036
22	0.030	0.030	0.000	0.000	0.000	0.000	0.030
23	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24	0.000	0.000	0.000	0.038	0.042	0.032	0.042
25	0.029	0.030	0.030	0.030	0.030	0.030	0.030
26	0.035	0.028	0.028	0.030	0.036	0.034	0.036
27	0.034	0.034	0.000	0.031	0.034	0.036	0.036
28	0.038	0.000	0.000	0.034	0.044	0.034	0.044
29	0.032	0.034	0.033	0.000	0.000	0.000	0.034
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.036	0.044	0.034	0.044

Conventional or Direct Filtration 95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes:		PRINTED NAME: Michael Dimmick SIGNATURE:  PHONE #: (503) 738-5112 DATE: 6/1/2021 422982	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

21-May

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	0.73	148	108.04	15.7	7.60	18	Yes	2000
4	0.98	148	145.04	15.8	7.60	18	Yes	2000
5	0.94	148	139.12	15.8	7.40	15	Yes	2000
6	1.04	148	153.92	15.9	7.50	15	Yes	2000
7	0.94	148	139.12	15.8	7.50	15	Yes	2000
8	0.00	0	0.00	0.0	0.00	0	Yes	0
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	0.79	148	116.92	15.6	7.70	15	Yes	2000
11	1.14	148	168.72	15.7	7.50	15	Yes	2000
12	1.10	148	162.80	15.9	7.50	15	Yes	2000
13	1.08	148	159.84	16.0	7.50	15	Yes	2000
14	1.10	148	162.80	16.2	7.60	15	Yes	2000
15	0.00	0	0.00	0.0	0.00	0	Yes	0
16	0.00	0	0.00	0.0	0.00	0	Yes	0
17	0.82	148	121.36	16.1	7.50	15	Yes	2000
18	1.07	148	158.36	15.8	7.50	15	Yes	2000
19	1.03	115	118.45	16.0	7.50	15	Yes	2400
20	1.12	115	128.80	16.1	7.50	15	Yes	2400
21	1.10	148	162.80	16.2	7.60	19	Yes	2000
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.84	123	103.32	16.3	7.50	15	Yes	2300
25	1.13	148	167.24	16.5	7.50	15	Yes	2000
26	1.09	148	161.32	16.6	7.50	15	Yes	2000
27	1.10	148	162.80	16.7	7.60	19	Yes	2000
28	0.95	148	140.60	16.7	7.50	15	Yes	2000
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.73	148	108.04	17.2	7.60	18	Yes	2000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012