


OHA - Drinking Water Program -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: CLATSOP

21-Jun

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.032	0.033	0.034	0.034	0.043	0.034	0.043
2	0.034	0.034	0.034	0.036	0.040	0.034	0.040
3	0.032	0.032	0.000	0.030	0.030	0.026	0.032
4	0.024	0.000	0.000	0.026	0.032	0.028	0.032
5	0.026	0.025	0.028	0.000	0.000	0.000	0.028
6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7	0.000	0.000	0.000	0.028	0.042	0.026	0.042
8	0.026	0.036	0.000	0.024	0.041	0.030	0.041
9	0.030	0.000	0.000	0.032	0.036	0.030	0.036
10	0.026	0.000	0.000	0.026	0.038	0.032	0.038
11	0.030	0.000	0.000	0.030	0.042	0.038	0.042
12	0.034	0.034	0.000	0.000	0.000	0.000	0.034
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.034	0.042	0.034	0.042
15	0.032	0.034	0.000	0.034	0.047	0.034	0.047
16	0.034	0.000	0.000	0.036	0.050	0.038	0.050
17	0.034	0.000	0.000	0.036	0.042	0.038	0.042
18	0.034	0.036	0.000	0.038	0.044	0.036	0.044
19	0.038	0.036	0.000	0.000	0.000	0.000	0.038
20	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21	0.000	0.000	0.000	0.042	0.034	0.034	0.042
22	0.033	0.034	0.034	0.046	0.036	0.035	0.046
23	0.034	0.033	0.040	0.038	0.044	0.036	0.044
24	0.034	0.034	0.000	0.034	0.040	0.038	0.040
25	0.036	0.000	0.000	0.036	0.036	0.038	0.038
26	0.036	0.034	0.000	0.000	0.000	0.000	0.036
27	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28	0.000	0.000	0.000	0.036	0.038	0.034	0.038
29	0.034	0.032	0.034	0.040	0.044	0.039	0.044
30	0.041	0.034	0.000	0.034	0.040	0.036	0.041
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

<b>Conventional or Direct Filtration</b> 95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		<b>Monthly Summary (Answer Yes or No)</b> CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes:		PRINTED NAME: Michael Dimmick SIGNATURE:  PHONE #: ( 503 ) 738-5112 DATE: 7/1/21 422982	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

21-Jun

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv:		0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.11	123	136.53	17.5	7.60	19	Yes	2300
2	1.06	132	139.92	17.8	7.60	19	Yes	2200
3	0.91	132	120.12	18.1	7.50	15	Yes	2200
4	0.89	132	117.48	18.1	7.60	18	Yes	2200
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	0.00	0	0.00	0.0	0.00	0	Yes	0
7	0.46	115	52.90	18.2	7.30	14	Yes	2400
8	0.95	123	116.85	18.0	7.50	15	Yes	2300
9	0.87	123	107.01	18.0	7.50	15	Yes	2300
10	0.90	123	110.70	18.1	7.60	18	Yes	2300
11	1.04	132	137.28	18.1	7.50	15	Yes	2200
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	0.00	0	0.00	0.0	0.00	0	Yes	0
14	0.41	115	47.15	17.7	7.50	15	Yes	2400
15	0.92	123	113.16	17.6	7.50	15	Yes	2300
16	0.94	123	115.62	18.0	7.50	15	Yes	2300
17	0.83	123	102.09	18.1	7.60	18	Yes	2300
18	0.88	123	108.24	18.2	7.60	18	Yes	2300
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	0.00	0	0.00	0.0	0.00	0	Yes	0
21	0.80	115	92.00	19.2	7.60	18	Yes	2400
22	1.13	115	129.95	19.3	7.50	15	Yes	2400
23	0.97	105	101.85	19.6	7.60	18	Yes	2600
24	1.09	115	125.35	20.0	7.50	15	Yes	2400
25	0.88	115	101.20	20.1	7.50	11	Yes	2400
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.00	0	0.00	0.0	0.00	0	Yes	0
28	0.70	115	80.50	21.1	7.60	13	Yes	2400
29	1.07	110	117.70	21.3	7.60	14	Yes	2500
30	0.96	110	105.60	21.2	7.50	11	Yes	2500
31	0.00	0	0.00	0.0	0.00	0	Yes	0

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012