


OHA - Drinking Water Program -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: CLATSOP

21-Jul

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.034	0.032	0.000	0.044	0.044	0.036	0.044
2	0.040	0.034	0.000	0.032	0.040	0.050	0.050
3	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.000	0.046	0.062	0.050	0.062
6	0.063	0.052	0.048	0.048	0.054	0.056	0.063
7	0.054	0.050	0.000	0.044	0.040	0.036	0.054
8	0.038	0.000	0.000	0.039	0.046	0.038	0.046
9	0.038	0.036	0.038	0.036	0.045	0.036	0.045
10	0.036	0.034	0.000	0.000	0.000	0.000	0.036
11	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12	0.000	0.000	0.000	0.056	0.042	0.040	0.056
13	0.038	0.038	0.040	0.054	0.038	0.036	0.054
14	0.038	0.034	0.000	0.034	0.044	0.036	0.044
15	0.036	0.000	0.000	0.036	0.042	0.040	0.042
16	0.038	0.000	0.000	0.034	0.044	0.036	0.044
17	0.034	0.034	0.036	0.000	0.000	0.000	0.036
18	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19	0.000	0.000	0.000	0.038	0.042	0.040	0.042
20	0.038	0.038	0.040	0.038	0.046	0.032	0.046
21	0.032	0.034	0.032	0.038	0.042	0.042	0.042
22	0.040	0.000	0.000	0.040	0.044	0.042	0.044
23	0.038	0.000	0.000	0.040	0.046	0.042	0.046
24	0.040	0.038	0.038	0.000	0.000	0.000	0.040
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26	0.000	0.000	0.000	0.038	0.044	0.036	0.044
27	0.034	0.034	0.036	0.034	0.043	0.036	0.043
28	0.034	0.034	0.000	0.034	0.040	0.038	0.040
29	0.034	0.000	0.000	0.036	0.044	0.040	0.044
30	0.036	0.036	0.000	0.036	0.046	0.038	0.046
31	0.038	0.038	0.042	0.000	0.000	0.000	0.042

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
<b>Notes:</b>		<b>PRINTED NAME: Michael Dimmick</b>	
		<b>SIGNATURE:</b> 	<b>DATE:</b> 8/2/21
		<b>PHONE #:</b> ( 503 ) 738-5112	<b>422982</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

21-Jul

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.91	115	104.65	21.2	7.50	11	Yes	2400
2	0.94	132	124.08	21.7	7.50	11	Yes	2200
3	0.00	0	0.00	0.0	0.00	0	Yes	0
4	0.00	0	0.00	0.0	0.00	0	Yes	0
5	0.53	110	58.30	21.2	7.50	11	Yes	2500
6	1.15	115	132.25	21.0	7.60	14	Yes	2400
7	1.03	115	118.45	20.8	7.60	14	Yes	2400
8	0.87	123	107.01	20.8	7.50	11	Yes	2300
9	0.99	132	130.68	20.9	7.60	14	Yes	2200
10	0.00	0	0.00	0.0	0.00	0	Yes	0
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	0.99	115	113.85	20.6	7.50	11	Yes	2400
13	1.06	115	121.90	20.3	7.50	12	Yes	2400
14	0.91	115	104.65	20.0	7.50	11	Yes	2400
15	0.85	115	97.75	19.8	7.50	15	Yes	2400
16	0.81	132	106.92	20.0	7.60	14	Yes	2200
17	0.00	0	0.00	0.0	0.00	0	Yes	0
18	0.00	0	0.00	0.0	0.00	0	Yes	0
19	0.27	115	31.05	20.2	7.60	13	Yes	2400
20	1.10	115	126.50	20.5	7.50	12	Yes	2400
21	1.11	115	127.65	20.7	7.60	14	Yes	2400
22	0.89	115	102.35	20.8	7.60	14	Yes	2400
23	0.91	132	120.12	21.0	7.50	11	Yes	2200
24	0.00	0	0.00	0.0	0.00	0	Yes	0
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.28	115	32.20	21.1	7.70	12	Yes	2400
27	1.16	115	133.40	21.4	7.50	12	Yes	2400
28	1.20	115	138.00	21.5	7.50	12	Yes	2400
29	0.99	115	113.85	21.5	7.50	11	Yes	2400
30	1.03	132	135.96	21.6	7.50	12	Yes	2200
31	0.00	0	0.00	0.0	0.00	0	Yes	0

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012