


OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

21-Aug

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.036	0.040	0.038	0.040
3	0.038	0.036	0.036	0.034	0.038	0.038	0.038
4	0.038	0.036	0.038	0.034	0.040	0.040	0.040
5	0.036	0.036	0.038	0.040	0.036	0.038	0.040
6	0.036	0.000	0.000	0.036	0.042	0.036	0.042
7	0.036	0.000	0.000	0.000	0.000	0.000	0.036
8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9	0.000	0.000	0.000	0.038	0.042	0.040	0.042
10	0.040	0.040	0.040	0.044	0.042	0.040	0.044
11	0.040	0.038	0.038	0.042	0.044	0.044	0.044
12	0.044	0.042	0.000	0.044	0.040	0.042	0.044
13	0.042	0.000	0.000	0.036	0.036	0.040	0.042
14	0.040	0.038	0.038	0.000	0.000	0.000	0.040
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16	0.000	0.000	0.000	0.038	0.044	0.038	0.044
17	0.036	0.037	0.040	0.034	0.052	0.036	0.052
18	0.034	0.034	0.036	0.032	0.038	0.034	0.038
19	0.033	0.032	0.000	0.032	0.036	0.034	0.036
20	0.000	0.000	0.000	0.034	0.046	0.034	0.046
21	0.032	0.000	0.000	0.000	0.000	0.000	0.032
22	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23	0.000	0.000	0.000	0.032	0.038	0.034	0.038
24	0.034	0.034	0.000	0.034	0.036	0.032	0.036
25	0.032	0.032	0.034	0.030	0.034	0.032	0.034
26	0.032	0.030	0.000	0.032	0.041	0.032	0.041
27	0.030	0.000	0.000	0.032	0.034	0.030	0.034
28	0.030	0.000	0.000	0.000	0.000	0.000	0.030
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.040	0.058	0.038	0.058
31	0.038	0.038	0.038	0.040	0.042	0.038	0.042

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:		PRINTED NAME: Michael Dimmick	
		SIGNATURE: 	DATE: 9/11/2021
		PHONE #: (503) 738-5112	422982

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

21-Aug

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.58	115	66.70	21.0	7.50	11	Yes	2400
3	1.16	115	133.40	20.9	7.50	12	Yes	2400
4	1.02	115	117.30	21.2	7.60	14	Yes	2400
5	0.93	115	106.95	21.2	7.30	11	Yes	2400
6	0.91	132	120.12	21.2	7.50	11	Yes	2200
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.00	0	0.00	0.0	0.00	0	Yes	0
9	0.47	115	54.05	21.1	7.60	12	Yes	2400
10	1.00	115	115.00	21.3	7.50	11	Yes	2400
11	1.09	115	125.35	21.6	7.60	14	Yes	2400
12	0.94	115	108.10	21.7	7.50	11	Yes	2400
13	0.95	132	125.40	21.9	7.50	11	Yes	2200
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.00	0	0.00	0.0	0.00	0	Yes	0
16	0.50	115	57.50	21.9	7.60	13	Yes	2400
17	1.14	115	131.10	22.3	7.60	14	Yes	2400
18	1.13	115	129.95	21.9	7.50	12	Yes	2400
19	1.05	115	120.75	21.7	7.50	12	Yes	2400
20	0.97	115	111.55	21.4	7.50	11	Yes	2400
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	0.67	115	77.05	20.8	7.60	11	Yes	2400
24	1.00	115	115.00	20.9	7.60	11	Yes	2400
25	1.00	123	123.00	21.0	7.50	11	Yes	2300
26	0.94	123	115.62	21.1	7.60	13	Yes	2300
27	0.94	123	115.62	21.0	7.50	11	Yes	2300
28	0.00	0	0.00	0.0	0.00	0	Yes	0
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.69	115	79.35	20.5	7.50	11	Yes	2400
31	1.16	115	133.40	20.6	7.60	14	Yes	2400

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.