

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration


County: CLATSOP

21-Sep

System Name: SEASIDE ID#: 4100799 WTP - : A							
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.036	0.038	0.000	0.036	0.040	0.038	0.040
2	0.036	0.000	0.000	0.036	0.038	0.036	0.038
3	0.035	0.000	0.000	0.034	0.042	0.034	0.042
4	0.034	0.000	0.000	0.000	0.000	0.000	0.034
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6	0.000	0.000	0.000	0.034	0.034	0.032	0.034
7	0.032	0.033	0.032	0.032	0.036	0.034	0.036
8	0.034	0.032	0.034	0.034	0.038	0.034	0.038
9	0.032	0.000	0.000	0.034	0.032	0.034	0.034
10	0.032	0.000	0.000	0.034	0.032	0.034	0.034
11	0.030	0.032	0.000	0.000	0.000	0.000	0.032
12	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13	0.000	0.000	0.000	0.000	0.036	0.034	0.036
14	0.034	0.038	0.038	0.038	0.038	0.038	0.038
15	0.036	0.000	0.000	0.040	0.042	0.038	0.042
16	0.038	0.000	0.000	0.038	0.044	0.040	0.044
17	0.039	0.040	0.000	0.040	0.042	0.042	0.042
18	0.040	0.000	0.000	0.000	0.000	0.000	0.040
19	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.046	0.048	0.044	0.048
21	0.044	0.046	0.047	0.040	0.038	0.036	0.047
22	0.000	0.000	0.000	0.036	0.050	0.042	0.050
23	0.044	0.000	0.000	0.036	0.040	0.036	0.044
24	0.038	0.000	0.000	0.040	0.042	0.038	0.042
25	0.036	0.036	0.000	0.000	0.000	0.000	0.036
26	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27	0.000	0.000	0.000	0.034	0.037	0.035	0.037
28	0.036	0.036	0.036	0.036	0.038	0.036	0.038
29	0.037	0.036	0.040	0.036	0.038	0.036	0.040
30	0.038	0.000	0.000	0.036	0.038	0.036	0.038
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		

Notes:

PRINTED NAME: Michael Dimmick
SIGNATURE: 
PHONE #: (503) 738-5112
DATE: 9/21/21
422982

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

21-Sep

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.05	132	138.60	20.1	7.60	14	Yes	2200
2	0.96	132	126.72	20.0	7.50	11	Yes	2200
3	0.97	132	128.04	19.9	7.60	18	Yes	2200
4	0.00	0	0.00	0.0	0.00	0	Yes	0
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	0.75	115	86.25	19.9	7.50	12	Yes	2400
7	1.11	115	127.65	20.1	7.50	12	Yes	2400
8	1.03	132	135.96	20.2	7.60	15	Yes	2200
9	0.92	132	121.44	20.3	7.70	15	Yes	2200
10	1.04	132	137.28	20.4	7.70	15	Yes	2200
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	0.83	115	95.45	20.4	7.60	15	Yes	2400
14	1.08	123	132.84	20.2	7.50	12	Yes	2300
15	1.09	123	134.07	20.0	7.50	12	Yes	2300
16	1.05	132	138.60	19.7	7.50	15	Yes	2200
17	1.05	132	138.60	19.3	7.50	15	Yes	2200
18	0.00	0	0.00	0.0	0.00	0	Yes	0
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	0.74	115	85.10	18.9	7.60	21	Yes	2400
21	1.12	115	128.80	18.7	7.50	15	Yes	2400
22	0.97	123	119.31	18.9	7.50	15	Yes	2300
23	0.97	132	128.04	18.7	7.60	18	Yes	2200
24	0.97	148	143.56	18.6	7.50	15	Yes	2000
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.69	115	79.35	18.2	7.50	15	Yes	2400
28	1.12	115	128.80	17.9	7.60	19	Yes	2400
29	1.03	132	135.96	17.6	7.50	15	Yes	2200
30	0.94	132	124.08	17.5	7.60	18	Yes	2200
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012