


OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: CLATSOP

21-Oct

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.036	0.000	0.000	0.036	0.042	0.036	0.042
2	0.034	0.000	0.000	0.000	0.000	0.000	0.034
3	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4	0.000	0.000	0.000	0.032	0.030	0.028	0.032
5	0.027	0.028	0.000	0.028	0.031	0.030	0.031
6	0.030	0.026	0.000	0.028	0.032	0.029	0.032
7	0.000	0.000	0.000	0.030	0.034	0.026	0.034
8	0.026	0.000	0.000	0.026	0.030	0.027	0.030
9	0.027	0.000	0.000	0.000	0.000	0.000	0.027
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11	0.000	0.000	0.000	0.023	0.028	0.024	0.028
12	0.024	0.024	0.024	0.024	0.038	0.026	0.038
13	0.026	0.024	0.024	0.024	0.024	0.022	0.026
14	0.000	0.000	0.000	0.026	0.024	0.024	0.026
15	0.000	0.000	0.000	0.023	0.026	0.024	0.026
16	0.022	0.000	0.000	0.000	0.000	0.000	0.022
17	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18	0.000	0.000	0.000	0.022	0.030	0.024	0.030
19	0.024	0.024	0.000	0.022	0.022	0.022	0.024
20	0.020	0.022	0.000	0.026	0.024	0.023	0.026
21	0.022	0.000	0.000	0.026	0.022	0.022	0.026
22	0.000	0.000	0.000	0.022	0.026	0.024	0.026
23	0.024	0.000	0.000	0.000	0.000	0.000	0.024
24	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.000	0.026	0.032	0.028	0.032
26	0.026	0.026	0.000	0.026	0.026	0.024	0.026
27	0.024	0.000	0.000	0.036	0.030	0.027	0.036
28	0.026	0.000	0.000	0.026	0.027	0.024	0.027
29	0.000	0.000	0.000	0.032	0.028	0.026	0.032
30	0.025	0.000	0.000	0.000	0.000	0.000	0.025
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings $\leq$ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings $<$ IFE <sup>2</sup> triggers	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
<b>Notes:</b>		<b>PRINTED NAME: Michael Dimmick</b>	
		<b>SIGNATURE:</b> 	<b>DATE:</b> 1 Nov 21
		<b>PHONE #: ( 503 ) 738-5112</b>	<b>422982</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

21-Oct

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv: 0.5		
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.90	148	133.20	17.2	7.60	18	Yes	2000
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	0.00	0	0.00	0.0	0.00	0	Yes	0
4	0.67	148	99.16	16.5	7.50	15	Yes	2000
5	1.05	148	155.40	16.3	7.50	15	Yes	2000
6	1.00	148	148.00	16.0	7.60	18	Yes	2000
7	1.02	148	150.96	15.5	7.60	19	Yes	2000
8	1.00	148	148.00	15.2	7.60	18	Yes	2000
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	0.00	0	0.00	0.0	0.00	0	Yes	0
11	0.77	148	113.96	14.8	7.50	22	Yes	2000
12	0.99	148	146.52	14.2	7.60	27	Yes	2000
13	1.07	148	158.36	13.8	7.50	23	Yes	2000
14	0.62	148	91.76	13.9	7.60	26	Yes	2000
15	0.96	148	142.08	14.0	7.50	22	Yes	2000
16	0.00	0	0.00	0.0	0.00	0	Yes	0
17	0.00	0	0.00	0.0	0.00	0	Yes	0
18	0.82	148	121.36	14.2	7.60	27	Yes	2000
19	1.25	148	185.00	13.8	7.50	23	Yes	2000
20	1.14	148	168.72	13.7	7.50	23	Yes	2000
21	1.11	148	164.28	13.8	7.50	23	Yes	2000
22	1.14	148	168.72	13.7	7.60	26	Yes	2000
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.00	0	0.00	0.0	0.00	0	Yes	0
25	0.90	148	133.20	13.6	7.50	22	Yes	2000
26	1.17	148	173.16	13.6	7.60	28	Yes	2000
27	1.05	148	155.40	13.5	7.50	23	Yes	2000
28	1.06	148	156.88	13.6	7.50	23	Yes	2000
29	1.04	148	153.92	13.7	7.50	23	Yes	2000
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.00	0	0.00	0.0	0.00	0	Yes	0

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012