


OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: CLATSOP

21-Nov

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.022	0.032	0.026	0.032
2	0.026	0.000	0.000	0.000	0.022	0.022	0.026
3	0.023	0.000	0.000	0.024	0.025	0.023	0.025
4	0.024	0.000	0.000	0.022	0.022	0.021	0.024
5	0.000	0.000	0.000	0.022	0.026	0.024	0.026
6	0.023	0.000	0.000	0.000	0.000	0.000	0.023
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.022	0.022	0.022	0.022
9	0.022	0.000	0.000	0.024	0.030	0.026	0.030
10	0.024	0.000	0.000	0.025	0.022	0.022	0.025
11	0.025	0.000	0.000	0.022	0.030	0.024	0.030
12	0.022	0.000	0.000	0.022	0.028	0.024	0.028
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.022	0.030	0.026	0.030
16	0.024	0.024	0.000	0.026	0.032	0.067	0.067
17	0.064	0.000	0.000	0.064	0.026	0.024	0.064
18	0.022	0.000	0.000	0.024	0.035	0.037	0.037
19	0.045	0.000	0.000	0.059	0.024	0.022	0.059
20	0.022	0.000	0.000	0.000	0.000	0.000	0.022
21	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22	0.000	0.000	0.000	0.022	0.031	0.024	0.031
23	0.022	0.000	0.000	0.022	0.022	0.022	0.022
24	0.024	0.000	0.000	0.040	0.028	0.024	0.040
25	0.022	0.000	0.000	0.020	0.022	0.024	0.024
26	0.023	0.026	0.000	0.027	0.022	0.022	0.027
27	0.020	0.000	0.000	0.000	0.000	0.000	0.020
28	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29	0.000	0.000	0.000	0.020	0.026	0.022	0.026
30	0.020	0.000	0.000	0.020	0.020	0.022	0.022
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:		PRINTED NAME: Michael Dimmick	
		SIGNATURE: 	DATE: 12/1/22
		PHONE #: ( 503 ) 738-5112	422982

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

## OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

21-Nov

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv:		0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.86	148	127.28	12.7	7.50	22	Yes	2000
2	1.02	132	134.64	12.4	7.50	23	Yes	2200
3	1.06	148	156.88	12.4	7.60	23	Yes	2000
4	1.04	148	153.92	12.7	7.60	22	Yes	2000
5	1.04	148	153.92	12.6	7.60	22	Yes	2000
6	0.00	0	0.00	0.0	0.00	0	Yes	0
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.78	148	115.44	11.9	7.60	22	Yes	2000
9	0.97	148	143.56	12.0	7.50	22	Yes	2000
10	1.00	148	148.00	11.8	7.60	27	Yes	2000
11	1.00	148	148.00	12.0	7.60	27	Yes	2000
12	1.02	148	150.96	12.4	7.50	23	Yes	2000
13	0.00	0	0.00	0.0	0.00	0	Yes	0
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.77	148	113.96	12.8	7.60	26	Yes	2000
16	0.97	148	143.56	12.8	7.50	22	Yes	2000
17	0.94	148	139.12	12.3	7.50	22	Yes	2000
18	1.00	148	148.00	11.9	7.50	22	Yes	2000
19	1.00	148	148.00	11.8	7.50	22	Yes	2000
20	0.00	0	0.00	0.0	0.00	0	Yes	0
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.82	148	121.36	11.0	7.50	22	Yes	2000
23	0.95	148	140.60	11.1	7.50	22	Yes	2000
24	0.97	148	143.56	10.7	7.60	22	Yes	2000
25	0.96	148	142.08	10.8	7.60	27	Yes	2000
26	1.05	148	155.40	11.0	7.50	23	Yes	2000
27	0.00	0	0.00	0.0	0.00	0	Yes	0
28	0.00	0	0.00	0.0	0.00	0	Yes	0
29	0.84	148	124.32	11.8	7.60	22	Yes	2000
30	1.03	148	152.44	11.9	7.60	28	Yes	2000
31	0.00	0	0.00	0.0	0.00	0	Yes	0

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012