


OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: CLATSOP

21-Dec

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.022	0.000	0.000	0.026	0.028	0.022	0.028
2	0.020	0.000	0.000	0.020	0.020	0.020	0.020
3	0.020	0.000	0.000	0.024	0.036	0.023	0.036
4	0.022	0.000	0.000	0.000	0.000	0.000	0.022
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6	0.000	0.000	0.000	0.020	0.030	0.024	0.030
7	0.022	0.000	0.000	0.022	0.020	0.022	0.022
8	0.022	0.023	0.000	0.026	0.028	0.022	0.028
9	0.000	0.000	0.000	0.022	0.022	0.022	0.022
10	0.022	0.000	0.000	0.026	0.026	0.024	0.026
11	0.022	0.000	0.000	0.000	0.000	0.000	0.022
12	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13	0.000	0.000	0.000	0.030	0.026	0.024	0.030
14	0.024	0.000	0.000	0.027	0.030	0.040	0.040
15	0.072	0.088	0.000	0.030	0.026	0.032	0.088
16	0.026	0.000	0.000	0.026	0.040	0.051	0.051
17	0.087	0.000	0.000	0.042	0.028	0.029	0.087
18	0.028	0.030	0.000	0.000	0.000	0.000	0.030
19	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.028	0.038	0.024	0.038
21	0.022	0.000	0.000	0.026	0.032	0.039	0.039
22	0.000	0.000	0.000	0.030	0.024	0.022	0.030
23	0.022	0.024	0.000	0.027	0.052	0.081	0.081
24	0.088	0.000	0.000	0.030	0.023	0.024	0.088
25	0.030	0.000	0.000	0.000	0.000	0.000	0.030
26	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27	0.000	0.000	0.000	0.042	0.032	0.023	0.042
28	0.000	0.000	0.000	0.024	0.030	0.045	0.045
29	0.052	0.000	0.000	0.031	0.026	0.024	0.052
30	0.026	0.000	0.000	0.030	0.035	0.042	0.042
31	0.057	0.000	0.000	0.032	0.026	0.026	0.057

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
<b>Notes:</b>		<b>PRINTED NAME: Michael Dimmick</b>	
		<b>SIGNATURE:</b> 	<b>DATE:</b> 1/31/2008
		<b>PHONE #:</b> ( 503 ) 738-5112	<b>422982</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

21-Dec

System Name:		Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv:	
								0.5	
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	1.17	148	173.16	12.0	7.50	23	Yes	2000	
2	1.17	148	173.16	12.0	7.40	23	Yes	2000	
3	1.16	148	171.68	11.6	7.50	23	Yes	2000	
4	0.00	0	0.00	0.0	0.00	0	Yes	0	
5	0.00	0	0.00	0.0	0.00	0	Yes	0	
6	0.93	148	137.64	10.6	7.50	22	Yes	2000	
7	1.13	148	167.24	10.7	7.60	28	Yes	2000	
8	1.17	148	173.16	10.9	7.50	23	Yes	2000	
9	1.14	148	168.72	10.7	7.50	23	Yes	2000	
10	1.16	148	171.68	10.6	7.60	28	Yes	2000	
11	0.00	0	0.00	0.0	0.00	0	Yes	0	
12	0.00	0	0.00	0.0	0.00	0	Yes	0	
13	0.90	148	133.20	10.1	7.50	22	Yes	2000	
14	1.17	148	173.16	9.5	7.50	43	Yes	2000	
15	1.10	148	162.80	9.3	7.50	43	Yes	2000	
16	1.13	148	167.24	9.0	7.60	52	Yes	2000	
17	1.11	148	164.28	8.9	7.50	43	Yes	2000	
18	0.00	0	0.00	0.0	0.00	0	Yes	0	
19	0.00	0	0.00	0.0	0.00	0	Yes	0	
20	0.92	148	136.16	9.2	7.50	42	Yes	2000	
21	1.11	148	164.28	9.2	7.50	43	Yes	2000	
22	1.00	148	148.00	9.5	7.40	42	Yes	2000	
23	1.13	148	167.24	9.5	7.60	52	Yes	2000	
24	1.04	148	153.92	9.3	7.40	43	Yes	2000	
25	0.00	0	0.00	0.0	0.00	0	Yes	0	
26	0.00	0	0.00	0.0	0.00	0	Yes	0	
27	0.92	148	136.16	7.8	7.60	51	Yes	2000	
28	1.09	148	161.32	7.4	7.50	43	Yes	2000	
29	1.10	148	162.80	7.3	7.50	43	Yes	2000	
30	1.23	148	182.04	7.2	7.50	44	Yes	2000	
31	1.13	148	167.24	7.3	7.50	43	Yes	2000	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012