


OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP 2022/1

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.024	0.026	0.000	0.000	0.000	0.000	0.026
2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3	0.000	0.000	0.000	0.028	0.050	0.028	0.050
4	0.026	0.000	0.000	0.026	0.028	0.030	0.030
5	0.040	0.000	0.000	0.066	0.059	0.026	0.066
6	0.022	0.000	0.000	0.022	0.028	0.056	0.056
7	0.000	0.000	0.000	0.038	0.027	0.032	0.038
8	0.071	0.000	0.000	0.000	0.000	0.000	0.071
9	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.060	0.028	0.033	0.060
11	0.069	0.000	0.000	0.044	0.034	0.038	0.069
12	0.057	0.000	0.000	0.040	0.034	0.038	0.057
13	0.066	0.000	0.000	0.086	0.034	0.029	0.086
14	0.030	0.045	0.000	0.076	0.030	0.026	0.076
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17	0.000	0.000	0.000	0.036	0.026	0.026	0.036
18	0.026	0.000	0.000	0.026	0.028	0.032	0.032
19	0.038	0.000	0.000	0.038	0.028	0.026	0.038
20	0.026	0.000	0.000	0.026	0.024	0.026	0.026
21	0.028	0.000	0.000	0.031	0.030	0.028	0.031
22	0.026	0.000	0.000	0.000	0.000	0.000	0.026
23	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24	0.000	0.000	0.000	0.026	0.040	0.028	0.040
25	0.026	0.000	0.000	0.026	0.026	0.026	0.026
26	0.026	0.000	0.000	0.026	0.034	0.028	0.034
27	0.028	0.000	0.000	0.027	0.028	0.026	0.028
28	0.026	0.000	0.000	0.027	0.044	0.030	0.044
29	0.028	0.000	0.000	0.000	0.000	0.000	0.028
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.028	0.036	0.030	0.036

Conventional or Direct Filtration 95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No			Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes:			PRINTED NAME: Michael Dimmick SIGNATURE:  PHONE #: (503) 738-5112 DATE: 1/18/22 TID 422982	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

2022/1

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	0.94	148	139.12	7.4	7.50	42	Yes	2000
4	1.15	148	170.20	7.3	7.50	43	Yes	2000
5	1.11	148	164.28	7.4	7.50	43	Yes	2000
6	1.14	148	168.72	7.9	7.60	52	Yes	2000
7	1.06	132	139.92	8.6	7.50	43	Yes	2200
8	0.00	0	0.00	0.0	0.00	0	Yes	0
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	0.88	148	130.24	8.6	7.50	42	Yes	2000
11	1.10	148	162.80	9.1	7.50	43	Yes	2000
12	1.06	148	156.88	9.7	7.40	43	Yes	2000
13	1.03	148	152.44	10.1	7.60	28	Yes	2000
14	1.08	148	159.84	10.2	7.50	23	Yes	2000
15	0.00	0	0.00	0.0	0.00	0	Yes	0
16	0.00	0	0.00	0.0	0.00	0	Yes	0
17	0.92	148	136.16	10.0	7.50	22	Yes	2000
18	1.13	148	167.24	10.1	7.60	28	Yes	2000
19	1.10	148	162.80	10.3	7.60	28	Yes	2000
20	1.08	148	159.84	10.5	7.60	28	Yes	2000
21	1.05	148	155.40	10.6	7.50	23	Yes	2000
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.84	148	124.32	10.0	7.40	22	Yes	2000
25	1.00	148	148.00	9.7	7.50	22	Yes	2000
26	1.04	148	153.92	9.5	7.50	23	Yes	2000
27	1.12	148	165.76	9.3	7.70	28	Yes	2000
28	1.13	148	167.24	9.2	7.50	43	Yes	2000
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	1.03	148	152.44	9.1	7.40	43	Yes	2000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012