

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration


County: CLATSOP

Feb-22

System Name: SEASIDE ID#: 4100799 WTP - : A							
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.030	0.028	0.030	0.030
2	0.030	0.000	0.000	0.030	0.034	0.032	0.034
3	0.030	0.000	0.000	0.031	0.030	0.030	0.031
4	0.000	0.000	0.000	0.030	0.034	0.032	0.034
5	0.032	0.000	0.000	0.000	0.000	0.000	0.032
6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7	0.000	0.000	0.000	0.030	0.038	0.032	0.038
8	0.032	0.000	0.000	0.031	0.032	0.032	0.032
9	0.030	0.000	0.000	0.032	0.040	0.034	0.040
10	0.032	0.000	0.000	0.032	0.032	0.030	0.032
11	0.032	0.000	0.000	0.032	0.035	0.032	0.035
12	0.032	0.000	0.000	0.000	0.000	0.000	0.032
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.032	0.030	0.022	0.032
15	0.022	0.000	0.000	0.022	0.022	0.020	0.022
16	0.021	0.000	0.000	0.020	0.024	0.023	0.024
17	0.024	0.000	0.000	0.022	0.020	0.022	0.024
18	0.021	0.000	0.000	0.021	0.028	0.022	0.028
19	0.022	0.000	0.000	0.000	0.000	0.000	0.022
20	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21	0.000	0.000	0.000	0.026	0.030	0.023	0.030
22	0.022	0.000	0.000	0.022	0.022	0.022	0.022
23	0.022	0.000	0.000	0.022	0.028	0.024	0.028
24	0.022	0.000	0.000	0.023	0.024	0.022	0.024
25	0.000	0.000	0.000	0.033	0.026	0.024	0.033
26	0.023	0.000	0.000	0.000	0.000	0.000	0.023
27	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28	0.000	0.000	0.000	0.022	0.028	0.024	0.028
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: Michael Dimmick	
SIGNATURE: 	DATE: 3/1/2022
PHONE #: (503) 738-5112	422982

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

Feb-22

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactive:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.13	148	167.24	8.9	7.50	43	Yes	2000
2	1.15	148	170.20	8.9	7.60	52	Yes	2000
3	1.12	148	165.76	9.0	7.60	52	Yes	2000
4	1.15	148	170.20	9.2	7.50	43	Yes	2000
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	0.00	0	0.00	0.0	0.00	0	Yes	0
7	0.93	148	137.64	9.4	7.30	42	Yes	2000
8	1.08	148	159.84	9.3	7.50	43	Yes	2000
9	1.08	148	159.84	9.5	7.50	43	Yes	2000
10	1.11	148	164.28	9.7	7.50	43	Yes	2000
11	1.09	148	161.32	9.6	7.50	43	Yes	2000
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	0.00	0	0.00	0.0	0.00	0	Yes	0
14	0.96	148	142.08	10.1	7.40	22	Yes	2000
15	1.09	148	161.32	10.0	7.50	23	Yes	2000
16	1.16	148	171.68	10.1	7.60	28	Yes	2000
17	1.08	148	159.84	10.1	7.50	23	Yes	2000
18	1.13	148	167.24	10.1	7.70	28	Yes	2000
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	0.00	0	0.00	0.0	0.00	0	Yes	0
21	0.94	148	139.12	10.1	7.80	27	Yes	2000
22	1.10	148	162.80	9.7	7.70	43	Yes	2000
23	1.07	148	158.36	9.0	7.50	43	Yes	2000
24	1.08	148	159.84	8.8	7.60	52	Yes	2000
25	1.03	148	152.44	8.4	7.50	43	Yes	2000
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.00	0	0.00	0.0	0.00	0	Yes	0
28	0.86	148	127.28	9.3	7.40	42	Yes	2000
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012