


OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: CLATSOP

22-Mar

System Name: SEASIDE ID#: 4100799 WTP - : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.024	0.000	0.000	0.022	0.022	0.022	0.024
2	0.022	0.000	0.000	0.034	0.024	0.024	0.034
3	0.024	0.000	0.000	0.022	0.021	0.020	0.024
4	0.020	0.000	0.000	0.026	0.022	0.022	0.026
5	0.020	0.000	0.000	0.000	0.000	0.000	0.020
6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7	0.000	0.000	0.000	0.020	0.028	0.022	0.028
8	0.022	0.000	0.000	0.020	0.020	0.020	0.022
9	0.020	0.000	0.000	0.061	0.024	0.022	0.061
10	0.020	0.000	0.000	0.020	0.020	0.020	0.020
11	0.020	0.000	0.000	0.036	0.024	0.022	0.036
12	0.022	0.000	0.000	0.000	0.000	0.000	0.022
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.028	0.024	0.022	0.028
15	0.022	0.000	0.000	0.038	0.024	0.022	0.038
16	0.022	0.000	0.000	0.024	0.036	0.028	0.036
17	0.000	0.000	0.000	0.024	0.024	0.024	0.024
18	0.000	0.000	0.000	0.024	0.026	0.024	0.026
19	0.022	0.000	0.000	0.000	0.000	0.000	0.022
20	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21	0.000	0.000	0.000	0.022	0.026	0.022	0.026
22	0.026	0.022	0.021	0.022	0.026	0.030	0.030
23	0.021	0.020	0.000	0.020	0.028	0.022	0.028
24	0.020	0.030	0.020	0.020	0.022	0.021	0.030
25	0.020	0.000	0.000	0.020	0.028	0.022	0.028
26	0.021	0.020	0.000	0.000	0.000	0.000	0.021
27	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28	0.000	0.000	0.000	0.020	0.026	0.024	0.026
29	0.022	0.000	0.000	0.020	0.024	0.022	0.024
30	0.022	0.022	0.000	0.020	0.028	0.024	0.028
31	0.022	0.000	0.000	0.027	0.024	0.024	0.027

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers	Yes / No		
Notes:		PRINTED NAME: Michael Dimmick	DATE: 4/1/22
		SIGNATURE: 	422982
		PHONE #: ( 503 ) 738-5112	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))  
PAGE 1 of 2

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

22-Mar

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv: 0.5		
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.05	148	155.40	9.8	7.60	52	Yes	2000
2	1.08	148	159.84	10.0	7.50	23	Yes	2000
3	1.05	148	155.40	10.0	7.60	28	Yes	2000
4	1.08	148	159.84	10.0	7.40	22	Yes	2000
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	0.00	0	0.00	0.0	0.00	0	Yes	0
7	0.86	148	127.28	10.7	7.40	22	Yes	2000
8	1.05	148	155.40	10.7	7.40	23	Yes	2000
9	1.08	148	159.84	10.5	7.50	23	Yes	2000
10	1.10	148	162.80	10.3	7.60	28	Yes	2000
11	1.12	148	165.76	10.3	7.50	23	Yes	2000
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	0.00	0	0.00	0.0	0.00	0	Yes	0
14	0.97	115	111.55	10.4	7.50	22	Yes	2400
15	0.75	148	111.00	10.5	7.60	26	Yes	2000
16	1.09	148	161.32	10.6	7.50	23	Yes	2000
17	1.11	148	164.28	10.8	7.50	23	Yes	2000
18	1.12	148	165.76	10.9	7.60	28	Yes	2000
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	0.00	0	0.00	0.0	0.00	0	Yes	0
21	0.87	148	128.76	11.0	7.50	22	Yes	2000
22	1.21	148	179.08	11.2	7.60	28	Yes	2000
23	1.20	148	177.60	11.4	7.60	28	Yes	2000
24	1.20	148	177.60	11.4	7.50	23	Yes	2000
25	1.14	148	168.72	11.6	7.60	28	Yes	2000
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.00	0	0.00	0.0	0.00	0	Yes	0
28	0.92	148	136.16	12.2	7.60	27	Yes	2000
29	1.09	148	161.32	12.4	7.60	28	Yes	2000
30	1.27	148	187.96	12.5	7.50	23	Yes	2000
31	1.11	148	164.28	12.6	7.50	23	Yes	2000

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012