

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

22-Apr

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.022	0.022	0.000	0.022	0.026	0.026	0.026
2	0.024	0.000	0.000	0.000	0.000	0.000	0.024
3	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4	0.000	0.000	0.000	0.026	0.034	0.026	0.034
5	0.027	0.026	0.000	0.026	0.036	0.030	0.036
6	0.030	0.029	0.000	0.027	0.046	0.030	0.046
7	0.028	0.026	0.027	0.028	0.026	0.026	0.028
8	0.026	0.000	0.000	0.026	0.033	0.036	0.036
9	0.029	0.040	0.000	0.000	0.000	0.000	0.040
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11	0.000	0.000	0.000	0.037	0.030	0.029	0.037
12	0.028	0.029	0.026	0.032	0.028	0.028	0.032
13	0.028	0.000	0.000	0.028	0.040	0.026	0.040
14	0.024	0.024	0.000	0.024	0.030	0.026	0.030
15	0.024	0.000	0.000	0.021	0.028	0.024	0.028
16	0.024	0.000	0.000	0.000	0.000	0.000	0.024
17	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18	0.000	0.000	0.000	0.024	0.039	0.022	0.039
19	0.020	0.020	0.000	0.024	0.034	0.022	0.034
20	0.020	0.000	0.000	0.024	0.040	0.022	0.040
21	0.020	0.000	0.000	0.022	0.020	0.022	0.022
22	0.023	0.020	0.000	0.022	0.026	0.020	0.026
23	0.020	0.000	0.000	0.000	0.000	0.000	0.020
24	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.000	0.026	0.032	0.022	0.032
26	0.020	0.038	0.022	0.038	0.028	0.020	0.038
27	0.020	0.048	0.022	0.020	0.026	0.026	0.048
28	0.024	0.000	0.000	0.022	0.026	0.022	0.026
29	0.019	0.028	0.020	0.020	0.026	0.020	0.028
30	0.020	0.031	0.000	0.000	0.000	0.000	0.031
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration 95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes:		PRINTED NAME: Ronald Wanner SIGNATURE: <i>Ronald Wanner</i> PHONE #: (503) 738-5112 DATE: 5/5/22 T-08898	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

22-Apr

System Name:		Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv:	
								0.5	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	1.13	148	167.24	12.4	7.50	23	Yes	2000	
2	0.00	0	0.00	0.0	0.00	0	Yes	0	
3	0.00	0	0.00	0.0	0.00	0	Yes	0	
4	0.84	148	124.32	12.4	7.60	27	Yes	2000	
5	1.10	148	162.80	12.3	7.50	23	Yes	2000	
6	1.06	115	121.90	12.3	7.60	28	Yes	2400	
7	1.10	123	135.30	12.6	7.60	28	Yes	2200	
8	1.05	123	129.15	12.8	7.40	23	Yes	2200	
9	0.00	0	0.00	0.0	0.00	0	Yes	0	
10	0.00	0	0.00	0.0	0.00	0	Yes	0	
11	0.77	148	113.96	12.1	7.50	22	Yes	2000	
12	1.05	148	155.40	11.6	7.60	28	Yes	2000	
13	1.06	148	156.88	11.4	7.50	23	Yes	2000	
14	1.10	148	162.80	11.5	7.50	23	Yes	2000	
15	1.07	148	158.36	11.4	7.60	28	Yes	2000	
16	0.00	0	0.00	0.0	0.00	0	Yes	0	
17	0.00	0	0.00	0.0	0.00	0	Yes	0	
18	0.96	148	142.08	11.8	7.40	22	Yes	2000	
19	1.11	148	164.28	11.4	7.60	28	Yes	2000	
20	1.00	148	148.00	11.6	7.60	28	Yes	2000	
21	1.00	148	148.00	11.4	7.30	22	Yes	2000	
22	1.08	148	159.84	11.6	7.60	28	Yes	2000	
23	0.00	0	0.00	0.0	0.00	0	Yes	0	
24	0.00	0	0.00	0.0	0.00	0	Yes	0	
25	0.94	148	139.12	12.3	7.60	27	Yes	2000	
26	1.16	148	171.68	12.4	7.50	23	Yes	2000	
27	1.15	148	170.20	12.6	7.60	28	Yes	2000	
28	1.15	123	141.45	13.2	7.50	23	Yes	2300	
29	1.18	132	155.76	13.3	7.50	23	Yes	2200	
30	0.00	0	0.00	0.0	0.00	0	Yes	0	
31	0.00	0	0.00	0.0	0.00	0	Yes	0	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012