

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.022	0.026	0.020	0.026
3	0.018	0.018	0.018	0.024	0.030	0.022	0.030
4	0.020	0.018	0.029	0.022	0.030	0.022	0.030
5	0.020	0.000	0.000	0.024	0.040	0.022	0.040
6	0.021	0.000	0.000	0.026	0.034	0.020	0.034
7	0.020	0.020	0.000	0.000	0.000	0.000	0.020
8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9	0.000	0.000	0.000	0.021	0.030	0.022	0.030
10	0.020	0.020	0.000	0.024	0.034	0.022	0.034
11	0.000	0.000	0.000	0.030	0.042	0.022	0.042
12	0.024	0.020	0.000	0.026	0.026	0.022	0.026
13	0.022	0.020	0.000	0.028	0.036	0.024	0.036
14	0.000	0.000	0.000	0.020	0.028	0.000	0.028
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16	0.000	0.000	0.000	0.026	0.030	0.022	0.030
17	0.020	0.000	0.000	0.024	0.024	0.022	0.024
18	0.020	0.020	0.020	0.024	0.029	0.022	0.029
19	0.020	0.000	0.000	0.027	0.033	0.024	0.033
20	0.022	0.023	0.000	0.026	0.036	0.024	0.036
21	0.022	0.022	0.000	0.000	0.000	0.000	0.022
22	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23	0.000	0.000	0.000	0.026	0.034	0.026	0.034
24	0.024	0.000	0.000	0.024	0.024	0.024	0.024
25	0.000	0.000	0.000	0.026	0.042	0.028	0.042
26	0.000	0.000	0.000	0.051	0.041	0.042	0.051
27	0.042	0.040	0.042	0.049	0.048	0.044	0.049
28	0.043	0.044	0.000	0.000	0.000	0.000	0.044
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.050	0.043	0.048	0.050
31	0.050	0.048	0.000	0.044	0.056	0.050	0.056

Conventional or Direct Filtration 95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes:		PRINTED NAME: Ronald Wanner SIGNATURE: <i>Ronald Wanner</i> DATE: 6/1/20 PHONE #: (503) 738-5112 T-08898 FE	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effic. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.96	148	142.08	13.7	7.50	22	Yes	2000
3	1.14	148	168.72	13.8	7.50	23	Yes	2000
4	1.15	148	170.20	13.7	7.60	28	Yes	2000
5	1.11	148	164.28	13.9	7.50	23	Yes	2000
6	1.09	148	161.32	13.8	7.60	28	Yes	2000
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.00	0	0.00	0.0	0.00	0	Yes	0
9	0.91	148	134.68	13.8	7.60	27	Yes	2000
10	1.08	148	159.84	13.4	7.60	25	Yes	2000
11	0.98	123	120.54	13.5	7.60	27	Yes	2300
12	1.09	123	134.07	13.6	7.60	28	Yes	2300
13	1.07	148	158.36	13.6	7.40	23	Yes	2000
14	0.92	148	136.16	13.6	7.50	22	Yes	2000
15	0.00	0	0.00	0.0	0.00	0	Yes	0
16	0.96	148	142.08	13.8	7.40	22	Yes	2000
17	1.01	148	149.48	13.9	7.60	28	Yes	2000
18	0.92	148	136.16	14.2	7.60	27	Yes	2000
19	0.74	148	109.52	14.3	7.60	26	Yes	2000
20	0.44	148	65.12	14.4	7.40	21	Yes	2000
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	0.85	148	125.80	14.9	7.60	27	Yes	2000
24	1.06	148	156.88	14.9	7.50	23	Yes	2000
25	0.92	148	136.16	14.9	7.60	27	Yes	2000
26	0.70	148	103.60	15.6	7.50	15	Yes	2000
27	1.18	148	174.64	15.7	7.50	15	Yes	2000
28	0.00	0	0.00	0.0	0.00	0	Yes	0
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.83	148	122.84	15.3	7.50	15	Yes	2000
31	1.14	148	168.72	15.5	7.60	19	Yes	2000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012