

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.053	0.000	0.000	0.053	0.056	0.052	0.056
2	0.050	0.053	0.000	0.052	0.059	0.050	0.059
3	0.051	0.000	0.000	0.053	0.056	0.052	0.056
4	0.052	0.051	0.000	0.000	0.000	0.000	0.052
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6	0.000	0.000	0.000	0.055	0.060	0.066	0.066
7	0.054	0.000	0.000	0.051	0.054	0.052	0.054
8	0.051	0.048	0.000	0.050	0.052	0.051	0.052
9	0.049	0.000	0.000	0.046	0.068	0.054	0.068
10	0.053	0.000	0.000	0.058	0.052	0.054	0.058
11	0.055	0.000	0.000	0.000	0.000	0.000	0.055
12	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13	0.000	0.000	0.000	0.056	0.088	0.056	0.088
14	0.054	0.000	0.000	0.054	0.067	0.054	0.067
15	0.052	0.000	0.000	0.066	0.068	0.064	0.068
16	0.062	0.062	0.000	0.062	0.078	0.066	0.078
17	0.066	0.000	0.000	0.060	0.080	0.072	0.080
18	0.075	0.000	0.000	0.000	0.000	0.000	0.075
19	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.067	0.076	0.072	0.076
21	0.067	0.067	0.000	0.070	0.079	0.074	0.079
22	0.068	0.000	0.000	0.066	0.079	0.064	0.079
23	0.060	0.000	0.000	0.060	0.076	0.066	0.076
24	0.066	0.060	0.063	0.060	0.075	0.064	0.075
25	0.060	0.062	0.060	0.000	0.000	0.000	0.062
26	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27	0.000	0.000	0.000	0.058	0.058	0.067	0.067
28	0.054	0.054	0.054	0.059	0.075	0.067	0.075
29	0.051	0.050	0.000	0.050	0.057	0.064	0.064
30	0.056	0.000	0.000	0.055	0.048	0.048	0.056
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration 95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes:		PRINTED NAME: Ronald Wanner SIGNATURE: <i>Ronald Wanner</i> PHONE #: (503) 738-5112	
		7/11/2022 T-08898	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.13	148	167.24	15.8	7.60	19	Yes	2000
2	1.06	148	156.88	15.8	7.50	15	Yes	2000
3	1.09	148	161.32	15.9	7.50	15	Yes	2000
4	0.00	0	0.00	0.0	0.00	0	Yes	0
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	0.85	148	125.80	16.1	7.60	18	Yes	2000
7	1.03	148	152.44	16.5	7.50	15	Yes	2000
8	1.07	148	158.36	16.6	7.60	0	Yes	2000
9	1.00	148	148.00	16.7	6.80	18	Yes	2000
10	1.09	148	161.32	16.8	7.50	17	Yes	2000
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	0.81	148	119.88	16.6	7.60	18	Yes	2000
14	1.09	148	161.32	16.4	17.60	19	Yes	2000
15	1.08	148	159.84	16.5	7.60	19	Yes	2000
16	1.07	148	158.36	16.3	7.50	15	Yes	2000
17	1.00	148	148.00	16.3	7.60	18	Yes	2000
18	0.00	0	0.00	0.0	0.00	0	Yes	0
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	0.73	148	108.04	16.3	7.50	15	Yes	2000
21	1.04	148	153.92	16.6	7.60	19	Yes	2000
22	0.97	148	143.56	16.9	7.60	18	Yes	2000
23	1.07	148	158.36	16.9	7.60	19	Yes	2000
24	1.13	148	167.24	17.0	7.60	19	Yes	2000
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.79	115	90.85	17.9	7.50	15	Yes	2400
28	1.10	132	145.20	18.2	7.60	19	Yes	2200
29	1.00	132	132.00	18.3	7.50	15	Yes	2200
30	1.00	132	132.00	18.7	7.50	15	Yes	2200
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012