

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

22-Jul

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.056	0.047	0.046	0.059	0.060	0.058	0.060
2	0.059	0.000	0.000	0.000	0.000	0.000	0.059
3	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4	0.000	0.000	0.000	0.060	0.060	0.058	0.060
5	0.066	0.060	0.000	0.044	0.042	0.036	0.066
6	0.036	0.036	0.036	0.037	0.034	0.034	0.037
7	0.034	0.000	0.000	0.034	0.048	0.049	0.049
8	0.048	0.048	0.000	0.041	0.036	0.034	0.048
9	0.034	0.000	0.000	0.000	0.000	0.000	0.034
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11	0.000	0.000	0.000	0.046	0.045	0.045	0.046
12	0.049	0.050	0.052	0.048	0.050	0.049	0.052
13	0.047	0.000	0.000	0.056	0.054	0.048	0.056
14	0.049	0.052	0.000	0.071	0.076	0.062	0.076
15	0.059	0.000	0.000	0.059	0.076	0.070	0.076
16	0.064	0.064	0.058	0.000	0.000	0.000	0.064
17	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18	0.000	0.000	0.000	0.062	0.060	0.060	0.062
19	0.058	0.065	0.070	0.071	0.071	0.068	0.071
20	0.063	0.000	0.000	0.056	0.053	0.047	0.063
21	0.048	0.042	0.048	0.048	0.053	0.044	0.053
22	0.044	0.046	0.000	0.046	0.048	0.046	0.048
23	0.045	0.046	0.000	0.000	0.000	0.000	0.046
24	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.000	0.050	0.060	0.050	0.060
26	0.040	0.050	0.052	0.052	0.050	0.050	0.052
27	0.046	0.050	0.079	0.056	0.050	0.048	0.079
28	0.046	0.045	0.000	0.042	0.050	0.048	0.050
29	0.046	0.044	0.000	0.054	0.056	0.052	0.056
30	0.050	0.048	0.052	0.000	0.000	0.000	0.052
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:		PRINTED NAME: Ronald Wanner	DATE: 8/1/22
		SIGNATURE: <i>Ronald Wanner</i>	T-08898
		PHONE #: (503) 738-5112	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

22-Jul

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.13	132	149.16	18.9	7.60	19	Yes	2200
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	0.00	0	0.00	0.0	0.00	0	Yes	0
4	0.62	132	81.84	18.8	7.50	15	Yes	2200
5	1.13	132	149.16	19.0	7.50	19	Yes	2200
6	1.20	123	147.60	19.1	7.60	19	Yes	2300
7	1.03	123	126.69	19.1	7.50	16	Yes	2300
8	0.95	123	116.85	19.3	7.50	15	Yes	2300
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	0.00	0	0.00	0.0	0.00	0	Yes	0
11	0.61	123	75.03	19.7	7.60	18	Yes	2300
12	1.08	123	132.84	20.0	7.60	14	Yes	2300
13	0.94	123	115.62	20.0	7.60	14	Yes	2300
14	1.12	123	137.76	20.5	7.50	12	Yes	2300
15	1.03	115	118.45	20.6	7.40	12	Yes	2400
16	0.00	0	0.00	0.0	0.00	0	Yes	0
17	0.00	0	0.00	0.0	0.00	0	Yes	0
18	0.51	115	58.65	20.7	7.70	13	Yes	2400
19	1.20	115	138.00	21.1	7.50	12	Yes	2400
20	1.09	115	125.35	21.1	7.50	11	Yes	2400
21	1.16	115	133.40	21.3	7.50	12	Yes	2400
22	1.12	115	128.80	21.2	7.40	12	Yes	2400
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.00	0	0.00	0.0	0.00	0	Yes	0
25	0.57	115	65.55	21.0	7.60	13	Yes	2400
26	1.11	115	127.65	21.2	7.50	12	Yes	2400
27	1.06	115	121.90	21.5	7.60	14	Yes	2400
28	0.98	115	112.70	21.6	7.50	11	Yes	2400
29	0.94	123	115.62	21.7	7.60	14	Yes	2300
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012