

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

22-Aug

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.060	0.041	0.040	0.060
2	0.040	0.038	0.040	0.040	0.038	0.035	0.040
3	0.034	0.034	0.000	0.036	0.048	0.036	0.048
4	0.034	0.000	0.000	0.036	0.036	0.036	0.036
5	0.035	0.036	0.000	0.036	0.036	0.036	0.036
6	0.034	0.034	0.000	0.000	0.000	0.000	0.034
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.034	0.034	0.030	0.034
9	0.030	0.032	0.030	0.032	0.037	0.030	0.037
10	0.030	0.030	0.032	0.029	0.030	0.026	0.032
11	0.026	0.000	0.000	0.028	0.032	0.026	0.032
12	0.027	0.000	0.000	0.028	0.032	0.028	0.032
13	0.026	0.026	0.026	0.000	0.000	0.000	0.026
14	0.000	0.000	0.000	0.028	0.027	0.000	0.028
15	0.000	0.000	0.000	0.028	0.028	0.026	0.028
16	0.025	0.026	0.000	0.026	0.026	0.026	0.026
17	0.026	0.000	0.000	0.026	0.027	0.025	0.027
18	0.024	0.024	0.000	0.026	0.025	0.024	0.026
19	0.024	0.000	0.000	0.026	0.026	0.026	0.026
20	0.026	0.000	0.000	0.000	0.000	0.000	0.026
21	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22	0.000	0.000	0.000	0.029	0.036	0.028	0.036
23	0.026	0.026	0.030	0.026	0.032	0.026	0.032
24	0.026	0.000	0.000	0.026	0.037	0.026	0.037
25	0.026	0.000	0.000	0.026	0.028	0.026	0.028
26	0.025	0.000	0.000	0.026	0.028	0.026	0.028
27	0.026	0.024	0.000	0.000	0.000	0.000	0.026
28	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29	0.000	0.000	0.000	0.023	0.026	0.024	0.026
30	0.024	0.026	0.025	0.026	0.028	0.025	0.028
31	0.026	0.000	0.000	0.026	0.028	0.026	0.028

<p align="center">Conventional or Direct Filtration</p> <p>95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No</p> <p>All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No</p> <p>All turbidity readings < IFE² triggers <input checked="" type="radio"/> Yes <input type="radio"/> No</p>	<p align="center">Monthly Summary (Answer Yes or No)</p> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%;">CT's met everyday? (see back)</td> <td style="width:50%;">All Cl2 residual at entry point ≥ 0.2 mg/l?</td> </tr> <tr> <td align="center"><input checked="" type="radio"/> Yes <input type="radio"/> No</td> <td align="center"><input checked="" type="radio"/> Yes <input type="radio"/> No</td> </tr> </table>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?	<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No
CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?				
<input checked="" type="radio"/> Yes <input type="radio"/> No	<input checked="" type="radio"/> Yes <input type="radio"/> No				
<p>Notes:</p>	<p>PRINTED NAME: Ronald Wannier</p> <p>SIGNATURE: <i>Ronald Wannier</i></p> <p>PHONE #: (503) 738-5112</p> <p>DATE: 9/1/2022</p> <p>T-08898</p>				

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

22-Aug

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.38	123	46.74	21.9	7.50	10	Yes	2300
2	1.07	123	131.61	22.1	7.60	14	Yes	2300
3	1.05	123	129.15	22.2	7.60	14	Yes	2300
4	1.08	123	132.84	22.3	7.60	14	Yes	2300
5	1.01	123	124.23	22.2	7.50	12	Yes	2300
6	0.00	0	0.00	0.0	0.00	0	Yes	0
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.53	115	60.95	22.1	7.50	11	Yes	2400
9	1.24	115	142.60	22.1	7.60	14	Yes	2400
10	1.14	115	131.10	22.2	7.60	14	Yes	2400
11	1.02	123	125.46	21.7	7.60	14	Yes	2300
12	0.95	123	116.85	21.9	7.60	14	Yes	2300
13	0.00	0	0.00	0.0	0.00	0	Yes	0
14	0.82	123	100.86	21.7	7.50	11	Yes	2300
15	0.83	115	95.45	21.8	7.50	11	Yes	2400
16	0.94	115	108.10	22.0	7.50	11	Yes	2400
17	1.03	115	118.45	22.2	7.50	11	Yes	2400
18	1.02	115	117.30	22.3	7.50	11	Yes	2400
19	1.03	115	118.45	22.5	7.60	14	Yes	2400
20	0.00	0	0.00	0.0	0.00	0	Yes	0
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.66	115	75.90	22.5	7.50	11	Yes	2400
23	1.12	115	128.80	23.0	7.60	14	Yes	2400
24	1.06	115	121.90	22.8	7.60	14	Yes	2400
25	1.04	115	119.60	22.9	7.50	12	Yes	2400
26	0.99	115	113.85	22.9	7.40	11	Yes	2400
27	0.00	0	0.00	0.0	0.00	0	Yes	0
28	0.00	0	0.00	0.0	0.00	0	Yes	0
29	0.67	115	77.05	22.4	7.30	11	Yes	2400
30	1.20	115	138.00	22.4	7.40	12	Yes	2400
31	1.09	115	125.35	22.3	7.50	12	Yes	2400

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012