

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: CLATSOP

22-Sep

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.028	0.026	0.000	0.028	0.028	0.027	0.028
2	0.028	0.000	0.000	0.028	0.030	0.028	0.030
3	0.028	0.028	0.000	0.000	0.000	0.000	0.028
4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.000	0.030	0.030	0.028	0.030
6	0.030	0.028	0.028	0.028	0.029	0.028	0.030
7	0.030	0.000	0.000	0.030	0.032	0.028	0.032
8	0.028	0.000	0.000	0.031	0.030	0.028	0.031
9	0.028	0.000	0.000	0.032	0.032	0.030	0.032
10	0.026	0.030	0.030	0.000	0.000	0.000	0.030
11	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12	0.000	0.000	0.000	0.039	0.030	0.020	0.039
13	0.030	0.028	0.000	0.033	0.031	0.030	0.033
14	0.028	0.000	0.000	0.048	0.039	0.038	0.048
15	0.035	0.035	0.000	0.037	0.038	0.039	0.039
16	0.036	0.000	0.000	0.038	0.039	0.035	0.039
17	0.038	0.049	0.035	0.000	0.000	0.000	0.049
18	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19	0.000	0.000	0.000	0.034	0.038	0.042	0.042
20	0.037	0.040	0.000	0.042	0.036	0.036	0.042
21	0.036	0.000	0.000	0.033	0.036	0.038	0.038
22	0.049	0.044	0.047	0.042	0.036	0.034	0.049
23	0.036	0.000	0.000	0.041	0.036	0.036	0.041
24	0.038	0.046	0.000	0.000	0.000	0.000	0.046
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26	0.000	0.000	0.000	0.047	0.036	0.036	0.047
27	0.046	0.044	0.046	0.047	0.038	0.041	0.047
28	0.056	0.000	0.000	0.043	0.033	0.030	0.056
29	0.030	0.032	0.000	0.032	0.038	0.038	0.038
30	0.038	0.000	0.000	0.047	0.030	0.032	0.047
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

<b>Conventional or Direct Filtration</b> 95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		<b>Monthly Summary (Answer Yes or No)</b> CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No	
Notes:		PRINTED NAME: Ronald Wanner SIGNATURE: <i>Ronald Wanner</i> DATE: 10/3/22 PHONE #: ( 503 ) 738-5112 T-08898	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

22-Sep

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.06	115	121.90	22.0	7.50	12	Yes	2400
2	0.94	115	108.10	22.0	7.50	11	Yes	2400
3	1.10	115	126.50	22.1	7.50	11	Yes	2400
4	0.00	0	0.00	0.0	0.00	0	Yes	0
5	0.65	115	74.75	21.6	7.40	11	Yes	2400
6	1.13	115	129.95	21.3	7.50	12	Yes	2400
7	1.04	115	119.60	21.2	7.40	11	Yes	2400
8	1.00	115	115.00	20.9	7.40	11	Yes	2400
9	1.08	115	124.20	20.7	7.50	12	Yes	2400
10	1.16	115	133.40	20.7	7.40	12	Yes	2400
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	0.79	115	90.85	20.0	7.50	11	Yes	2400
13	1.03	115	118.45	20.0	7.50	12	Yes	2400
14	0.93	132	122.76	20.0	7.40	11	Yes	2200
15	0.96	132	126.72	20.1	7.40	11	Yes	2200
16	0.91	132	120.12	19.9	7.40	1	Yes	2200
17	1.11	132	146.52	19.7	7.40	15	Yes	2200
18	0.00	0	0.00	0.0	0.00	0	Yes	0
19	0.62	132	81.84	19.5	7.50	15	Yes	2200
20	1.02	132	134.64	19.4	7.40	15	Yes	2200
21	0.98	132	129.36	19.4	7.40	15	Yes	2200
22	1.18	132	155.76	19.2	7.50	15	Yes	2200
23	1.07	132	141.24	19.1	7.50	15	Yes	2200
24	1.20	132	158.40	19.1	7.50	15	Yes	2200
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.80	132	105.60	18.9	7.50	15	Yes	2200
27	1.20	132	158.40	18.9	7.50	15	Yes	2200
28	1.11	132	146.52	18.5	7.40	15	Yes	2200
29	1.12	132	147.84	18.4	7.50	15	Yes	2200
30	1.07	132	141.24	18.4	7.50	15	Yes	2200
31	0.00	0	0.00	0.0	0.00	0	Yes	0

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012