

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

22-Oct

System Name: SEASIDE ID#: 4100799 WTP - : A							
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.032	0.031	0.000	0.000	0.000	0.000	0.032
2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3	0.000	0.000	0.000	0.034	0.036	0.044	0.044
4	0.044	0.068	0.070	0.069	0.034	0.043	0.070
5	0.042	0.063	0.051	0.059	0.031	0.035	0.063
6	0.030	0.035	0.000	0.039	0.032	0.032	0.039
7	0.032	0.032	0.000	0.036	0.030	0.030	0.036
8	0.036	0.040	0.000	0.000	0.000	0.000	0.040
9	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.026	0.028	0.033	0.033
11	0.035	0.047	0.044	0.049	0.030	0.034	0.049
12	0.033	0.050	0.059	0.069	0.032	0.042	0.069
13	0.054	0.000	0.000	0.046	0.029	0.030	0.054
14	0.034	0.037	0.000	0.054	0.027	0.026	0.054
15	0.031	0.037	0.034	0.000	0.000	0.000	0.037
16	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17	0.000	0.000	0.000	0.026	0.030	0.036	0.036
18	0.036	0.037	0.000	0.048	0.036	0.063	0.063
19	0.057	0.066	0.000	0.043	0.027	0.027	0.066
20	0.029	0.000	0.000	0.036	0.029	0.026	0.036
21	0.032	0.032	0.036	0.048	0.029	0.037	0.048
22	0.038	0.038	0.000	0.000	0.000	0.000	0.038
23	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24	0.000	0.000	0.000	0.027	0.029	0.027	0.029
25	0.030	0.026	0.000	0.057	0.022	0.031	0.057
26	0.000	0.000	0.000	0.025	0.021	0.026	0.026
27	0.024	0.023	0.000	0.029	0.024	0.023	0.029
28	0.023	0.000	0.000	0.028	0.026	0.025	0.028
29	0.028	0.040	0.032	0.000	0.000	0.000	0.040
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.022	0.032	0.028	0.032

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		
Notes:	PRINTED NAME: Ronald Wanner SIGNATURE: <i>Ronald Wanner</i> DATE: 11-1-22 PHONE #: (503) 738-5112 T-08898	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

22-Oct

System Name: Seaside		ID#: 4100799			WTP -: A		Disinfection <i>Giardia</i> Log Inactiv:	0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.13	132	149.16	18.5	7.40	15	Yes	2200
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	0.76	132	100.32	18.5	7.40	15	Yes	2200
4	1.07	132	141.24	18.5	7.40	15	Yes	2200
5	1.05	148	155.40	18.5	7.40	15	Yes	2000
6	1.02	148	150.96	18.4	7.40	15	Yes	2000
7	0.98	148	145.04	18.5	7.40	15	Yes	2000
8	1.08	148	159.84	18.5	7.50	15	Yes	2000
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	0.85	148	125.80	18.2	7.30	15	Yes	2000
11	1.03	148	152.44	18.1	7.40	15	Yes	2000
12	1.01	148	149.48	18.0	7.50	15	Yes	2000
13	1.02	148	150.96	17.7	7.40	0	Yes	2000
14	0.98	148	145.04	17.7	7.40	15	Yes	2000
15	1.07	148	158.36	17.6	7.50	15	Yes	2000
16	0.00	0	0.00	0.0	0.00	0	Yes	0
17	0.57	148	84.36	17.3	7.40	14	Yes	2000
18	1.06	148	156.88	17.1	7.50	15	Yes	2000
19	0.99	140	138.60	17.0	7.50	15	Yes	2100
20	0.98	115	112.70	16.9	7.50	15	Yes	2400
21	1.09	132	143.88	16.5	7.50	15	Yes	2200
22	1.03	214	220.42	16.2	7.50	15	Yes	1200
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.69	123	84.87	15.6	7.40	15	Yes	2300
25	1.07	132	141.24	15.2	7.50	15	Yes	2200
26	0.94	123	115.62	14.8	7.40	22	Yes	2300
27	1.03	123	126.69	14.6	7.40	23	Yes	2300
28	1.03	123	126.69	14.6	7.50	23	Yes	2300
29	0.96	218	209.28	14.7	7.40	22	Yes	1150
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.64	123	78.72	14.4	7.40	22	Yes	2300

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012