

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: CLATSOP

22-Nov

System Name: SEASIDE ID#: 4100799 WTP - : A							
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.020	0.024	0.022	0.024
2	0.022	0.000	0.000	0.022	0.023	0.022	0.023
3	0.022	0.024	0.000	0.020	0.022	0.022	0.024
4	0.000	0.000	0.000	0.022	0.025	0.023	0.025
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7	0.000	0.000	0.000	0.020	0.032	0.025	0.032
8	0.022	0.023	0.020	0.020	0.031	0.024	0.031
9	0.023	0.000	0.000	0.022	0.032	0.024	0.032
10	0.022	0.000	0.000	0.020	0.026	0.022	0.026
11	0.021	0.000	0.000	0.020	0.025	0.022	0.025
12	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.018	0.027	0.022	0.027
15	0.021	0.020	0.000	0.019	0.025	0.022	0.025
16	0.020	0.000	0.000	0.020	0.026	0.022	0.026
17	0.020	0.000	0.000	0.019	0.026	0.022	0.026
18	0.020	0.020	0.000	0.018	0.026	0.021	0.026
19	0.020	0.000	0.000	0.000	0.000	0.000	0.020
20	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21	0.000	0.000	0.000	0.018	0.024	0.021	0.024
22	0.019	0.000	0.000	0.018	0.022	0.022	0.022
23	0.020	0.018	0.000	0.018	0.027	0.022	0.027
24	0.020	0.000	0.000	0.018	0.022	0.020	0.022
25	0.000	0.000	0.019	0.018	0.023	0.020	0.023
26	0.020	0.020	0.000	0.000	0.000	0.000	0.020
27	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28	0.000	0.000	0.000	0.018	0.024	0.020	0.024
29	0.019	0.000	0.000	0.018	0.022	0.020	0.022
30	0.021	0.020	0.000	0.026	0.020	0.019	0.026
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
<b>Notes:</b>		PRINTED NAME: Ronald Wanner SIGNATURE: <i>Ronald Wanner</i> PHONE #: ( 503 ) 738-5112 DATE: 12/1/2022 T-08898	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

22-Nov

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	132	132.00	14.1	7.50	22	Yes	2200
2	0.94	148	139.12	13.7	7.50	22	Yes	2000
3	1.03	148	152.44	13.1	7.50	23	Yes	2000
4	1.00	148	148.00	13.8	7.40	22	Yes	2000
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	0.00	0	0.00	0.0	0.00	0	Yes	0
7	0.81	148	119.88	13.9	7.50	22	Yes	2000
8	1.09	148	161.32	12.9	7.40	23	Yes	2000
9	1.03	148	152.44	12.7	7.40	23	Yes	2000
10	1.05	148	155.40	12.3	7.40	23	Yes	2000
11	1.06	148	156.88	12.2	7.40	23	Yes	2000
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	0.00	0	0.00	0.0	0.00	0	Yes	0
14	0.88	148	130.24	13.6	7.50	22	Yes	2000
15	1.09	148	161.32	11.1	7.50	23	Yes	2000
16	1.07	148	158.36	11.4	7.60	28	Yes	2000
17	1.08	148	159.84	10.7	7.50	23	Yes	2000
18	1.15	148	170.20	10.0	7.50	23	Yes	2000
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	0.00	0	0.00	0.0	0.00	0	Yes	0
21	0.98	148	145.04	10.1	7.50	23	Yes	2000
22	1.03	148	152.44	9.9	7.50	43	Yes	2000
23	1.17	148	173.16	10.0	7.50	23	Yes	2000
24	1.11	148	164.28	9.8	7.40	43	Yes	2000
25	1.11	148	164.28	9.9	7.50	43	Yes	2000
26	1.15	148	170.20	9.8	7.50	43	Yes	2000
27	0.00	0	0.00	0.0	0.00	0	Yes	0
28	0.95	148	140.60	10.4	7.40	22	Yes	2000
29	1.09	148	161.32	9.9	7.50	43	Yes	2000
30	1.05	148	155.40	9.6	7.40	43	Yes	2000
31	0.00	0	0.00	0.0	0.00	0	Yes	0

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.