

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: CLATSOP

22-Dec

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.018	0.018	0.000	0.017	0.024	0.022	0.024
2	0.000	0.000	0.000	0.019	0.020	0.022	0.022
3	0.020	0.000	0.000	0.000	0.000	0.000	0.020
4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.000	0.018	0.024	0.020	0.024
6	0.018	0.000	0.000	0.018	0.036	0.022	0.036
7	0.000	0.000	0.000	0.018	0.018	0.018	0.018
8	0.018	0.018	0.000	0.016	0.021	0.020	0.021
9	0.000	0.000	0.000	0.018	0.022	0.020	0.022
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12	0.000	0.000	0.000	0.018	0.026	0.022	0.026
13	0.000	0.000	0.000	0.018	0.018	0.018	0.018
14	0.020	0.018	0.000	0.016	0.026	0.020	0.026
15	0.020	0.000	0.000	0.016	0.018	0.017	0.020
16	0.016	0.016	0.000	0.024	0.021	0.018	0.024
17	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19	0.000	0.000	0.000	0.016	0.022	0.019	0.022
20	0.018	0.000	0.000	0.016	0.016	0.016	0.018
21	0.016	0.000	0.000	0.028	0.019	0.018	0.028
22	0.016	0.000	0.000	0.016	0.016	0.018	0.018
23	0.015	0.000	0.000	0.016	0.020	0.022	0.022
24	0.016	0.000	0.000	0.000	0.000	0.000	0.016
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26	0.000	0.000	0.000	0.016	0.022	0.016	0.022
27	0.018	0.018	0.016	0.016	0.016	0.016	0.018
28	0.000	0.000	0.000	0.016	0.026	0.020	0.026
29	0.018	0.000	0.000	0.018	0.018	0.018	0.018
30	0.000	0.000	0.000	0.033	0.022	0.020	0.033
31	0.018	0.018	0.018	0.000	0.000	0.000	0.018

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
<b>Notes:</b>		<b>PRINTED NAME:</b> Ronald Wanner	
		<b>SIGNATURE:</b> <i>Ronald Wanner</i>	<b>DATE:</b> 1/2/23
		<b>PHONE #:</b> ( 503 ) 738-5112	<b>T-08898</b>

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

22-Dec

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv: 0.5		
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.06	148	156.88	9.3	7.40	43	Yes	2000
2	1.01	148	149.48	8.9	7.50	43	Yes	2000
3	1.12	148	165.76	8.9	7.50	43	Yes	2000
4	0.00	0	0.00	0.0	0.00	0	Yes	0
5	0.90	148	133.20	8.9	7.30	42	Yes	2000
6	1.17	148	173.16	8.8	7.40	43	Yes	2000
7	1.14	148	168.72	9.0	7.50	43	Yes	2000
8	1.16	148	171.68	9.1	7.40	43	Yes	2000
9	1.11	148	164.28	9.0	7.50	43	Yes	2000
10	0.00	0	0.00	0.0	0.00	0	Yes	0
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	1.01	148	149.48	9.5	7.40	43	Yes	2000
13	1.07	148	158.36	9.5	7.30	43	Yes	2000
14	1.12	148	165.76	9.6	7.30	43	Yes	2000
15	1.09	148	161.32	9.2	7.50	43	Yes	2000
16	1.13	148	167.24	9.0	7.50	43	Yes	2000
17	0.00	0	0.00	0.0	0.00	0	Yes	0
18	0.00	0	0.00	0.0	0.00	0	Yes	0
19	0.96	148	142.08	9.4	7.60	51	Yes	2000
20	1.06	148	156.88	8.7	7.50	43	Yes	2000
21	1.19	148	176.12	8.7	7.50	51	Yes	2000
22	1.21	148	179.08	7.8	7.40	43	Yes	2000
23	1.12	148	165.76	7.5	7.40	43	Yes	2000
24	1.14	148	168.72	7.8	7.40	43	Yes	2000
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.99	148	146.52	9.9	7.30	0	Yes	2000
27	1.14	148	168.72	10.3	7.50	22	Yes	2000
28	1.08	148	159.84	10.4	7.50	23	Yes	2000
29	1.07	148	158.36	10.3	7.40	23	Yes	2000
30	1.05	148	155.40	10.4	7.40	23	Yes	2000
31	1.09	148	161.32	10.6	7.40	23	Yes	2000

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012