

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

23-Feb

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.019	0.000	0.000	0.018	0.026	0.022	0.026
2	0.020	0.000	0.000	0.020	0.020	0.020	0.020
3	0.020	0.000	0.000	0.018	0.025	0.022	0.025
4	0.020	0.020	0.000	0.000	0.000	0.000	0.020
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6	0.000	0.000	0.000	0.020	0.030	0.022	0.030
7	0.022	0.000	0.000	0.020	0.020	0.020	0.022
8	0.020	0.000	0.000	0.020	0.024	0.022	0.024
9	0.022	0.000	0.000	0.020	0.020	0.020	0.022
10	0.000	0.000	0.000	0.020	0.031	0.024	0.031
11	0.022	0.022	0.022	0.000	0.000	0.000	0.022
12	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13	0.000	0.000	0.000	0.020	0.028	0.024	0.028
14	0.022	0.000	0.000	0.022	0.021	0.020	0.022
15	0.020	0.020	0.000	0.020	0.024	0.022	0.024
16	0.022	0.000	0.000	0.021	0.022	0.020	0.022
17	0.020	0.000	0.000	0.026	0.022	0.022	0.026
18	0.020	0.020	0.000	0.000	0.000	0.000	0.020
19	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.019	0.027	0.022	0.027
21	0.020	0.020	0.000	0.019	0.018	0.018	0.020
22	0.018	0.000	0.000	0.018	0.026	0.022	0.026
23	0.020	0.021	0.000	0.020	0.018	0.018	0.021
24	0.018	0.000	0.000	0.024	0.022	0.020	0.024
25	0.020	0.000	0.000	0.000	0.000	0.000	0.020
26	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27	0.000	0.000	0.000	0.018	0.032	0.022	0.032
28	0.020	0.020	0.000	0.020	0.019	0.018	0.020
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:		PRINTED NAME: Ronald Wanner SIGNATURE: <i>Ronald Wanner</i> PHONE #: (503) 738-5112 DATE: 3/1/2023 T-08898	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

23-Feb

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	148	148.00	8.9	7.40	42	Yes	2000
2	1.00	148	148.00	8.6	7.50	42	Yes	2000
3	1.09	148	161.32	8.7	7.40	43	Yes	2000
4	1.18	148	174.64	9.0	7.40	43	Yes	2000
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	1.00	148	148.00	9.6	7.50	42	Yes	2000
7	1.19	148	176.12	9.8	7.30	43	Yes	2000
8	1.09	148	161.32	9.9	7.40	43	Yes	2000
9	1.12	148	165.76	10.0	7.40	23	Yes	2000
10	1.10	148	162.80	10.3	7.40	23	Yes	2000
11	1.16	148	171.68	10.3	7.30	23	Yes	2000
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	1.01	148	149.48	10.4	7.40	23	Yes	2000
14	1.11	148	164.28	10.0	7.40	23	Yes	2000
15	1.17	148	173.16	9.6	7.40	43	Yes	2000
16	1.15	148	170.20	9.5	7.50	43	Yes	2000
17	1.03	148	152.44	9.7	7.40	43	Yes	2000
18	1.20	148	177.60	9.6	7.50	43	Yes	2000
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	1.06	148	156.88	10.1	7.60	28	Yes	2000
21	1.23	148	182.04	9.9	7.30	44	Yes	2000
22	1.21	148	179.08	9.7	7.50	44	Yes	2000
23	1.20	148	177.60	9.1	7.40	43	Yes	2000
24	1.11	148	164.28	8.2	7.30	43	Yes	2000
25	1.15	148	170.20	8.3	7.50	43	Yes	2000
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.99	148	146.52	8.3	7.30	42	Yes	2000
28	1.10	148	162.80	8.2	7.50	43	Yes	2000
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.