

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

23-Mar

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.018	0.000	0.000	0.018	0.024	0.022	0.024
2	0.020	0.020	0.000	0.018	0.018	0.020	0.020
3	0.018	0.000	0.000	0.018	0.024	0.022	0.024
4	0.022	0.000	0.000	0.000	0.000	0.000	0.022
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6	0.000	0.000	0.000	0.022	0.020	0.026	0.026
7	0.022	0.023	0.000	0.022	0.020	0.020	0.023
8	0.020	0.000	0.000	0.020	0.028	0.024	0.028
9	0.022	0.000	0.000	0.020	0.020	0.020	0.022
10	0.020	0.000	0.000	0.018	0.026	0.022	0.026
11	0.020	0.020	0.000	0.000	0.000	0.000	0.020
12	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13	0.000	0.000	0.000	0.018	0.027	0.022	0.027
14	0.020	0.020	0.000	0.018	0.018	0.018	0.020
15	0.018	0.000	0.000	0.018	0.028	0.022	0.028
16	0.020	0.020	0.000	0.020	0.019	0.018	0.020
17	0.018	0.000	0.000	0.018	0.024	0.020	0.024
18	0.020	0.019	0.000	0.000	0.000	0.000	0.020
19	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.018	0.027	0.020	0.027
21	0.020	0.000	0.000	0.018	0.018	0.018	0.020
22	0.019	0.018	0.000	0.020	0.022	0.020	0.022
23	0.020	0.020	0.000	0.018	0.018	0.017	0.020
24	0.016	0.000	0.000	0.016	0.023	0.024	0.024
25	0.020	0.000	0.000	0.000	0.000	0.000	0.020
26	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27	0.000	0.000	0.000	0.018	0.035	0.022	0.035
28	0.020	0.020	0.000	0.019	0.018	0.018	0.020
29	0.018	0.000	0.000	0.026	0.022	0.020	0.026
30	0.020	0.018	0.000	0.018	0.018	0.022	0.022
31	0.020	0.020	0.000	0.018	0.018	0.023	0.023

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		

Notes:

PRINTED NAME: Ronald Wanner
 SIGNATURE: *Ronald Wanner*
 PHONE #: (503) 738-5112
 DATE: 4/3/2023
 T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))
PAGE 1 of 2

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

23-Mar

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.06	148	156.88	8.2	7.50	43	Yes	2000
2	1.09	148	161.32	8.4	7.40	43	Yes	2000
3	1.07	148	158.36	8.7	7.50	43	Yes	2000
4	1.11	148	164.28	8.6	7.40	43	Yes	2000
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	0.93	148	137.64	8.5	7.60	51	Yes	2000
7	1.09	148	161.32	8.6	7.50	43	Yes	2000
8	1.05	148	155.40	8.7	7.40	43	Yes	2000
9	1.00	148	148.00	8.8	7.40	42	Yes	2000
10	1.00	148	148.00	8.7	7.50	42	Yes	2000
11	1.11	148	164.28	9.0	7.40	42	Yes	2000
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	0.88	148	130.24	9.7	7.30	42	Yes	2000
14	1.06	148	156.88	9.6	7.60	52	Yes	2000
15	1.06	148	156.88	9.9	7.50	43	Yes	2000
16	1.06	148	156.88	9.9	7.40	43	Yes	2000
17	1.12	148	165.76	10.2	7.30	23	Yes	2000
18	1.19	148	176.12	10.6	7.50	23	Yes	2000
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	1.03	148	152.44	11.2	7.30	23	Yes	2000
21	1.15	148	170.20	11.2	7.50	23	Yes	2000
22	1.17	148	173.16	11.5	7.40	23	Yes	2000
23	1.17	148	173.16	11.6	7.40	23	Yes	2000
24	1.16	148	171.68	11.4	7.50	23	Yes	2000
25	1.20	148	177.60	11.1	7.50	23	Yes	2000
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.98	148	145.04	11.0	7.30	23	Yes	2000
28	1.10	148	162.80	11.0	7.50	23	Yes	2000
29	1.12	148	165.76	10.8	7.50	23	Yes	2000
30	1.10	148	162.80	10.9	7.60	28	Yes	2000
31	1.13	148	167.24	10.9	7.40	23	Yes	2000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012