

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: CLATSOP

23-May

System Name: SEASIDE ID#: 4100799 WTP - : A							
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.030	0.031	0.025	0.031
2	0.022	0.022	0.022	0.030	0.025	0.024	0.030
3	0.024	0.022	0.000	0.022	0.032	0.025	0.032
4	0.024	0.022	0.022	0.024	0.035	0.022	0.035
5	0.033	0.000	0.000	0.032	0.024	0.030	0.033
6	0.028	0.032	0.030	0.000	0.000	0.000	0.032
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.030	0.027	0.027	0.030
9	0.024	0.025	0.000	0.024	0.039	0.030	0.039
10	0.030	0.026	0.000	0.028	0.026	0.026	0.030
11	0.026	0.025	0.000	0.037	0.030	0.000	0.037
12	0.000	0.000	0.000	0.032	0.028	0.026	0.032
13	0.026	0.024	0.026	0.000	0.000	0.000	0.026
14	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.028	0.048	0.044	0.048
16	0.044	0.044	0.000	0.048	0.050	0.049	0.050
17	0.052	0.050	0.054	0.070	0.054	0.066	0.070
18	0.063	0.060	0.068	0.058	0.050	0.048	0.068
19	0.048	0.046	0.000	0.048	0.054	0.050	0.054
20	0.048	0.000	0.000	0.000	0.000	0.000	0.048
21	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22	0.000	0.000	0.000	0.050	0.057	0.052	0.057
23	0.050	0.046	0.056	0.045	0.056	0.050	0.056
24	0.051	0.048	0.052	0.052	0.046	0.045	0.052
25	0.042	0.044	0.000	0.040	0.048	0.040	0.048
26	0.040	0.000	0.000	0.044	0.049	0.043	0.049
27	0.038	0.040	0.043	0.000	0.000	0.000	0.043
28	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29	0.000	0.000	0.000	0.043	0.041	0.038	0.043
30	0.036	0.036	0.038	0.057	0.046	0.041	0.057
31	0.046	0.041	0.054	0.044	0.048	0.041	0.054

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl2 residual at entry point $\geq$ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All daily turbidity readings $\leq$ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		

Notes:	PRINTED NAME: Ronald Wanner	
	SIGNATURE: <i>Ronald Wanner</i>	DATE: 6/2/23
	PHONE #: ( 503 ) 738-5112	T-08898

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

23-May

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv: 0.5		
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	148	148.00	14.1	7.50	23	Yes	2000
2	1.11	148	164.28	14.4	7.40	23	Yes	2000
3	1.11	148	164.28	14.6	7.40	23	Yes	2000
4	1.14	148	168.72	15.6	7.50	15	Yes	2000
5	1.13	148	167.24	15.3	7.40	15	Yes	2000
6	1.10	231	254.10	15.4	7.30	15	Yes	1000
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.89	132	117.48	15.0	7.30	15	Yes	2200
9	1.15	148	170.20	15.0	7.50	15	Yes	2000
10	1.06	148	156.88	14.9	7.40	23	Yes	2000
11	1.15	148	170.20	15.3	7.50	15	Yes	2000
12	1.00	132	132.00	15.4	7.40	15	Yes	2200
13	1.15	132	151.80	15.8	7.30	15	Yes	2200
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.66	132	87.12	16.4	7.50	15	Yes	2200
16	1.09	132	143.88	16.6	7.50	15	Yes	2200
17	1.14	132	150.48	16.9	7.50	15	Yes	2200
18	1.13	132	149.16	17.2	7.30	15	Yes	2200
19	1.14	132	150.48	17.2	7.60	19	Yes	2200
20	1.09	132	143.88	17.4	7.50	15	Yes	2200
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.66	132	87.12	17.9	7.30	15	Yes	2200
23	1.14	132	150.48	18.0	7.50	15	Yes	2200
24	1.15	132	151.80	17.7	7.40	15	Yes	2200
25	1.07	132	141.24	17.8	7.40	15	Yes	2200
26	0.91	132	120.12	17.9	7.40	15	Yes	2200
27	1.10	132	145.20	18.1	7.50	15	Yes	2200
28	0.00	0	0.00	0.0	0.00	0	Yes	0
29	0.72	132	95.04	17.8	7.60	18	Yes	2200
30	0.74	132	97.68	17.6	7.60	18	Yes	2200
31	1.10	132	145.20	17.5	7.40	18	Yes	2200

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012