

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: CLATSOP

23-Aug

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.052	0.062	0.052	0.051	0.055	0.051	0.062
2	0.052	0.053	0.054	0.051	0.056	0.048	0.056
3	0.046	0.048	0.000	0.046	0.055	0.054	0.055
4	0.052	0.056	0.000	0.052	0.056	0.052	0.056
5	0.055	0.052	0.000	0.000	0.000	0.000	0.055
6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7	0.000	0.000	0.000	0.052	0.054	0.048	0.054
8	0.050	0.052	0.052	0.050	0.056	0.048	0.056
9	0.046	0.050	0.054	0.059	0.069	0.054	0.069
10	0.057	0.064	0.000	0.068	0.054	0.051	0.068
11	0.051	0.054	0.000	0.055	0.050	0.049	0.055
12	0.054	0.056	0.065	0.000	0.000	0.000	0.065
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.057	0.050	0.054	0.057
15	0.054	0.063	0.070	0.072	0.052	0.060	0.072
16	0.068	0.066	0.085	0.066	0.053	0.052	0.085
17	0.063	0.064	0.071	0.081	0.068	0.061	0.081
18	0.062	0.000	0.000	0.083	0.062	0.056	0.083
19	0.065	0.076	0.060	0.074	0.000	0.000	0.076
20	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21	0.000	0.000	0.000	0.064	0.062	0.064	0.064
22	0.066	0.075	0.074	0.074	0.056	0.054	0.075
23	0.053	0.058	0.056	0.062	0.056	0.050	0.062
24	0.053	0.000	0.000	0.063	0.056	0.048	0.063
25	0.049	0.000	0.000	0.056	0.049	0.046	0.056
26	0.046	0.000	0.000	0.000	0.000	0.000	0.046
27	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28	0.000	0.000	0.054	0.058	0.048	0.044	0.058
29	0.048	0.050	0.060	0.064	0.050	0.046	0.064
30	0.046	0.049	0.052	0.053	0.048	0.046	0.053
31	0.000	0.000	0.000	0.046	0.050	0.046	0.050

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: Ronald Warner	DATE: 9/2/23
SIGNATURE: <i>Ronald Warner</i>	T-08898
PHONE #: ( 503 ) 738-5112	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

23-Aug

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.06	123	130.38	21.9	7.40	12	Yes	2300
2	1.09	115	125.35	19.9	7.50	15	Yes	2400
3	0.98	115	112.70	19.8	7.40	15	Yes	2400
4	0.89	123	109.47	19.9	7.50	15	Yes	2300
5	1.06	123	130.38	20.0	7.60	14	Yes	2300
6	0.00	0	0.00	0.0	0.00	0	Yes	0
7	0.43	115	49.45	19.9	7.50	14	Yes	2400
8	0.96	115	110.40	19.7	7.40	15	Yes	2400
9	1.06	115	121.90	19.9	7.40	15	Yes	2400
10	1.18	148	174.64	19.8	7.50	15	Yes	2000
11	1.08	123	132.84	19.9	7.50	15	Yes	2300
12	1.16	123	142.68	19.8	7.50	15	Yes	2300
13	0.00	0	0.00	0.0	0.00	0	Yes	0
14	0.60	115	69.00	19.8	7.50	14	Yes	2400
15	1.00	115	115.00	19.7	7.40	15	Yes	2400
16	1.00	115	115.00	19.8	7.50	15	Yes	2400
17	1.05	115	120.75	19.7	7.40	15	Yes	2400
18	0.87	115	100.05	19.8	7.40	15	Yes	2400
19	1.15	115	132.25	19.8	7.40	15	Yes	2400
20	0.00	0	0.00	0.0	0.00	0	Yes	0
21	0.78	115	89.70	19.8	7.40	15	Yes	2400
22	0.93	115	106.95	19.9	7.50	15	Yes	2400
23	1.06	115	121.90	19.8	7.60	19	Yes	2400
24	0.96	115	110.40	19.8	7.50	15	Yes	2400
25	0.89	115	102.35	19.8	7.40	15	Yes	2400
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.00	0	0.00	0.0	0.00	0	Yes	0
28	0.54	115	62.10	19.5	7.50	15	Yes	2400
29	1.09	115	125.35	19.8	7.50	15	Yes	2400
30	1.06	115	121.90	19.7	7.40	15	Yes	2400
31	0.84	115	96.60	19.9	7.50	15	Yes	2400

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012