

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

23-Nov

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.025	0.032	0.031	0.032
2	0.032	0.000	0.000	0.028	0.027	0.023	0.032
3	0.028	0.000	0.000	0.028	0.036	0.031	0.036
4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6	0.000	0.000	0.000	0.028	0.036	0.030	0.036
7	0.029	0.030	0.028	0.028	0.026	0.029	0.030
8	0.026	0.000	0.000	0.026	0.043	0.032	0.043
9	0.032	0.000	0.000	0.030	0.030	0.031	0.032
10	0.028	0.000	0.000	0.026	0.036	0.030	0.036
11	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13	0.000	0.000	0.000	0.030	0.036	0.030	0.036
14	0.030	0.030	0.028	0.029	0.026	0.026	0.030
15	0.027	0.026	0.000	0.026	0.044	0.030	0.044
16	0.030	0.000	0.000	0.028	0.028	0.027	0.030
17	0.000	0.000	0.000	0.026	0.032	0.029	0.032
18	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.031	0.034	0.028	0.034
21	0.028	0.027	0.026	0.026	0.026	0.025	0.028
22	0.060	0.000	0.000	0.024	0.034	0.028	0.060
23	0.028	0.028	0.026	0.026	0.026	0.025	0.028
24	0.026	0.000	0.000	0.024	0.030	0.027	0.030
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27	0.000	0.000	0.000	0.024	0.042	0.026	0.042
28	0.026	0.026	0.024	0.026	0.024	0.024	0.026
29	0.022	0.000	0.000	0.022	0.032	0.026	0.032
30	0.024	0.024	0.000	0.024	0.024	0.024	0.024
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration

95% of daily turbidity readings ≤ 0.3 NTU? Yes / No

All daily turbidity readings ≤ 1 NTU? Yes / No

All turbidity readings < IFE² triggers Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: Ronald Wannier

SIGNATURE: *Ronald Wannier*

PHONE #: (503) 738-5112

DATE: 12-1-23

T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

PAGE 1 of 2

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

23-Nov

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.89	148	131.72	12.3	7.40	22	Yes	2000
2	0.92	148	136.16	12.7	7.40	22	Yes	2000
3	0.88	148	130.24	12.8	7.40	22	Yes	2000
4	0.00	0	0.00	0.0	0.00	0	Yes	0
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	0.73	148	108.04	13.2	7.50	22	Yes	2000
7	0.97	148	143.56	13.2	7.40	22	Yes	2000
8	0.89	148	131.72	13.1	7.30	22	Yes	2000
9	0.86	148	127.28	12.9	7.40	22	Yes	2000
10	0.85	148	125.80	12.6	7.50	22	Yes	2000
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	0.74	148	109.52	12.4	7.50	22	Yes	2000
14	0.81	148	119.88	12.1	7.50	22	Yes	2000
15	0.88	148	130.24	12.0	7.50	22	Yes	2000
16	0.90	148	133.20	11.6	7.40	22	Yes	2000
17	0.87	148	128.76	11.4	7.50	22	Yes	2000
18	0.00	0	0.00	0.0	0.00	0	Yes	0
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	0.75	148	111.00	11.1	7.30	22	Yes	2000
21	1.05	148	155.40	10.9	7.50	23	Yes	2000
22	0.99	148	146.52	11.0	7.40	22	Yes	2000
23	0.89	148	131.72	10.7	7.50	22	Yes	2000
24	1.01	148	149.48	10.2	7.30	23	Yes	2000
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.91	148	134.68	9.3	7.50	42	Yes	2000
28	1.15	148	170.20	8.9	7.60	52	Yes	2000
29	1.06	148	156.88	8.6	7.50	43	Yes	2000
30	1.01	148	149.48	8.4	7.40	43	Yes	2000
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012