

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.038	0.028	0.025	0.038
2	0.024	0.000	0.000	0.024	0.028	0.025	0.028
3	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.000	0.023	0.028	0.024	0.028
6	0.024	0.022	0.024	0.022	0.022	0.022	0.024
7	0.000	0.000	0.000	0.022	0.027	0.024	0.027
8	0.023	0.000	0.000	0.022	0.022	0.022	0.023
9	0.000	0.000	0.000	0.022	0.029	0.024	0.029
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12	0.000	0.000	0.000	0.022	0.029	0.026	0.029
13	0.022	0.022	0.022	0.024	0.024	0.023	0.024
14	0.000	0.000	0.000	0.034	0.026	0.024	0.034
15	0.024	0.000	0.000	0.024	0.024	0.024	0.024
16	0.000	0.000	0.000	0.024	0.030	0.027	0.030
17	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19	0.000	0.000	0.000	0.025	0.030	0.028	0.030
20	0.026	0.025	0.026	0.028	0.028	0.026	0.028
21	0.026	0.000	0.000	0.026	0.034	0.028	0.034
22	0.028	0.026	0.000	0.027	0.026	0.028	0.028
23	0.026	0.000	0.000	0.020	0.032	0.030	0.032
24	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26	0.000	0.000	0.000	0.026	0.042	0.030	0.042
27	0.028	0.028	0.029	0.028	0.028	0.028	0.029
28	0.028	0.000	0.000	0.028	0.032	0.034	0.034
29	0.028	0.028	0.000	0.030	0.028	0.028	0.030
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: Ronald Wanner	DATE: 3/5/24
SIGNATURE: <i>Ronald Wanner</i>	T-08898
PHONE #: (503) 738-5112	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

24-Feb

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.09	132	143.88	11.2	7.50	23	Yes	2200
2	1.16	148	171.68	11.1	7.40	23	Yes	2000
3	0.00	0	0.00	0.0	0.00	0	Yes	0
4	0.00	0	0.00	0.0	0.00	0	Yes	0
5	0.91	148	134.68	12.2	7.50	22	Yes	2000
6	1.25	148	185.00	10.2	7.50	23	Yes	2000
7	1.14	148	168.72	10.2	7.40	23	Yes	2000
8	1.12	148	165.76	9.9	7.40	43	Yes	2000
9	1.09	148	161.32	10.0	7.50	23	Yes	2000
10	0.00	0	0.00	0.0	0.00	0	Yes	0
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	0.95	148	140.60	10.2	7.50	22	Yes	2000
13	1.12	148	165.76	9.8	7.50	43	Yes	2000
14	1.05	148	155.40	9.7	7.50	43	Yes	2000
15	1.09	148	161.32	9.3	7.50	43	Yes	2000
16	1.05	148	155.40	9.2	7.50	43	Yes	2000
17	0.00	0	0.00	0.0	0.00	0	Yes	0
18	0.00	0	0.00	0.0	0.00	0	Yes	0
19	0.96	148	142.08	8.8	7.50	42	Yes	2000
20	1.17	148	173.16	9.1	7.50	43	Yes	2000
21	1.07	148	158.36	9.3	7.40	43	Yes	2000
22	1.10	148	162.80	9.5	7.50	43	Yes	2000
23	1.07	148	158.36	9.6	7.40	43	Yes	2000
24	0.00	0	0.00	0.0	0.00	0	Yes	0
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.94	148	139.12	9.8	7.50	42	Yes	2000
27	1.06	148	156.88	9.4	7.50	43	Yes	2000
28	0.99	148	146.52	9.5	7.40	42	Yes	2000
29	1.02	148	150.96	9.4	7.50	43	Yes	2000
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012