

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

24-Mar

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.026	0.038	0.030	0.038
2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4	0.000	0.000	0.000	0.030	0.042	0.034	0.042
5	0.030	0.030	0.031	0.030	0.028	0.028	0.031
6	0.028	0.032	0.030	0.032	0.040	0.032	0.040
7	0.030	0.030	0.028	0.032	0.026	0.028	0.032
8	0.028	0.000	0.000	0.028	0.032	0.030	0.032
9	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11	0.000	0.000	0.000	0.030	0.074	0.032	0.074
12	0.030	0.030	0.000	0.028	0.030	0.028	0.030
13	0.028	0.000	0.000	0.026	0.034	0.030	0.034
14	0.032	0.000	0.000	0.026	0.026	0.000	0.032
15	0.000	0.000	0.000	0.026	0.034	0.028	0.034
16	0.026	0.026	0.026	0.000	0.000	0.000	0.026
17	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18	0.000	0.000	0.000	0.024	0.036	0.028	0.036
19	0.026	0.026	0.000	0.026	0.024	0.026	0.026
20	0.024	0.026	0.000	0.030	0.034	0.030	0.034
21	0.028	0.029	0.028	0.028	0.028	0.026	0.029
22	0.026	0.000	0.000	0.034	0.030	0.030	0.034
23	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.000	0.026	0.032	0.029	0.032
26	0.028	0.028	0.026	0.029	0.028	0.026	0.029
27	0.000	0.000	0.000	0.026	0.031	0.028	0.031
28	0.031	0.028	0.032	0.032	0.028	0.028	0.032
29	0.026	0.000	0.000	0.039	0.031	0.030	0.039
30	0.029	0.030	0.000	0.000	0.000	0.000	0.030
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: Ronald Warner
SIGNATURE: <i>Ronald Warner</i>
PHONE #: (503) 738-5112
DATE: 4/2/24
T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

24-Mar

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	148	148.00	9.1	7.50	42	Yes	2000
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	0.00	0	0.00	0.0	0.00	0	Yes	0
4	0.86	140	120.40	8.1	7.40	42	Yes	2100
5	1.13	140	158.20	7.7	7.30	43	Yes	2100
6	1.15	132	151.80	8.0	7.40	43	Yes	2200
7	1.17	132	154.44	7.9	7.30	43	Yes	2200
8	1.00	148	148.00	8.3	7.50	42	Yes	2000
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	0.00	0	0.00	0.0	0.00	0	Yes	0
11	0.92	132	121.44	8.8	7.40	42	Yes	2200
12	1.05	132	138.60	8.8	7.50	43	Yes	2200
13	1.02	132	134.64	9.0	7.50	43	Yes	2200
14	1.04	148	153.92	9.0	7.40	43	Yes	2000
15	1.00	148	148.00	9.5	7.60	51	Yes	2000
16	1.10	148	162.80	10.0	7.40	23	Yes	2000
17	0.00	0	0.00	0.0	0.00	0	Yes	0
18	0.93	140	130.20	10.6	7.50	22	Yes	2100
19	1.06	132	139.92	10.9	7.60	28	Yes	2200
20	1.07	132	141.24	11.0	7.40	23	Yes	2200
21	1.13	132	149.16	11.3	7.50	23	Yes	2200
22	1.09	140	152.60	11.4	7.40	23	Yes	2100
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.00	0	0.00	0.0	0.00	0	Yes	0
25	0.94	132	124.08	11.6	7.40	22	Yes	2200
26	1.10	132	145.20	11.6	7.20	23	Yes	2200
27	1.07	132	141.24	11.9	7.50	23	Yes	2200
28	1.10	132	145.20	11.8	7.40	23	Yes	2200
29	1.03	132	135.96	11.4	7.50	23	Yes	2200
30	1.14	132	150.48	11.6	7.50	23	Yes	2200
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012