

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

24-Apr

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.026	0.033	0.030	0.033
2	0.029	0.000	0.000	0.028	0.027	0.027	0.029
3	0.027	0.000	0.000	0.026	0.034	0.030	0.034
4	0.030	0.031	0.000	0.028	0.028	0.028	0.031
5	0.026	0.000	0.000	0.035	0.032	0.030	0.035
6	0.030	0.031	0.000	0.000	0.000	0.000	0.031
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.028	0.035	0.031	0.035
9	0.032	0.000	0.000	0.032	0.032	0.030	0.032
10	0.028	0.000	0.000	0.029	0.035	0.032	0.035
11	0.030	0.034	0.037	0.031	0.031	0.029	0.037
12	0.029	0.000	0.000	0.028	0.036	0.035	0.036
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.031	0.042	0.035	0.042
16	0.032	0.000	0.000	0.031	0.030	0.032	0.032
17	0.030	0.030	0.000	0.030	0.044	0.034	0.044
18	0.032	0.000	0.000	0.032	0.032	0.031	0.032
19	0.030	0.000	0.000	0.031	0.041	0.036	0.041
20	0.032	0.035	0.000	0.000	0.000	0.000	0.035
21	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22	0.000	0.000	0.000	0.030	0.034	0.032	0.034
23	0.030	0.000	0.000	0.030	0.034	0.030	0.034
24	0.030	0.000	0.000	0.028	0.037	0.032	0.037
25	0.030	0.032	0.000	0.030	0.030	0.030	0.032
26	0.044	0.028	0.000	0.028	0.034	0.032	0.044
27	0.030	0.032	0.000	0.000	0.000	0.000	0.032
28	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29	0.000	0.000	0.000	0.030	0.042	0.032	0.042
30	0.030	0.000	0.000	0.031	0.030	0.030	0.031
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		

Notes:

PRINTED NAME: Ronald Wanner
 SIGNATURE: *Ronald Wanner*
 PHONE #: (503) 738-5112
 DATE: 5/1/24
 T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))
PAGE 1 of 2

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

24-Apr

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.95	132	125.40	11.9	7.50	22	Yes	2200
2	1.05	132	138.60	12.1	7.40	23	Yes	2200
3	1.09	132	143.88	12.2	7.50	23	Yes	2200
4	0.97	148	143.56	12.4	7.50	22	Yes	2000
5	1.05	148	155.40	12.3	7.40	23	Yes	2000
6	1.21	148	179.08	12.4	7.40	23	Yes	2000
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.95	140	133.00	12.5	7.40	22	Yes	2100
9	1.09	140	152.60	12.7	7.30	23	Yes	2100
10	1.13	140	158.20	12.7	7.30	23	Yes	2100
11	1.07	148	158.36	12.8	7.40	23	Yes	2000
12	1.06	148	156.88	12.9	7.50	23	Yes	2000
13	0.00	0	0.00	0.0	0.00	0	Yes	0
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.90	140	126.00	13.1	7.40	22	Yes	2100
16	1.09	140	152.60	13.3	7.40	23	Yes	2100
17	1.05	140	147.00	13.3	7.71	22	Yes	2100
18	0.90	140	126.00	13.5	7.60	27	Yes	2100
19	0.98	148	145.04	13.7	7.60	27	Yes	2000
20	1.10	148	162.80	14.0	7.40	23	Yes	2000
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.88	140	123.20	13.6	7.30	22	Yes	2100
23	1.01	140	141.40	13.7	7.40	23	Yes	2100
24	1.00	140	140.00	13.9	7.50	22	Yes	2100
25	1.05	148	155.40	13.9	7.40	23	Yes	2000
26	1.02	148	150.96	13.7	7.40	23	Yes	2000
27	1.06	148	156.88	13.8	7.50	23	Yes	2000
28	0.00	0	0.00	0.0	0.00	0	Yes	0
29	0.83	140	116.20	13.5	7.20	23	Yes	2100
30	0.92	140	128.80	13.5	7.40	22	Yes	2100
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012