

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

24-May

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.028	0.000	0.000	0.028	0.035	0.032	0.035
2	0.030	0.033	0.029	0.028	0.029	0.028	0.033
3	0.026	0.000	0.000	0.026	0.034	0.030	0.034
4	0.031	0.029	0.000	0.000	0.000	0.000	0.031
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6	0.000	0.000	0.000	0.026	0.033	0.032	0.033
7	0.028	0.000	0.000	0.026	0.024	0.026	0.028
8	0.024	0.000	0.000	0.022	0.035	0.026	0.035
9	0.026	0.026	0.024	0.024	0.024	0.023	0.026
10	0.022	0.022	0.000	0.042	0.028	0.026	0.042
11	0.024	0.024	0.000	0.000	0.000	0.000	0.024
12	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13	0.000	0.000	0.000	0.024	0.034	0.027	0.034
14	0.026	0.025	0.000	0.024	0.023	0.022	0.026
15	0.023	0.022	0.022	0.037	0.029	0.026	0.037
16	0.026	0.024	0.000	0.026	0.024	0.024	0.026
17	0.023	0.000	0.000	0.023	0.030	0.026	0.030
18	0.026	0.026	0.000	0.000	0.000	0.000	0.026
19	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.026	0.034	0.032	0.034
21	0.031	0.000	0.000	0.034	0.032	0.032	0.034
22	0.029	0.032	0.030	0.034	0.036	0.033	0.036
23	0.034	0.032	0.032	0.031	0.040	0.036	0.040
24	0.034	0.034	0.000	0.034	0.038	0.034	0.038
25	0.032	0.032	0.000	0.000	0.000	0.000	0.032
26	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27	0.000	0.000	0.000	0.034	0.042	0.036	0.042
28	0.034	0.034	0.034	0.032	0.040	0.036	0.040
29	0.036	0.034	0.036	0.036	0.037	0.040	0.040
30	0.039	0.040	0.000	0.034	0.041	0.037	0.041
31	0.036	0.037	0.000	0.034	0.040	0.035	0.040

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:		PRINTED NAME: <u>Ronald Warner</u>	
		SIGNATURE: <u>Ronald Warner</u>	DATE: <u>6/3/2024</u>
		PHONE #: (503) 738-5112	T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))
PAGE 1 of 2

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

24-May

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.98	140	137.20	13.5	7.40	22	Yes	2100
2	1.10	140	154.00	13.4	7.50	22	Yes	2100
3	1.01	148	149.48	13.6	7.60	23	Yes	2000
4	1.06	148	156.88	13.6	7.50	23	Yes	2000
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	0.99	140	138.60	13.2	7.40	22	Yes	2100
7	1.06	140	148.40	13.2	7.50	23	Yes	2100
8	1.10	140	154.00	13.3	7.30	23	Yes	2100
9	1.10	148	162.80	13.7	7.50	23	Yes	2100
10	1.06	148	156.88	14.1	7.50	23	Yes	2000
11	1.09	148	161.32	14.6	7.40	23	Yes	2000
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	0.83	140	116.20	14.8	7.40	22	Yes	2100
14	1.06	140	148.40	15.0	7.40	15	Yes	2100
15	1.01	148	149.48	15.2	7.40	15	Yes	2000
16	1.00	148	148.00	15.2	7.50	15	Yes	2000
17	1.03	148	152.44	15.5	7.30	15	Yes	2000
18	1.17	148	173.16	16.3	7.50	15	Yes	2000
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	0.92	140	128.80	16.3	7.30	15	Yes	2100
21	1.08	140	151.20	16.4	7.40	15	Yes	2100
22	1.09	140	152.60	16.1	7.50	15	Yes	2100
23	1.17	140	163.80	15.9	7.50	15	Yes	2100
24	1.12	148	165.76	16.0	7.50	15	Yes	2000
25	1.14	148	168.72	15.9	7.70	15	Yes	2000
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.89	148	131.72	15.7	7.70	18	Yes	2000
28	1.15	148	170.20	15.7	7.60	19	Yes	2000
29	1.15	148	170.20	15.8	7.40	15	Yes	2000
30	1.12	148	165.76	15.8	7.30	15	Yes	2000
31	1.07	148	158.36	16.0	7.50	15	Yes	2000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012