

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

24-Jun

System Name: SEASIDE ID#: 4100799 WTP - : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3	0.000	0.000	0.000	0.038	0.045	0.042	0.045
4	0.036	0.034	0.000	0.032	0.033	0.032	0.036
5	0.037	0.000	0.000	0.042	0.034	0.032	0.042
6	0.031	0.031	0.000	0.034	0.032	0.030	0.034
7	0.030	0.029	0.028	0.038	0.032	0.030	0.038
8	0.031	0.030	0.000	0.000	0.000	0.000	0.031
9	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.030	0.034	0.030	0.034
11	0.030	0.030	0.000	0.032	0.034	0.030	0.034
12	0.064	0.036	0.055	0.030	0.034	0.034	0.064
13	0.034	0.034	0.000	0.033	0.034	0.056	0.056
14	0.000	0.000	0.000	0.043	0.068	0.048	0.068
15	0.044	0.048	0.000	0.000	0.000	0.000	0.048
16	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17	0.000	0.000	0.000	0.039	0.032	0.028	0.039
18	0.028	0.028	0.030	0.028	0.032	0.028	0.032
19	0.029	0.030	0.028	0.026	0.032	0.031	0.032
20	0.028	0.000	0.000	0.028	0.028	0.026	0.028
21	0.030	0.000	0.000	0.032	0.030	0.030	0.032
22	0.026	0.030	0.030	0.000	0.000	0.000	0.030
23	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24	0.000	0.000	0.000	0.026	0.036	0.032	0.036
25	0.030	0.032	0.000	0.030	0.040	0.037	0.040
26	0.038	0.036	0.000	0.032	0.042	0.038	0.042
27	0.036	0.038	0.000	0.032	0.047	0.038	0.047
28	0.038	0.038	0.000	0.036	0.042	0.041	0.042
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration

95% of daily turbidity readings ≤ 0.3 NTU? Yes / No

All daily turbidity readings ≤ 1 NTU? Yes / No

All turbidity readings < IFE² triggers Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: Ronald Wanner

SIGNATURE: *Ronald Wanner* DATE: 7/1/24

PHONE #: (503) 738-5112 T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

24-Jun

System Name: Seaside ID#: 4100799 WTP -: A Disinfection Giardia Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	0.91	140	127.40	16.1	7.70	18	Yes	2100
4	1.08	140	151.20	15.8	7.60	18	Yes	2100
5	1.04	140	145.60	15.5	7.30	15	Yes	2100
6	0.99	140	138.60	15.7	7.60	15	Yes	2100
7	0.90	148	133.20	16.0	7.40	15	Yes	2000
8	1.08	148	159.84	16.3	7.50	15	Yes	2000
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	0.77	140	107.80	16.1	7.30	15	Yes	2100
11	1.03	140	144.20	16.4	7.30	15	Yes	2100
12	0.96	140	134.40	16.7	7.40	0	Yes	2100
13	1.14	140	159.60	16.8	7.35	15	Yes	2000
14	0.86	140	120.40	16.7	7.50	15	Yes	2100
15	1.17	140	163.80	16.6	7.50	15	Yes	2100
16	0.00	0	0.00	0.0	0.00	0	Yes	0
17	0.91	132	120.12	16.7	7.80	18	Yes	2200
18	1.17	123	143.91	16.9	7.40	15	Yes	2300
19	1.16	123	142.68	17.0	7.50	15	Yes	2300
20	1.11	123	136.53	17.2	7.50	15	Yes	2300
21	1.01	123	124.23	17.3	7.50	15	Yes	2300
22	1.15	123	141.45	17.4	7.40	15	Yes	2300
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.75	123	92.25	17.6	7.30	15	Yes	2300
25	1.01	123	124.23	17.9	7.50	15	Yes	2300
26	1.05	123	129.15	18.1	7.50	15	Yes	2300
27	0.97	123	119.31	10.3	7.50	15	Yes	2300
28	1.02	123	125.46	18.5	7.50	15	Yes	2300
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012