

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

24-Jul

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.034	0.043	0.039	0.043
2	0.039	0.036	0.034	0.033	0.041	0.037	0.041
3	0.040	0.032	0.043	0.038	0.036	0.036	0.043
4	0.036	0.035	0.000	0.046	0.066	0.046	0.066
5	0.066	0.054	0.000	0.036	0.044	0.044	0.066
6	0.039	0.036	0.036	0.000	0.000	0.000	0.039
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.054	0.042	0.039	0.054
9	0.040	0.038	0.040	0.040	0.046	0.043	0.046
10	0.040	0.036	0.038	0.046	0.056	0.040	0.056
11	0.038	0.036	0.035	0.050	0.049	0.036	0.050
12	0.038	0.034	0.036	0.040	0.035	0.036	0.040
13	0.039	0.033	0.000	0.000	0.000	0.000	0.039
14	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.035	0.036	0.038	0.038
16	0.040	0.040	0.041	0.040	0.050	0.038	0.050
17	0.036	0.036	0.038	0.032	0.036	0.034	0.038
18	0.033	0.033	0.032	0.030	0.036	0.031	0.036
19	0.030	0.030	0.000	0.028	0.033	0.030	0.033
20	0.030	0.028	0.000	0.000	0.000	0.000	0.030
21	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22	0.000	0.000	0.000	0.025	0.031	0.027	0.031
23	0.028	0.027	0.026	0.026	0.030	0.030	0.030
24	0.028	0.028	0.026	0.026	0.033	0.028	0.033
25	0.027	0.027	0.000	0.026	0.030	0.028	0.030
26	0.028	0.030	0.030	0.027	0.033	0.031	0.033
27	0.030	0.032	0.000	0.000	0.000	0.000	0.032
28	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29	0.000	0.000	0.000	0.033	0.036	0.030	0.036
30	0.029	0.026	0.036	0.030	0.035	0.031	0.036
31	0.030	0.030	0.000	0.031	0.034	0.030	0.034

Conventional or Direct Filtration

95% of daily turbidity readings \leq 0.3 NTU? Yes / No
 All daily turbidity readings \leq 1 NTU? Yes / No
 All turbidity readings $<$ IFE² triggers Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No
 All Cl2 residual at entry point \geq 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: Ronald Wanner
 SIGNATURE: *Ronald Wanner* DATE: 8/1/24
 PHONE #: (503) 738-5112 T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-081-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

24-Jul

System Name: Seaside ID#: 4100799 WTP -: A Disinfection Giardia Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.71	123	87.33	18.7	7.50	15	Yes	2300
2	1.17	123	143.91	18.9	7.40	15	Yes	2300
3	1.03	123	126.69	18.9	7.60	18	Yes	2300
4	0.99	123	121.77	19.3	7.40	15	Yes	2300
5	0.96	123	118.08	19.2	7.50	15	Yes	2300
6	1.13	123	138.99	19.6	7.50	15	Yes	2300
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.61	123	75.03	19.7	7.30	15	Yes	2300
9	1.10	123	135.30	20.0	7.50	12	Yes	2300
10	1.11	123	136.53	20.3	7.50	12	Yes	2300
11	1.06	123	130.38	20.5	7.50	12	Yes	2300
12	1.09	123	134.07	20.8	7.50	12	Yes	2300
13	1.05	123	129.15	20.8	7.50	12	Yes	2300
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.42	123	51.66	20.5	7.30	12	Yes	2300
16	0.98	123	120.54	20.7	7.50	12	Yes	2300
17	0.95	123	116.85	20.9	7.40	11	Yes	2300
18	0.97	123	119.31	20.7	7.50	11	Yes	2300
19	0.91	123	111.93	20.9	7.50	11	Yes	2300
20	1.09	123	134.07	21.2	7.50	12	Yes	2300
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.84	115	96.60	21.0	7.30	11	Yes	2400
23	1.12	115	128.80	21.2	7.40	12	Yes	2400
24	1.10	115	126.50	21.2	7.40	12	Yes	2400
25	0.98	115	112.70	20.9	7.50	11	Yes	2400
26	1.10	115	126.50	21.1	7.50	12	Yes	2400
27	1.06	123	130.38	21.1	7.50	12	Yes	2300
28	0.00	0	0.00	0.0	0.00	0	Yes	0
29	0.67	115	77.05	21.0	7.30	11	Yes	2400
30	1.04	115	119.60	20.6	7.50	12	Yes	2400
31	1.04	115	119.60	20.8	7.40	12	Yes	2400

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012