

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

24-Aug

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.031	0.029	0.030	0.030	0.034	0.030	0.034
2	0.030	0.000	0.000	0.032	0.036	0.032	0.036
3	0.030	0.032	0.030	0.000	0.000	0.000	0.032
4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.000	0.028	0.034	0.032	0.034
6	0.031	0.030	0.032	0.036	0.040	0.036	0.040
7	0.034	0.038	0.038	0.040	0.046	0.042	0.046
8	0.040	0.038	0.036	0.030	0.029	0.026	0.040
9	0.030	0.034	0.026	0.060	0.040	0.038	0.060
10	0.038	0.037	0.000	0.000	0.000	0.000	0.038
11	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12	0.000	0.000	0.036	0.045	0.038	0.037	0.045
13	0.036	0.036	0.040	0.038	0.042	0.038	0.042
14	0.040	0.042	0.000	0.040	0.046	0.040	0.046
15	0.038	0.042	0.000	0.042	0.044	0.042	0.044
16	0.042	0.000	0.000	0.040	0.048	0.042	0.048
17	0.046	0.042	0.000	0.000	0.000	0.000	0.046
18	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19	0.000	0.000	0.000	0.038	0.044	0.042	0.044
20	0.039	0.040	0.042	0.044	0.047	0.042	0.047
21	0.000	0.000	0.000	0.042	0.040	0.040	0.042
22	0.037	0.040	0.000	0.040	0.042	0.040	0.042
23	0.042	0.000	0.000	0.040	0.048	0.040	0.048
24	0.040	0.040	0.000	0.000	0.000	0.000	0.040
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26	0.000	0.000	0.000	0.038	0.046	0.041	0.046
27	0.041	0.041	0.040	0.039	0.048	0.043	0.048
28	0.043	0.000	0.000	0.033	0.040	0.038	0.043
29	0.036	0.000	0.000	0.030	0.040	0.038	0.040
30	0.036	0.038	0.000	0.033	0.040	0.036	0.040
31	0.035	0.036	0.000	0.000	0.000	0.000	0.036

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		

Notes:	PRINTED NAME: <u>Ronald Wanner</u>
	SIGNATURE: <u>[Signature]</u> DATE: <u>9/3/24</u>
	PHONE #: (503) 738-5112 T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

24-Aug

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.01	115	116.15	21.0	7.40	12	Yes	2400
2	0.96	115	110.40	21.2	7.60	14	Yes	2400
3	1.10	115	126.50	21.2	7.50	12	Yes	2400
4	0.00	0	0.00	0.0	0.00	0	Yes	0
5	0.48	115	55.20	21.2	7.40	11	Yes	2400
6	1.05	115	120.75	21.6	7.50	12	Yes	2400
7	1.02	115	117.30	21.9	7.50	12	Yes	2400
8	1.01	115	116.15	21.8	7.50	12	Yes	2400
9	0.99	115	113.85	21.6	7.40	11	Yes	2400
10	1.02	115	117.30	21.6	7.40	12	Yes	2400
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	0.26	115	29.90	21.3	7.30	11	Yes	2400
13	0.92	115	105.80	21.2	7.40	11	Yes	2400
14	0.95	115	109.25	21.3	7.30	11	Yes	2400
15	0.87	115	100.05	21.3	7.50	11	Yes	2400
16	0.97	115	111.55	21.4	7.40	11	Yes	2400
17	1.05	115	120.75	21.3	7.40	12	Yes	2400
18	0.00	0	0.00	0.0	0.00	0	Yes	0
19	0.67	115	77.05	20.6	7.40	11	Yes	2400
20	1.16	115	133.40	20.5	7.49	11	Yes	2400
21	0.97	115	111.55	20.4	7.50	11	Yes	2400
22	1.09	115	125.35	2.0	7.40	12	Yes	2400
23	1.05	115	120.75	20.1	7.50	12	Yes	2400
24	1.16	115	133.40	20.0	7.50	12	Yes	2400
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.60	115	69.00	19.6	7.50	15	Yes	2400
27	0.99	115	113.85	20.1	7.50	11	Yes	2400
28	0.90	115	103.50	19.8	7.40	15	Yes	2400
29	0.92	115	105.80	19.9	7.50	15	Yes	2400
30	0.99	123	121.77	20.2	7.50	11	Yes	2300
31	1.03	123	126.69	20.2	7.40	12	Yes	2300

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012