

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

24-Sep

System Name: SEASIDE ID#: 4100799 WTP -: A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.028	0.035	0.035	0.035
3	0.034	0.034	0.035	0.034	0.037	0.040	0.040
4	0.034	0.000	0.000	0.032	0.038	0.036	0.038
5	0.034	0.034	0.000	0.031	0.044	0.044	0.044
6	0.043	0.046	0.044	0.042	0.046	0.044	0.046
7	0.042	0.040	0.000	0.000	0.000	0.000	0.042
8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9	0.000	0.000	0.000	0.036	0.041	0.037	0.041
10	0.038	0.036	0.038	0.033	0.039	0.036	0.039
11	0.036	0.000	0.000	0.034	0.040	0.036	0.040
12	0.036	0.000	0.000	0.030	0.037	0.036	0.037
13	0.036	0.036	0.000	0.032	0.036	0.034	0.036
14	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16	0.000	0.000	0.000	0.026	0.034	0.030	0.034
17	0.030	0.030	0.000	0.027	0.033	0.031	0.033
18	0.032	0.000	0.000	0.032	0.032	0.032	0.032
19	0.031	0.000	0.000	0.026	0.031	0.029	0.031
20	0.029	0.029	0.029	0.026	0.032	0.032	0.032
21	0.032	0.033	0.000	0.000	0.000	0.000	0.033
22	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23	0.000	0.000	0.000	0.032	0.036	0.033	0.036
24	0.030	0.031	0.032	0.030	0.044	0.034	0.044
25	0.031	0.000	0.000	0.030	0.033	0.030	0.033
26	0.031	0.000	0.000	0.029	0.032	0.030	0.032
27	0.030	0.032	0.030	0.031	0.036	0.032	0.036
28	0.037	0.031	0.000	0.000	0.000	0.000	0.037
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.034	0.038	0.034	0.038
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration

95% of daily turbidity readings ≤ 0.3 NTU? Yes / No

All daily turbidity readings ≤ 1 NTU? Yes / No

All turbidity readings < IFE² triggers Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: Ronald Wanner

SIGNATURE: Ronald Wanner DATE: 10/1/24

PHONE #: (503) 738-5112 T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

24-Sep

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.59	115	67.85	20.1	7.50	11	Yes	2400
3	1.01	115	116.15	20.1	7.50	12	Yes	2400
4	0.95	123	116.85	20.2	7.50	11	Yes	2300
5	1.06	123	130.38	20.6	7.50	12	Yes	2300
6	0.96	123	118.08	20.7	7.40	11	Yes	2300
7	1.05	123	129.15	20.8	7.50	12	Yes	2300
8	0.00	0	0.00	0.0	0.00	0	Yes	0
9	0.30	123	36.90	20.4	7.50	11	Yes	2300
10	1.11	123	136.53	20.7	7.40	12	Yes	2300
11	0.89	123	109.47	20.6	7.50	11	Yes	2300
12	0.92	123	113.16	20.5	7.50	11	Yes	2300
13	0.96	123	118.08	20.0	7.50	11	Yes	2300
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.00	0	0.00	0.0	0.00	0	Yes	0
16	0.61	123	75.03	19.5	7.40	15	Yes	2300
17	1.07	123	131.61	19.6	7.40	15	Yes	2300
18	1.04	123	127.92	19.3	7.50	15	Yes	2300
19	1.00	123	123.00	19.3	7.50	15	Yes	2300
20	1.13	123	138.99	19.3	7.50	15	Yes	2300
21	1.01	214	216.14	19.3	7.40	15	Yes	1200
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	0.75	123	92.25	19.1	7.40	15	Yes	2300
24	1.05	123	129.15	19.2	7.40	15	Yes	2300
25	0.96	123	118.08	19.3	7.50	15	Yes	2300
26	1.03	123	126.69	18.8	7.40	15	Yes	2300
27	1.09	123	134.07	18.8	7.50	15	Yes	2300
28	0.94	214	201.16	18.8	7.40	15	Yes	1200
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.67	123	82.41	17.9	7.40	15	Yes	2300
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012