

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: CLATSOP

24-Oct

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.034	0.035	0.000	0.033	0.034	0.032	0.035
2	0.033	0.000	0.000	0.037	0.034	0.034	0.037
3	0.034	0.034	0.035	0.032	0.038	0.034	0.038
4	0.033	0.036	0.032	0.036	0.045	0.044	0.045
5	0.044	0.042	0.000	0.000	0.000	0.000	0.044
6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7	0.000	0.000	0.000	0.033	0.036	0.032	0.036
8	0.034	0.034	0.000	0.033	0.032	0.033	0.034
9	0.030	0.000	0.000	0.038	0.034	0.034	0.038
10	0.040	0.035	0.034	0.032	0.037	0.038	0.040
11	0.032	0.000	0.000	0.035	0.042	0.034	0.042
12	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.026	0.032	0.030	0.032
15	0.030	0.000	0.000	0.028	0.026	0.026	0.030
16	0.026	0.000	0.000	0.034	0.034	0.033	0.034
17	0.032	0.032	0.000	0.028	0.034	0.034	0.034
18	0.037	0.032	0.000	0.032	0.036	0.035	0.037
19	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21	0.000	0.000	0.000	0.031	0.038	0.034	0.038
22	0.034	0.034	0.000	0.034	0.032	0.032	0.034
23	0.031	0.028	0.000	0.036	0.032	0.033	0.036
24	0.039	0.032	0.030	0.029	0.036	0.033	0.039
25	0.033	0.000	0.000	0.030	0.037	0.033	0.037
26	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28	0.000	0.000	0.000	0.030	0.042	0.036	0.042
29	0.033	0.031	0.000	0.030	0.044	0.037	0.044
30	0.036	0.000	0.000	0.034	0.035	0.035	0.036
31	0.034	0.031	0.000	0.041	0.034	0.033	0.041

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		

Notes:

PRINTED NAME: Ronald Wanner
SIGNATURE: <i>Ronald Wanner</i>
DATE: 11-1-21
PHONE #: ( 503 ) 738-5112
T-08898

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

24-Oct

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.00	148	148.00	17.7	7.40	15	Yes	2000
2	1.10	148	162.80	17.5	7.50	15	Yes	2000
3	1.09	148	161.32	17.4	7.50	15	Yes	2000
4	1.07	148	158.36	17.0	7.40	15	Yes	2000
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	0.63	148	93.24	16.6	7.50	15	Yes	2000
7	1.01	39	39.39	16.7	7.50	15	Yes	2000
8	1.00	148	148.00	16.6	7.50	15	Yes	2000
9	1.00	148	148.00	16.4	7.50	15	Yes	2000
10	0.98	148	145.04	16.1	7.50	15	Yes	2000
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	0.62	148	91.76	16.1	7.50	15	Yes	2000
14	0.93	148	137.64	16.1	7.50	15	Yes	2000
15	0.93	132	122.76	16.2	7.40	15	Yes	2200
16	1.01	132	133.32	15.9	7.50	15	Yes	2200
17	1.02	132	134.64	15.6	7.40	15	Yes	2200
18	0.00	0	0.00	0.0	0.00	0	Yes	0
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	0.68	132	89.76	15.4	7.40	15	Yes	2200
21	1.00	148	148.00	15.1	7.40	15	Yes	2000
22	0.93	148	137.64	14.7	7.40	22	Yes	2000
23	0.94	148	139.12	14.4	7.50	22	Yes	2000
24	0.92	148	136.16	14.1	7.40	22	Yes	2000
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.64	148	94.72	14.1	7.50	2	Yes	2000
28	1.19	148	176.12	13.1	7.40	23	Yes	2000
29	1.05	148	155.40	13.6	7.50	23	Yes	2000
30	1.07	148	158.36	13.1	7.50	23	Yes	2000
31	0.00	0	0.00	0.0	0.00	0	Yes	0

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012