

OHA - Drinking Water Program - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

24-Nov

System Name: SEASIDE ID#: 4100799 WTP - : A

| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day 1 [NTU] |
|-----|-------------|------------|------------|------------|------------|------------|------------------------------------|
| 1 | 0.033 | 0.032 | 0.000 | 0.031 | 0.035 | 0.033 | 0.035 |
| 2 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 3 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 4 | 0.000 | 0.000 | 0.000 | 0.032 | 0.041 | 0.033 | 0.041 |
| 5 | 0.033 | 0.033 | 0.000 | 0.032 | 0.032 | 0.030 | 0.033 |
| 6 | 0.000 | 0.000 | 0.000 | 0.042 | 0.034 | 0.032 | 0.042 |
| 7 | 0.032 | 0.030 | 0.000 | 0.028 | 0.036 | 0.031 | 0.036 |
| 8 | 0.028 | 0.028 | 0.000 | 0.031 | 0.034 | 0.032 | 0.034 |
| 9 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 10 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 11 | 0.000 | 0.000 | 0.000 | 0.028 | 0.026 | 0.031 | 0.031 |
| 12 | 0.030 | 0.030 | 0.000 | 0.028 | 0.028 | 0.028 | 0.030 |
| 13 | 0.000 | 0.000 | 0.000 | 0.026 | 0.039 | 0.032 | 0.039 |
| 14 | 0.030 | 0.030 | 0.000 | 0.029 | 0.028 | 0.028 | 0.030 |
| 15 | 0.028 | 0.000 | 0.000 | 0.040 | 0.032 | 0.030 | 0.040 |
| 16 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 17 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 18 | 0.000 | 0.000 | 0.000 | 0.028 | 0.046 | 0.034 | 0.046 |
| 19 | 0.032 | 0.000 | 0.000 | 0.030 | 0.030 | 0.030 | 0.032 |
| 20 | 0.028 | 0.000 | 0.000 | 0.028 | 0.037 | 0.033 | 0.037 |
| 21 | 0.030 | 0.000 | 0.000 | 0.030 | 0.028 | 0.028 | 0.030 |
| 22 | 0.028 | 0.000 | 0.000 | 0.029 | 0.036 | 0.032 | 0.036 |
| 23 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 24 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 25 | 0.000 | 0.000 | 0.000 | 0.028 | 0.037 | 0.030 | 0.037 |
| 26 | 0.030 | 0.028 | 0.000 | 0.027 | 0.026 | 0.029 | 0.030 |
| 27 | 0.026 | 0.000 | 0.000 | 0.026 | 0.032 | 0.029 | 0.032 |
| 28 | 0.028 | 0.027 | 0.026 | 0.026 | 0.026 | 0.026 | 0.028 |
| 29 | 0.026 | 0.000 | 0.025 | 0.036 | 0.030 | 0.026 | 0.036 |
| 30 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |
| 31 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 |

Conventional or Direct Filtration

95% of daily turbidity readings ≤ 0.3 NTU? Yes / No

All daily turbidity readings ≤ 1 NTU? Yes / No

All turbidity readings < IFE² triggers Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: Ronald Wanner

SIGNATURE: *Ronald Wanner*

PHONE #: (503) 738-5112

DATE: 12/2/24

T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

24-

System Name:

Seaside

ID#: 4100799

WTP -: A

Disinfection
Giardia Log
Inactiv:

0.5

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hour Demand Flow |
|-------------|---|------------------|-----------|-------|------|-------------|----------------------|-----------------------|
| | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | 1.07 | 148 | 158.36 | 13.1 | 7.40 | 23 | Yes | 2000 |
| 2 | 0.00 | 0 | 0.00 | 0.0 | 0.00 | 0 | Yes | 0 |
| 3 | 0.00 | 0 | 0.00 | 0.0 | 0.00 | 0 | Yes | 0 |
| 4 | 0.79 | 148 | 116.92 | 13.0 | 7.40 | 22 | Yes | 2000 |
| 5 | 1.03 | 148 | 152.44 | 13.0 | 7.50 | 23 | Yes | 2000 |
| 6 | 0.96 | 148 | 142.08 | 12.7 | 7.40 | 22 | Yes | 2000 |
| 7 | 1.00 | 148 | 148.00 | 12.5 | 7.40 | 22 | Yes | 2000 |
| 8 | 1.02 | 148 | 150.96 | 12.4 | 7.40 | 23 | Yes | 2000 |
| 9 | 0.00 | 0 | 0.00 | 0.0 | 0.00 | 0 | Yes | 0 |
| 10 | 0.00 | 0 | 0.00 | 0.0 | 0.00 | 0 | Yes | 0 |
| 11 | 0.81 | 148 | 119.88 | 12.3 | 7.50 | 22 | Yes | 2000 |
| 12 | 0.97 | 148 | 143.56 | 12.2 | 7.30 | 22 | Yes | 2000 |
| 13 | 0.97 | 148 | 143.56 | 12.3 | 7.60 | 27 | Yes | 2000 |
| 14 | 0.99 | 148 | 146.52 | 12.2 | 7.50 | 22 | Yes | 2000 |
| 15 | 0.93 | 148 | 137.64 | 11.8 | 7.30 | 22 | Yes | 2000 |
| 16 | 0.00 | 0 | 0.00 | 0.0 | 0.00 | 0 | Yes | 0 |
| 17 | 0.00 | 0 | 0.00 | 0.0 | 0.00 | 0 | Yes | 0 |
| 18 | 0.77 | 148 | 113.96 | 11.2 | 7.40 | 22 | Yes | 2000 |
| 19 | 0.97 | 148 | 143.56 | 10.5 | 7.40 | 22 | Yes | 2000 |
| 20 | 0.97 | 148 | 143.56 | 10.5 | 7.50 | 22 | Yes | 2000 |
| 21 | 1.00 | 148 | 148.00 | 10.5 | 7.40 | 22 | Yes | 2000 |
| 22 | 1.04 | 148 | 153.92 | 10.5 | 7.40 | 22 | Yes | 2000 |
| 23 | 0.00 | 0 | 0.00 | 0.0 | 0.00 | 0 | Yes | 0 |
| 24 | 0.00 | 0 | 0.00 | 0.0 | 0.00 | 0 | Yes | 0 |
| 25 | 0.90 | 148 | 133.20 | 10.4 | 7.40 | 22 | Yes | 2000 |
| 26 | 1.05 | 148 | 155.40 | 10.1 | 7.40 | 23 | Yes | 2000 |
| 27 | 1.03 | 148 | 152.44 | 10.3 | 7.60 | 28 | Yes | 2000 |
| 28 | 1.13 | 148 | 167.24 | 9.9 | 7.50 | 43 | Yes | 2000 |
| 29 | 1.09 | 148 | 161.32 | 9.6 | 7.40 | 43 | Yes | 2000 |
| 30 | 0.00 | 0 | 0.00 | 0.0 | 0.00 | 0 | Yes | 0 |
| 31 | 0.00 | 0 | 0.00 | 0.0 | 0.00 | 0 | Yes | 0 |

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.