

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

24-Dec

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.027	0.041	0.029	0.041
3	0.026	0.028	0.000	0.026	0.024	0.024	0.028
4	0.024	0.000	0.000	0.024	0.036	0.028	0.036
5	0.026	0.000	0.000	0.025	0.024	0.024	0.026
6	0.024	0.000	0.000	0.024	0.044	0.028	0.044
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9	0.000	0.000	0.000	0.026	0.036	0.026	0.036
10	0.026	0.000	0.000	0.026	0.025	0.025	0.026
11	0.024	0.000	0.000	0.024	0.037	0.030	0.037
12	0.026	0.000	0.000	0.025	0.026	0.025	0.026
13	0.026	0.024	0.000	0.024	0.032	0.030	0.032
14	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16	0.000	0.028	0.025	0.026	0.036	0.032	0.036
17	0.028	0.028	0.028	0.026	0.026	0.026	0.028
18	0.026	0.037	0.035	0.044	0.040	0.030	0.044
19	0.028	0.028	0.028	0.030	0.041	0.033	0.041
20	0.030	0.030	0.000	0.030	0.042	0.035	0.042
21	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23	0.000	0.000	0.000	0.030	0.044	0.034	0.044
24	0.032	0.000	0.000	0.030	0.030	0.030	0.032
25	0.028	0.000	0.029	0.034	0.035	0.035	0.035
26	0.000	0.000	0.034	0.032	0.030	0.030	0.034
27	0.000	0.000	0.000	0.039	0.048	0.034	0.048
28	0.032	0.032	0.032	0.000	0.000	0.000	0.032
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.030	0.041	0.034	0.041
31	0.032	0.031	0.032	0.032	0.034	0.036	0.036

Conventional or Direct Filtration 95% of daily turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes: _____ _____		PRINTED NAME: Ronald Wanner SIGNATURE: <i>Ronald Wanner</i> DATE: 1/11/25 PHONE #: (503) 738-5112 T-08898	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

24-

System Name:

Seaside

ID#: 4100799

WTP -: A

Disinfection
Giardia Log
Inactiv:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hour Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.95	148	140.60	8.7	7.30	42	Yes	2000
3	1.03	148	152.44	8.5	7.40	43	Yes	2000
4	1.10	148	162.80	8.3	7.50	43	Yes	2000
5	1.10	148	162.80	8.3	7.50	43	Yes	2000
6	1.00	148	148.00	8.3	7.60	43	Yes	2000
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.00	0	0.00	0.0	0.00	0	Yes	0
9	0.94	148	139.12	9.0	7.60	51	Yes	2000
10	1.06	148	156.88	8.7	7.40	43	Yes	2000
11	1.06	148	156.88	8.7	7.50	43	Yes	2000
12	1.08	148	159.84	8.8	7.50	43	Yes	2000
13	1.09	148	161.32	8.8	7.40	43	Yes	2000
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.00	0	0.00	0.0	0.00	0	Yes	0
16	0.94	148	139.12	9.0	7.30	42	Yes	2000
17	1.12	148	165.76	9.2	7.30	43	Yes	2000
18	1.03	148	152.44	9.8	7.30	43	Yes	2000
19	1.05	148	155.40	10.1	7.50	23	Yes	2000
20	1.01	148	149.48	10.2	7.50	22	Yes	2000
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	1.03	148	152.44	10.7	7.50	23	Yes	2000
24	1.22	148	180.56	10.7	7.50	23	Yes	2000
25	1.20	148	177.60	10.6	7.50	23	Yes	2000
26	1.15	132	151.80	10.6	7.50	23	Yes	2200
27	1.20	132	158.40	10.6	7.50	23	Yes	2200
28	1.27	132	167.64	10.6	7.50	23	Yes	2200
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	1.04	148	153.92	10.6	7.50	23	Yes	2000
31	1.15	148	170.20	10.6	7.40	23	Yes	2000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.