

**OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration**

County: CLATSOP

25-Feb

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3	0.000	0.000	0.000	0.030	0.049	0.039	0.049
4	0.038	0.037	0.037	0.034	0.033	0.032	0.038
5	0.030	0.000	0.000	0.030	0.047	0.039	0.047
6	0.037	0.036	0.034	0.033	0.033	0.033	0.037
7	0.031	0.030	0.000	0.030	0.046	0.036	0.046
8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.032	0.046	0.036	0.046
11	0.034	0.034	0.034	0.032	0.034	0.031	0.034
12	0.030	0.028	0.000	0.033	0.040	0.036	0.040
13	0.034	0.034	0.032	0.032	0.030	0.030	0.034
14	0.034	0.028	0.000	0.028	0.040	0.036	0.040
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17	0.000	0.000	0.000	0.030	0.050	0.036	0.050
18	0.036	0.037	0.032	0.030	0.031	0.030	0.037
19	0.030	0.026	0.030	0.026	0.043	0.036	0.043
20	0.034	0.034	0.033	0.032	0.032	0.032	0.034
21	0.030	0.028	0.028	0.027	0.046	0.036	0.046
22	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24	0.000	0.000	0.000	0.030	0.046	0.036	0.046
25	0.000	0.000	0.034	0.034	0.032	0.030	0.034
26	0.028	0.028	0.027	0.046	0.038	0.035	0.046
27	0.036	0.032	0.030	0.029	0.046	0.039	0.046
28	0.036	0.000	0.000	0.032	0.030	0.041	0.041
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

<p align="center">Conventional or Direct Filtration</p> <p>95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p> <p>All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p> <p>All turbidity readings < IFE² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No</p>	<p align="center">Monthly Summary (Answer Yes or No)</p> <p>CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No</p> <p>All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No</p>
<p>Notes:</p>	<p>PRINTED NAME: Ronald Wanner</p> <p>SIGNATURE: <i>Ronald Wanner</i></p> <p>PHONE #: (503) 738-5112</p> <p>DATE: 3/3/24</p> <p>T-08898</p>

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

2

System Name: Seaside ID#: 4100799 WTP -: A Disinfection Giardia Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak H Dema Flo
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPD]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	1.07	148	158.36	7.4	7.40	43	Yes	200
4	1.20	148	177.60	7.4	7.40	43	Yes	200
5	1.14	148	168.72	7.2	7.50	43	Yes	200
6	1.20	148	177.60	6.9	7.50	43	Yes	200
7	1.18	148	174.64	6.9	7.50	43	Yes	200
8	0.00	0	0.00	0.0	0.00	0	Yes	0
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	1.07	148	158.36	7.0	7.40	43	Yes	200
11	1.18	148	174.64	6.8	7.50	43	Yes	200
12	1.15	148	170.20	6.7	7.50	43	Yes	200
13	1.17	148	173.16	6.1	7.40	43	Yes	200
14	1.11	148	164.28	5.9	7.50	43	Yes	200
15	0.00	0	0.00	0.0	0.00	0	Yes	0
16	0.00	0	0.00	0.0	0.00	0	Yes	0
17	0.88	148	130.24	7.0	7.50	42	Yes	200
18	1.06	148	156.88	7.0	7.40	43	Yes	200
19	1.13	148	167.24	7.6	7.50	43	Yes	200
20	1.11	148	164.28	8.0	7.50	43	Yes	200
21	1.09	148	161.32	8.3	7.50	43	Yes	200
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.95	132	125.40	9.6	7.40	42	Yes	2200
25	1.02	132	134.64	8.9	7.50	43	Yes	2200
26	1.08	132	142.56	9.7	7.30	43	Yes	2200
27	1.09	132	143.88	9.9	7.30	43	Yes	2200
28	1.02	115	117.30	10.0	7.40	23	Yes	2400
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.