

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

25-Mar

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3	0.000	0.000	0.000	0.026	0.032	0.041	0.041
4	0.034	0.032	0.030	0.032	0.054	0.042	0.054
5	0.036	0.000	0.033	0.032	0.033	0.040	0.040
6	0.036	0.000	0.000	0.032	0.033	0.040	0.040
7	0.036	0.000	0.000	0.034	0.033	0.042	0.042
8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.032	0.056	0.040	0.056
11	0.037	0.034	0.034	0.030	0.046	0.039	0.046
12	0.037	0.000	0.000	0.036	0.034	0.034	0.037
13	0.034	0.000	0.000	0.029	0.046	0.036	0.046
14	0.037	0.034	0.000	0.038	0.049	0.041	0.049
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17	0.000	0.000	0.040	0.036	0.049	0.042	0.049
18	0.040	0.039	0.036	0.036	0.034	0.034	0.040
19	0.032	0.000	0.000	0.030	0.046	0.040	0.046
20	0.039	0.038	0.000	0.037	0.035	0.036	0.039
21	0.033	0.000	0.000	0.054	0.043	0.040	0.054
22	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24	0.000	0.000	0.000	0.032	0.053	0.044	0.053
25	0.038	0.038	0.037	0.030	0.030	0.030	0.038
26	0.030	0.028	0.000	0.036	0.034	0.032	0.036
27	0.032	0.030	0.032	0.030	0.037	0.034	0.037
28	0.032	0.031	0.000	0.032	0.032	0.041	0.041
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.030	0.032	0.042	0.042

Conventional or Direct Filtration 95% of daily turbidity readings $\leq$ 0.3 NTU? <u>Yes</u>/ No All daily turbidity readings $\leq$ 1 NTU? <u>Yes</u>/ No All turbidity readings < IFE² triggers <u>Yes</u>/ No	Monthly Summary (Answer Yes or No) <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%;">CT's met everyday? (see back)</td> <td style="width:50%;">All Cl₂ residual at entry point $\geq$ 0.2 mg/l?</td> </tr> <tr> <td align="center"><u>Yes</u>/ No</td> <td align="center"><u>Yes</u>/ No</td> </tr> </table>	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?	<u>Yes</u> / No	<u>Yes</u> / No
CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?				
<u>Yes</u> / No	<u>Yes</u> / No				
Notes:	PRINTED NAME: Ronald Wanner SIGNATURE: <i>Ronald Wanner</i> DATE: 4/1/25 PHONE #: (503) 738-5112 T-08898				

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

25-Ma

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hour Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	0.91	115	104.65	10.2	7.30	22	Yes	2400
4	1.06	115	121.90	10.7	7.40	23	Yes	2400
5	1.12	115	128.80	10.9	7.50	23	Yes	2400
6	1.05	115	120.75	10.7	7.30	23	Yes	2400
7	1.06	115	121.90	10.8	7.30	23	Yes	2400
8	0.00	0	0.00	0.0	0.00	0	Yes	0
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	0.96	115	110.40	10.8	7.30	22	Yes	2400
11	1.13	132	149.16	10.9	7.40	23	Yes	2200
12	1.07	132	141.24	10.8	7.70	28	Yes	2200
13	1.08	132	142.56	10.9	7.50	23	Yes	2200
14	1.12	132	147.84	10.6	7.40	23	Yes	2200
15	0.00	0	0.00	0.0	0.00	0	Yes	0
16	0.00	0	0.00	0.0	0.00	0	Yes	0
17	1.07	132	141.24	10.5	7.40	23	Yes	2200
18	1.12	132	147.84	10.4	7.50	23	Yes	2200
19	1.06	132	139.92	10.7	7.50	23	Yes	2200
20	1.09	132	143.88	10.6	7.40	23	Yes	2200
21	1.13	132	149.16	10.6	7.50	23	Yes	2200
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.91	132	120.12	10.9	7.50	22	Yes	2200
25	1.03	132	135.96	11.1	7.30	23	Yes	2200
26	0.99	132	130.68	11.5	7.30	23	Yes	2200
27	1.08	132	142.56	11.7	7.50	23	Yes	2200
28	1.00	132	132.00	12.0	7.40	22	Yes	2200
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.83	132	109.56	12.2	7.50	22	Yes	2200

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012