

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

25-Apr

System Name: **SEASIDE** ID#: **4100799** WTP - : **A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.036	0.034	0.032	0.032	0.047	0.036	0.047
2	0.035	0.034	0.032	0.032	0.032	0.036	0.036
3	0.036	0.034	0.032	0.032	0.050	0.036	0.050
4	0.034	0.000	0.000	0.032	0.043	0.036	0.043
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7	0.000	0.000	0.000	0.030	0.043	0.036	0.043
8	0.034	0.032	0.032	0.032	0.040	0.038	0.040
9	0.034	0.032	0.032	0.032	0.046	0.036	0.046
10	0.034	0.034	0.034	0.032	0.045	0.036	0.045
11	0.036	0.000	0.000	0.034	0.044	0.036	0.044
12	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.036	0.053	0.044	0.053
15	0.042	0.042	0.042	0.042	0.041	0.040	0.042
16	0.038	0.000	0.000	0.036	0.056	0.044	0.056
17	0.042	0.042	0.040	0.042	0.058	0.046	0.058
18	0.044	0.042	0.040	0.040	0.050	0.046	0.050
19	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21	0.000	0.000	0.000	0.064	0.050	0.044	0.064
22	0.043	0.044	0.042	0.068	0.040	0.046	0.068
23	0.048	0.044	0.000	0.042	0.055	0.048	0.055
24	0.046	0.044	0.046	0.044	0.044	0.042	0.046
25	0.042	0.041	0.000	0.063	0.050	0.048	0.063
26	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28	0.000	0.000	0.000	0.034	0.043	0.035	0.043
29	0.034	0.032	0.034	0.032	0.030	0.032	0.034
30	0.028	0.033	0.000	0.036	0.032	0.030	0.036
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration

95% of daily turbidity readings $\leq$ 0.3 NTU? ☒ Yes ☐ No

All daily turbidity readings $\leq$ 1 NTU? ☒ Yes ☐ No

All turbidity readings < IFE² triggers ☒ Yes ☐ No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)

☒ Yes ☐ No

All Cl₂ residual at entry point $\geq$ 0.2 mg/l?

☒ Yes ☐ No

Notes:

PRINTED NAME: **Ronald Wanner**

SIGNATURE: *Ronald Wanner*

DATE: **5/1/25**

PHONE #: (503) 738-5112

T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

25-Apr

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.12	132	147.84	12.2	7.50	23	Yes	2200
2	1.09	132	143.88	12.2	7.50	23	Yes	2200
3	1.06	132	139.92	12.1	7.50	23	Yes	2200
4	1.01	132	133.32	12.1	7.50	23	Yes	2200
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	0.00	0	0.00	0.0	0.00	0	Yes	0
7	0.85	132	112.20	12.6	7.40	22	Yes	2200
8	1.07	132	141.24	12.6	7.40	23	Yes	2200
9	1.06	132	139.92	12.6	7.40	23	Yes	2200
10	1.04	132	137.28	12.6	7.50	23	Yes	2200
11	0.95	132	125.40	12.8	7.50	22	Yes	2200
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	0.00	0	0.00	0.0	0.00	0	Yes	0
14	0.76	132	100.32	13.0	7.40	22	Yes	2200
15	1.03	132	135.96	13.3	7.40	23	Yes	2200
16	0.96	132	126.72	13.4	7.40	22	Yes	2200
17	1.05	132	138.60	13.5	7.40	23	Yes	2200
18	1.00	132	132.00	13.6	7.50	22	Yes	2200
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	0.00	0	0.00	0.0	0.00	0	Yes	0
21	0.92	132	121.44	13.9	7.40	22	Yes	2200
22	1.16	132	153.12	13.9	7.40	23	Yes	2200
23	1.08	132	142.56	13.9	7.40	23	Yes	2200
24	1.13	132	149.16	14.1	7.50	23	Yes	2200
25	1.06	132	139.92	14.3	7.40	23	Yes	2200
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.00	0	0.00	0.0	0.00	0	Yes	0
28	0.71	132	93.72	14.5	7.50	22	Yes	2200
29	1.09	132	143.88	14.7	7.40	23	Yes	2200
30	1.05	132	138.60	14.7	7.50	23	Yes	2200
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012