

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

25-May

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.028	0.028	0.000	0.028	0.041	0.030	0.041
2	0.028	0.028	0.038	0.036	0.036	0.034	0.038
3	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.000	0.042	0.036	0.034	0.042
6	0.032	0.032	0.000	0.032	0.033	0.032	0.033
7	0.000	0.000	0.000	0.047	0.036	0.034	0.047
8	0.034	0.040	0.036	0.036	0.034	0.034	0.040
9	0.030	0.000	0.000	0.039	0.036	0.034	0.039
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12	0.000	0.000	0.000	0.036	0.040	0.037	0.040
13	0.036	0.036	0.036	0.036	0.034	0.036	0.036
14	0.036	0.034	0.036	0.039	0.033	0.036	0.039
15	0.031	0.031	0.000	0.031	0.031	0.029	0.031
16	0.000	0.000	0.000	0.029	0.037	0.034	0.037
17	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19	0.000	0.000	0.000	0.034	0.035	0.030	0.035
20	0.029	0.030	0.031	0.030	0.031	0.030	0.031
21	0.031	0.029	0.000	0.033	0.033	0.031	0.033
22	0.031	0.031	0.000	0.031	0.033	0.031	0.033
23	0.031	0.000	0.000	0.038	0.034	0.035	0.038
24	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26	0.000	0.000	0.000	0.035	0.043	0.037	0.043
27	0.037	0.037	0.037	0.036	0.037	0.039	0.039
28	0.035	0.035	0.000	0.040	0.038	0.035	0.040
29	0.035	0.034	0.039	0.037	0.035	0.035	0.039
30	0.034	0.033	0.000	0.034	0.031	0.031	0.034
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 0.3 NTU?	☒ Yes / ☐ No	CT's met everyday? (see back)	All Cl ₂ residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 1 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
All turbidity readings < IFE ² triggers	☒ Yes / ☐ No		

Notes:	PRINTED NAME: Ronald Wanner	
	SIGNATURE: <i>Ronald Wanner</i>	DATE: 6/2/25
	PHONE #: (503) 738-5112	T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

25-May

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.05	132	138.60	14.8	7.50	23	Yes	2200
2	1.06	132	139.92	15.0	7.50	15	Yes	2200
3	0.00	0	0.00	0.0	0.00	0	Yes	0
4	0.00	0	0.00	0.0	0.00	0	Yes	0
5	0.66	132	87.12	15.2	7.50	15	Yes	2200
6	0.97	148	143.56	15.4	7.40	15	Yes	2000
7	0.96	148	142.08	15.6	7.40	15	Yes	2000
8	1.07	148	158.36	15.6	7.40	15	Yes	2000
9	1.02	148	150.96	15.7	7.50	15	Yes	2000
10	0.00	0	0.00	0.0	0.00	0	Yes	0
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	0.47	148	69.56	15.7	7.50	15	Yes	2000
13	1.09	148	161.32	16.0	7.40	15	Yes	2000
14	1.06	148	156.88	16.1	7.30	15	Yes	2000
15	0.97	148	143.56	16.2	7.40	15	Yes	2000
16	0.92	148	136.16	16.0	7.50	15	Yes	2000
17	0.00	0	0.00	0.0	0.00	0	Yes	0
18	0.00	0	0.00	0.0	0.00	0	Yes	0
19	0.76	148	112.48	15.7	7.50	15	Yes	2000
20	1.05	148	155.40	15.8	7.50	15	Yes	2000
21	0.97	148	143.56	15.9	7.50	15	Yes	2000
22	0.95	148	140.60	16.0	7.50	15	Yes	2000
23	0.90	148	133.20	16.1	7.40	15	Yes	2000
24	0.00	0	0.00	0.0	0.00	0	Yes	0
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.64	148	94.72	16.4	7.50	14	Yes	2000
27	1.06	148	156.88	16.6	7.40	15	Yes	2000
28	1.01	148	149.48	16.9	7.50	15	Yes	2000
29	1.10	148	162.80	17.2	7.40	15	Yes	2000
30	1.05	148	155.40	17.2	7.40	15	Yes	2000
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012