

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

25-Jun

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.029	0.039	0.031	0.039
3	0.031	0.030	0.031	0.030	0.029	0.029	0.031
4	0.031	0.030	0.000	0.033	0.031	0.031	0.033
5	0.030	0.029	0.031	0.033	0.033	0.029	0.033
6	0.029	0.028	0.028	0.028	0.031	0.034	0.034
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9	0.000	0.000	0.000	0.035	0.045	0.035	0.045
10	0.037	0.041	0.041	0.037	0.037	0.038	0.041
11	0.035	0.035	0.041	0.052	0.042	0.041	0.052
12	0.050	0.050	0.039	0.045	0.045	0.045	0.050
13	0.060	0.060	0.052	0.073	0.075	0.062	0.075
14	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16	0.000	0.000	0.000	0.035	0.055	0.043	0.055
17	0.041	0.041	0.039	0.039	0.049	0.045	0.049
18	0.041	0.043	0.043	0.039	0.043	0.039	0.043
19	0.042	0.040	0.037	0.033	0.042	0.037	0.042
20	0.000	0.000	0.000	0.037	0.045	0.037	0.045
21	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23	0.000	0.000	0.000	0.035	0.043	0.041	0.043
24	0.041	0.040	0.039	0.041	0.054	0.047	0.054
25	0.043	0.029	0.029	0.031	0.043	0.039	0.043
26	0.035	0.000	0.000	0.035	0.044	0.038	0.044
27	0.035	0.000	0.000	0.033	0.039	0.037	0.039
28	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.029	0.037	0.034	0.037
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU? <u>Yes</u> / No All daily turbidity readings ≤ 1 NTU? <u>Yes</u> / No All turbidity readings < IFE ² triggers <u>Yes</u> / No	CT's met everyday? (see back) <u>Yes</u> / No All Cl2 residual at entry point ≥ 0.2 mg/l? <u>Yes</u> / No		

Notes: 	PRINTED NAME: Ronald Wanner	
	SIGNATURE: <i>Ronald Wanner</i>	DATE: 7/1/25
	PHONE #: (503) 738-5112 T-08898	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = (Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

25-Jun

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.62	132	81.84	17.3	7.40	15	Yes	2200
3	1.08	148	159.84	17.8	7.50	15	Yes	2000
4	1.06	148	156.88	18.1	7.50	15	Yes	2000
5	1.07	148	158.36	18.3	7.50	15	Yes	2000
6	1.11	148	164.28	18.3	7.40	15	Yes	2000
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.00	0	0.00	0.0	0.00	0	Yes	0
9	0.56	148	82.88	18.6	7.50	14	Yes	2000
10	0.84	132	110.88	18.9	7.40	15	Yes	2200
11	0.98	123	120.54	19.1	7.50	15	Yes	2300
12	0.99	123	121.77	19.1	7.50	15	Yes	2300
13	0.93	123	114.39	19.5	7.50	15	Yes	2300
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.00	0	0.00	0.0	0.00	0	Yes	0
16	0.53	123	65.19	19.2	7.50	14	Yes	2300
17	1.06	123	130.38	19.3	7.50	15	Yes	2300
18	0.99	123	121.77	19.5	7.50	15	Yes	2300
19	0.94	123	115.62	19.6	7.40	15	Yes	2300
20	0.78	123	95.94	19.6	7.50	15	Yes	2300
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	0.73	123	89.79	19.0	7.50	15	Yes	2300
24	0.90	123	110.70	19.2	7.40	15	Yes	2300
25	1.08	123	132.84	19.1	7.40	15	Yes	2300
26	0.80	123	98.40	19.1	7.50	15	Yes	2300
27	0.84	123	103.32	19.1	7.50	15	Yes	2300
28	0.00	0	0.00	0.0	0.00	0	Yes	0
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.38	123	46.74	19.3	7.40	14	Yes	2300
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012