

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

25-Jul

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.031	0.035	0.033	0.031	0.041	0.033	0.041
2	0.031	0.041	0.039	0.031	0.044	0.035	0.044
3	0.033	0.033	0.000	0.031	0.040	0.035	0.040
4	0.031	0.029	0.031	0.033	0.042	0.031	0.042
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7	0.000	0.000	0.000	0.024	0.029	0.027	0.029
8	0.026	0.026	0.029	0.026	0.031	0.031	0.031
9	0.026	0.029	0.029	0.028	0.035	0.033	0.035
10	0.029	0.029	0.029	0.041	0.037	0.029	0.041
11	0.035	0.029	0.000	0.043	0.038	0.035	0.043
12	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.037	0.035	0.037	0.037
15	0.035	0.033	0.031	0.037	0.062	0.039	0.062
16	0.065	0.062	0.038	0.032	0.033	0.042	0.065
17	0.037	0.035	0.033	0.045	0.046	0.041	0.046
18	0.036	0.033	0.000	0.052	0.036	0.035	0.052
19	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21	0.000	0.000	0.000	0.053	0.049	0.048	0.053
22	0.051	0.048	0.048	0.048	0.039	0.038	0.051
23	0.037	0.037	0.045	0.035	0.049	0.035	0.049
24	0.033	0.042	0.033	0.031	0.039	0.033	0.042
25	0.031	0.000	0.000	0.033	0.041	0.029	0.041
26	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28	0.000	0.000	0.000	0.041	0.042	0.029	0.042
29	0.028	0.030	0.033	0.029	0.033	0.030	0.033
30	0.028	0.029	0.032	0.035	0.040	0.031	0.040
31	0.029	0.029	0.032	0.033	0.036	0.033	0.036

Conventional or Direct Filtration 95% of daily turbidity readings ≤ 0.3 NTU? <u>Yes</u> / No All daily turbidity readings ≤ 1 NTU? <u>Yes</u> / No All turbidity readings < IFE² triggers <u>Yes</u> / No	Monthly Summary (Answer Yes or No) <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%;">CT's met everyday? (see back)</td> <td style="width:50%;">All Cl2 residual at entry point ≥ 0.2 mg/l?</td> </tr> <tr> <td align="center"><u>Yes</u> / No</td> <td align="center"><u>Yes</u> / No</td> </tr> </table>	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?	<u>Yes</u> / No	<u>Yes</u> / No
CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?				
<u>Yes</u> / No	<u>Yes</u> / No				
Notes:					
PRINTED NAME: Ronald Wanner SIGNATURE: <i>Ronald Wanner</i> DATE: 8/1/2025 PHONE #: (503) 738-5112 T-08898					

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

25-Jul

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.88	123	108.24	19.3	7.40	15	Yes	2300
2	0.98	123	120.54	19.6	7.50	15	Yes	2300
3	0.88	123	108.24	19.6	7.40	15	Yes	2300
4	1.00	123	123.00	19.7	7.40	15	Yes	2300
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	0.00	0	0.00	0.0	0.00	0	Yes	0
7	0.35	123	43.05	19.8	7.40	14	Yes	2300
8	0.96	123	118.08	19.9	7.50	15	Yes	2300
9	1.00	123	123.00	20.2	7.30	11	Yes	2300
10	1.12	123	137.76	20.2	7.40	12	Yes	2300
11	0.93	123	114.39	20.3	7.30	11	Yes	2300
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	0.00	0	0.00	0.0	0.00	0	Yes	0
14	0.54	123	66.42	20.4	7.50	11	Yes	2300
15	1.03	123	126.69	20.6	7.40	12	Yes	2300
16	1.14	123	140.22	20.7	7.40	12	Yes	2300
17	1.09	123	134.07	21.0	7.50	12	Yes	2300
18	1.06	123	130.38	21.1	7.50	0	Yes	2300
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	0.00	0	0.00	0.0	0.00	0	Yes	0
21	0.69	123	84.87	21.0	7.50	11	Yes	2300
22	1.07	123	131.61	21.1	7.50	11	Yes	2300
23	1.08	123	132.84	21.2	7.40	11	Yes	2300
24	1.08	123	132.84	21.4	7.50	11	Yes	2300
25	1.00	123	123.00	21.2	7.80	13	Yes	2300
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.00	0	0.00	0.0	0.00	0	Yes	0
28	0.90	123	110.70	21.1	7.50	11	Yes	2300
29	1.09	123	134.07	21.3	7.40	12	Yes	2300
30	1.06	123	130.38	21.5	7.50	12	Yes	2300
31	1.05	123	129.15	21.5	7.50	12	Yes	2300

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012